

# Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018  
(IET Wiring Regulations 18th Edition)



## Information for recipients:

The purpose of this report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).

The person ordering the report should have received the Original©Report and the inspector should have retained a duplicate.

The Original©Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested every 6 months. **For safety reasons it is important that these instructions are followed.**

Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The Inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licencing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.

For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in Section K as C2 ("Potentially Dangerous"), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated in Section K that an observation requires further investigation code FI the inspection has revealed an apparent deficiency which may result on a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the report under 'Recommendations' and on label at or near to the consumer unit/distribution board.

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/  
EICR 3486000001193

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)



## A. Details of the Installation

Client	WESSEX RFCA	Installation	243 (wx) FIELD HOSPITAL c SQUADRON
Address	MOUNT HOUSE MOUNT STREET TAUNTON SOMERSET	Address	TRURO DETACHMENT MORESK ROAD TRURO CORNWALL
Postcode	TA1 3QU	Postcode	TR1 1DF

## B. Reason for Producing this Report *This form is to be used only for reporting on the condition of an existing installation.*

SAFETY

Date(s) on which the inspection and testing were carried out 20/09/2021 to 20/09/2021

## C. Details of Installation which is the Subject of this Report

Description of premises Domestic ☐ Commercial ☒ Industrial ☐ Other (please specify)   
Estimated age of the wiring system 25 years  
Evidence of alterations or addition Yes ☐ No ☒ Not apparent ☐ if 'Yes', estimated  years  
Records of installation available Yes ☐ No ☒ Records held by   
Date of last inspection 01/10/2016 Electrical Installation Certificate No. or previous Inspection Report No. ?

## D. Extent of Electrical Installation Covered by this Report:

AS PER SCHEDULES

### Agreed Limitations and Operational Limitations (Regulations 653.2)

DB1 CCT 2/L3 NO TESTS CARRIED OUT DUE TO IT BEING SEPARATE SUPPLY TO DATA CABINET. UNABLE TO ISOLATE AND TEST SERVER ROOM (DB1/1 CCT 12/L2). NO TESTING CARRIED OUT AT HIGH LEVEL EXTERNAL LIGHTING (WILL NEED TO BE LOOKED INTO DUE TO VERY LOW IR READINGS. NO TESTING CARRIED OUT AT HIGH LEVEL GYM LIGHTING. NO TEST TAKEN AT HIGH LEVEL GARAGE LIGHTS.

Agreed with: .

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to 2020

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

## E. Summary of the Condition of the Installation

General conditions of the installation (in terms of electrical safety)

UN-SATISFACTORY - URGENT REMEDIAL WORKS REQUIRED.

Overall assessment of the installation in terms of its suitability for continued use

SATISFACTORY ☐

\*UNSATISFACTORY ☒



\*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2), Further investigation (code FI) conditions have been identified

## F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by 20/10/2022 (date)

## G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	Technical Electrical Engineering Ltd t/a Mr Electric		Inspected and tested by		Authorised for issue by	
Address	Wheal Kitty Studios, Wheal Kitty, St Agnes,		Name:	Ed Rowe	Steve Creese	
			Signature:			
			Position:	Technician	Qualified Supervisor	
Postcode	TR5 0RD		Date:	20/09/2021	29/09/2021	
Branch No.						
Scheme No.	019875					

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/  
EICR 3486000001193

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)



## H. Schedule(s)

2 schedule(s) of inspection and 15 schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

## I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input checked="" type="checkbox"/>	TT <input type="checkbox"/>	Other <input type="checkbox"/>	Please specify	
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	3	No. of wires	4
<b>Nature of Supply Parameters (Note: <sup>(1)</sup> by enquiry, <sup>(2)</sup> by enquiry or by measurement)</b>						
Nominal voltage, U <sub>0</sub> <sup>(1)</sup>	400/230	v	Nominal frequency, f <sup>(1)</sup>	50	Hz	Confirmation of supply polarity <input checked="" type="checkbox"/>
Prospective fault current, I <sub>pf</sub> <sup>(2)</sup>	4	kA	External loop impedance, Z <sub>e</sub> <sup>(2)</sup>	0.19	Ω	
Supply Protective Device BS (EN)	1361 Fuse HBC 1	Type	1	Rated Current	100	A
No. of Additional Supplies	0					

## J. Particulars of Installation Referred to in this Report

<b>Details of installation Earth Electrode</b> (where applicable) Type (e.g. rod(s), tape etc)			<b>Means of Earthing</b>				
Location			Distributors facility <input checked="" type="checkbox"/>	Installation Earth Electrode <input type="checkbox"/>			
Electrode resistance to earth			Maximum Demand (load)	50	Amps <input checked="" type="checkbox"/> KVA <input type="checkbox"/>		
<b>Main Protective Conductors</b>			<b>Material</b>	<b>csa</b>	<b>(✓) or Value</b>		
Earthing Conductor			Copper	25	Continuity Verified <input checked="" type="checkbox"/> Ω		
Protective Bonding Conductor (to extraneous-conductive-parts)			Copper	10	Continuity Verified <input type="checkbox"/> LIM Ω		
<b>Main Supply Conductor</b>			Copper	35	(connection / continuity) (✓) or Value		
<b>Main Switch</b> Location			BT OFFICE FRONT	Water installation <input checked="" type="checkbox"/> Ω			
<b>Fuse/device rating or setting</b>			100	A	Gas installation pipes <input checked="" type="checkbox"/> Ω		
<b>If RCD main switch:</b>			Rated residual operating current I Δn	N/A	mA		
BS(EN)			60947-3	No. of Poles	4		
Current Rating			100	A	Rated time delay	N/A	ms
Measured operating trip time			N/A	ms			

## K. Observations

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

- ☐ No remedial work required
- ☒ The following observations are made

### Explanation of codes

- C1** Danger present. Risk of Injury. Immediate remedial action required.
- C2** Potentially dangerous. Urgent remedial action required.
- C3** Improvement recommended.
- FI** Further Investigation required without delay

Item No.	Observations	Code
1	DB - : 5.2 Cables correctly supported throughout their run (521.10.202; 522.8.5) where visible	▲
2	DB - : 5.10 Concealed cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) - Only checked where visible	▲
3	DB - : 5.11 Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6.204) -Only checked where visible	▲
4	DB - : 5.15 Cables segregated/separated from communications cabling (528.2) Only checked where visible	▲
5	DB - : 5.16 Cables segregated/separated from non-electrical services (528.3) Only checked where visible	▲
6	3.1.3 Adequacy of earthing conductor size (542.3; 543.1.1)	●
7	DB Entire Installation : 1.9 Correct identification of circuit details and protective devices (514.8.1; 514.9.1) -	●
8	DB Entire Installation : 1.10 Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2) -	●
9	DB Entire Installation : 1.13 Presence of other required labelling (Please specify) (Section 514) -	●
10	DB Entire Installation : 1.11 Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14) -	●
11	DB Entire Installation : 1.18 RCD(s) provided for fault protection - includes RCBO(s)(411.4.204; 411.5.2; 531.2) -	●
12	DB Entire Installation : 1.19 RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1) - No RCD protection for socket-outlets for internal use (411.3.3)	●
13	DB Entire Installation : 2.1 Identification of conductors (514.3.1) -	●
14	DB Entire Installation : 2.10 Connected cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) Only where visible	▲
15	DB Entire Installation : 2.11 Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.204)Only where visible	▲
16	DB Entire Installation : 2.12.1 For all socket-outlets of rating 32 A or less unless exempt (4.11.3.3) -	●
17	DB Entire Installation : 2.12.3 For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	●
18	DB Entire Installation : 2.12.4 For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	●
19	DB Entire Installation : 2.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1) -	●

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/  
EICR 3486000001193

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)



20	DB Entire Installation : 1.16 Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11) - The sharp metal edges of the containment have not been provided with protection (522.8.1;522.8.11)	C2
21	DB Entire Installation : 2.17.1 Connections soundly made and under no undue strain (526.6) -	C3
22	DB Entire Installation : 2.17.2 No basic insulation of a conductor visible outside enclosure (526.8)	C3
23	DB Entire Installation : 2.17.4 Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) -	C3
24	5.23 Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11) - The sharp metal edges of the containment have not been provided with protection (522.8.1;522.8.11)	C2
25	3.1.4 Adequacy of earthing conductor connections (542.3.2) -	C3
26	DB Entire Installation : 2.18 Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v)) - See written report	C2
27	6.1 Identification of conductors (514.3.1) Various not labelled and not found.	FI
28	6.11 Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	FI
29	6.2 Cables correctly supported throughout their run (521.10.202; 522.8.5)	C2
30	6.24 General condition of wiring systems (651.2) FURTHER INVESTIGATIONS REQUIRED	FI
31	6.19 Condition of circuit accessories (651.2) See written report	C2
32	5.13 RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	C2
33	DB Entire Installation : 2.2 Cables correctly supported throughout their run (521.10.202; 522.8.5) -	C3
34	DB Entire Installation : 2.8 Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	FI
35	DB Entire Installation : 2.12.2 For the supply of Mobile equipment not exceeding 32 A rating for use outdoors (411.3.3) - RCD protection not provided for equipment rated up to 32 A and used outdoors (411.3.3)	C2
36	DB Entire Installation : 2.17.3 Connections of live conductors adequately enclosed (526.5)	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1 Danger present. Risk of Injury. Immediate remedial action required.	
C2 Potentially dangerous. Urgent remedial action required.	16, 19, 20, 24, 26, 29, 31, 32, 35
C3 Improvement recommended.	6, 7, 8, 9, 10, 11, 12, 13, 17, 18, 21, 22, 23, 25, 33, 36
FI Further Investigation required without delay	27, 28, 30, 34



## Outcomes

Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:
	or					

Item No.	Description	Outcome
----------	-------------	---------

**1.0 External Condition Of Intake Equipment (Visual Inspection Only) Where inadequacies are encountered, it is recommended that the person ordering the report informs the appropriate authority**

1.1	Service cable	
1.2	Service head	
1.3	Earthing arrangement	
1.4	Meter tails	
1.5	Metering equipment	
1.6	Isolator (where present)	

**2.0 Parallel Or Switched Alternative Sources Of Supply**

2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	

**3.0 Automatic Disconnection Of Supply**

3.1	Main earthing/bonding arrangements (411.3; Chap 54)	
3.1.1	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	
3.1.4	Adequacy of earthing conductor connections (542.3.2)	
3.1.5	Accessibility of earthing conductor connections (543.3.2)	
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	
3.1.8	Accessibility of all protective bonding connections (543.3.2)	
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	
3.2	FELV - requirements satisfied (411.7; 411.7.1)	

**4.0 Other Methods Of Protection (Where any of the methods listed below are employed details should be provided on separate sheets)**

4.1	Non-conducting location (418.1)	
4.2	Earth-free local equipotential bonding (418.2)	
4.3	Electrical separation (Section 413; 418.3)	
4.4	Double insulation (Section 412)	
4.5	Reinforced insulation (Section 412)	

**5.0 Distribution Equipment**

5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	
5.2	Security of fixing (134.1.1)	
5.3	Condition of insulation of live parts (416.1)	
5.4	Adequacy/security of barriers (416.2)	
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	
5.8	Presence and effectiveness of obstacles (417.2)	
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	
5.10	Operation of main switch(es) (functional check) (643.10)	
5.11	Manual operation of circuit-breakers and RCD(s) to prove disconnection (643.10)	
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	
5.17	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	
5.18	Presence of alternative supply warning notice at or near equipment, where required (514.15)	
5.19	Presence of next inspection recommendation label (514.12.1)	
5.20	Presence of other required labelling (please specify) (Section 514)	
5.21	Compatibility of protective device, base and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.4.5; 411.4.6; Sections 432; 433)	
5.22	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	

**6.0 Distribution Circuits**



6.1	Identification of conductors (514.3.1)	FI
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	C2
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. Integrity of containment (521.10.1)	✓
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	FI
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	✓
<b>6.15</b>	<b>Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts</b>	
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) or	NA
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	NA
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	NA
6.18	Cables segregated/separated from non-electrical services (528.3)	NA
6.19	Condition of circuit accessories (651.2)	C2
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; 537)	✓
6.24	General condition of wiring systems (651.2)	FI
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	✓

Inspector's Name: Ed Rowe

Signature:

Date: 21/09/2021



ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)

FT/ EICR 3486000001193



Company Name

Technical Electrical Engineering Ltd t/a Mr Electric

Company Address

Wheal Kitty Studios

Postcode

TR5 0RD

Branch No.

Scheme No.

019875

Client

WESSEX RFCA

Installation Address

, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL

Postcode

TR1 1DF

Distribution board details - Complete in every case

Location

BT OFFICE FRONT

Designation

DB 1

Num. of ways

8

Num. of phases

3

Supply polarity confirmed☒

Phase sequence confirmed☒

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from

Overcurrent protective device for the distribution circuit: Type Rating A Voltage

230

 V

Characteristics at this distribution board

Associated RCD(if any): BS (EN)

N/A

Operating at 1 IΔn

N/A

 ms

30mA or below

Operating at 5 IΔn

N/A

 ms

Time delay (if applicable)

N/A

Associated RCD(if any): BS (EN)

N/A

Operating at 1 IΔn

N/A

 ms

30mA or below

Operating at 5 IΔn

N/A

 ms

Time delay (if applicable)

N/A

Test instrument serial number(s)

Loop impedance

1008128101650691

Insulation resistance

1008128101650691

Continuity

1008128101650691

RCD

1008128101650691

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 100%	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity  (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB 1				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2    R2	Test voltage  V	L/L, L/N  M(Ω)	L/E, N/E  M(Ω)	Above 30mA IΔn  ms			30mA or below 5 IΔn  ms	RCD  (✓)	AFDD  (✓)		
	Circuit designation													r1	r	r2													
1/L1	Sub Mains(DB 1/2)	A	A	1	10	4	0.4	60898 MCB T	B	63	10	N/A	0.69	NA	NA	NA	✓	0.26	N/A	250	100	100	✓	0.33	N/A	N/A	✓	N/A	
1/L2	Sub Mains(DB 1/3)	A	A	1	10	4	0.4	60898 MCB T	B	63	10	N/A	0.69	NA	NA	NA	✓	0.27	N/A	250	100	100	✓	0.56	N/A	N/A	✓	N/A	
1/L3	Sub Mains(DB 1/5)	A	A	1	10	4	0.4	60898 MCB T	B	63	10	N/A	0.69	NA	NA	NA	✓	0.39	N/A	250	100	100	✓	0.38	N/A	N/A	✓	N/A	
2/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	N/A	N/A	N/A	N/A	N/A	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L2	Fire Alarm	O	A	1	1	1	0.4	60898 MCB T	B	6	10	N/A	7.28	NA	NA	NA	✓	0.24	N/A	250	100	100	✓	0.39	N/A	N/A	✓	N/A	
2/L3	OFFICE DATA CABINET	D	A	1	2.5	2.5	0.4	60898 MCB T	B	6	10	N/A	7.28	NA	NA	NA	✓	LIM	N/A	250	LIM	LIM	✓	LIM	N/A	N/A	✓	N/A	
3/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5/L1	DB GARAGE DB1 + DB2	A	A	2	10	4	0.4	60898 MCB T	B	63	10	N/A	0.69	NA	NA	NA	✓	0.13	N/A	250	100	100	✓	0.33	N/A	N/A	✓	N/A	
5/L2	SOCKET BT OFFICE	A	A	1	5	2.5	0.4	60898 MCB T	B	20	10	N/A	2.19	NA	NA	NA	✓	0.4	N/A	250	100	100	✓	0.54	N/A	N/A	✓	N/A	
5/L3	SECURITY LIGHTS	A	A	12	1	1	0.4	60898 MCB T	B	10	10	N/A	4.37	NA	NA	NA	✓	FI	N/A	250	0.04	0.04	✓	FI	N/A	N/A	✓	N/A	
6/TP	DB1/1 ELECTRICAL CUPBOARD	F	A	1	35	35	0.4	60898 MCB Type B	B	63	10	N/A	0.69	NA	NA	NA	✓	0.34	N/A	250	100	100	✓	0.65	N/A	N/A	✓	N/A	
7/L1	GATE SUPPLY	G	A	1	2.5	2.5	0.4	61009 RCD/	C	16	10	N/A	1.37	NA	NA	NA	✓	0.65	N/A	250	0.04	0.04	✓	0.56	N/A	N/A	✓	N/A	
7/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing

Not Specified

To

Not Specified

Date(s) live testing

20/09/2021

To

20/09/2021

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters)

ED ROWE

Position

Technician

Date

20/09/2021

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

FT/  
EICR 3486000001193



Company Name

Technical Electrical Engineering Ltd t/a Mr Electric

Company Address

Wheal Kitty Studios

Postcode

TR5 0RD

Branch No.

Scheme No.

019875

Client

WESSEX RFCA

Installation Address

, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL

Postcode

TR1 1DF

Distribution board details - Complete in every case

Location

MAIN ELECTRIC CUPBOARD

Designation

DB 1/1

Num. of ways

12

Num. of phases

3

Supply polarity confirmed☒

Phase sequence confirmed☒

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from

Overcurrent protective device for the distribution circuit: Type Rating A Voltage V

Characteristics at this distribution board

Associated RCD(if any): BS (EN)

N/A

 Above 30mA (if applicable)

N/A

 ms

Operating at 1 I<sub>Δn</sub>

N/A

 ms

30mA or below

Z<sub>s</sub>

0.62

 Ω No. of poles

N/A

I<sub>pf</sub>

0.687

 kA I<sub>Δn</sub>

N/A

 Operating at 5 I<sub>Δn</sub>

N/A

 ms

Time delay (if applicable)

N/A

Test instrument serial number(s)

Loop impedance

1008128101650691

Insulation resistance

1008128101650691

Continuity

1008128101650691

RCD

1008128101650691

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity  (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	DB 1/1				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both  R1 + R2    R2	Test voltage  V	L/L, L/N  M(Ω)	L/E, N/E  M(Ω)	Above 30mA IΔn  ms			30mA or below 5 IΔn  ms	RCD  (✓)	AFCD  (✓)	
	Circuit designation													r1	rn	r2												

1/L1	Lights LOUNGE/OFFICE	A	A	9	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	1.24	N/A	250	100	100	✓	0.98	7.87	5.09	✓	N/A
1/L2	Lights 10 PLATOON	A	A	8	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	1.68	N/A	250	100	100	✓	0.98	7.48	8.18	✓	N/A
1/L3	HANDRIER LADIES WC	A	A	1	2.5	1.5	0.4	61009 RCD/	C	20	10	0	0.87	NA	NA	NA	✓	0.24	N/A	250	100	100	✓	0.6	14.2	5	✓	N/A
2/L1	Lights 165 SQUADRON	A	A	3	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	0.87	N/A	250	100	100	✓	0.91	7.98	6.87	✓	N/A
2/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	NA	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L3	Lights PASSAGE	A	A	6	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	0.77	N/A	250	100	100	✓	0.91	7.88	7.58	✓	N/A
3/L1	HEATER FAR OFFICE	A	A	2	2.5	1.5	0.4	61009 RCD/	C	20	10	0	0.87	NA	NA	NA	✓	0.65	N/A	250	100	100	✓	0.78	7.88	8.18	✓	N/A
3/L2	HEATER RANGE	A	A	4	2.5	1.5	0.4	61009 RCD/	C	20	10	0	0.87	NA	NA	NA	✓	0.22	N/A	250	100	100	✓	0.39	7.89	8.19	✓	N/A
3/L3	Lights LHS OFFICES	A	A	12	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	1.42	N/A	250	100	100	✓	1.08	8.7	8.59	✓	N/A
4/L1	HEATERS STORES	A	A	4	2.5	1.5	0.4	61009 RCD/	C	20	10	0	0.87	NA	NA	NA	✓	0.56	N/A	250	100	100	✓	0.41	7.8	8.2	✓	N/A
4/L2	SOCKETS OLD SERVERY	A	A	FI	2.5	1.5	0.4	61009 RCD/	C	32	10	0	0.54	0.37	0.38	0.38	✓	FI	N/A	250	100	100	✓	FI	7.9	8.32	✓	N/A
4/L3	Lights WC + GYM	A	A	13	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	0.84	N/A	250	100	100	✓	0.93	7.7	7.4	✓	N/A
5/L1	SOCKETS 165 SQUADRON	A	A	5	2.5	1.5	0.4	61009 RCD/	C	32	10	0	0.54	0.49	0.5	0.82	✓	0.35	N/A	250	100	100	✓	0.64	7.82	7.54	✓	N/A
5/L2	SOCKETS OFFICES	A	A	7	2.5	1.5	0.4	61009 RCD/	C	32	10	0	0.54	0.59	0.59	0.59	✓	0.33	N/A	250	100	100	✓	0.43	6.1	5.8	✓	N/A
5/L3	HEATERS GYM	A	A	4	2.5	1.5	0.4	61009 RCD/	C	20	10	0	0.87	NA	NA	NA	✓	0.55	N/A	250	100	100	✓	0.71	7.7	7.9	✓	N/A
6/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	N/A
6/L2	Lights RANGE SPOTS	A	A	4	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	1.04	N/A	250	100	100	✓	0.65	8.6	8.7	✓	N/A
6/L3	SOCKETS COPY OFFICE	A	A	4	2.5	1.5	0.4	61009 RCD/	C	16	10	0	1.09	NA	NA	NA	✓	0.25	N/A	250	100	100	✓	FI	6.89	8.79	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing

Not Specified

 To 

Not Specified

 Date(s) live testing

20/09/2021

 To 

20/09/2021

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters)

ED ROWE

 Position

Technician

 Date

20/09/2021

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

Created by FastTest © Copyright FastTest 2021

4th Floor, Mill 3, Pleasley Vale Business Park, Mansfield, Nottinghamshire NG19 8RL

Page 8 of 24

NA/EICR/001



*for Industrial/Commercial Premises*

FT/  
EICR 3486000001193

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)



Circuit Details														Test Results														
Circuit No and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity  (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	DB 1/1				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage  V	L/L, L/N  M(Ω)	L/E, N/E  M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD  (✓)	AFDD  (✓)
	Circuit designation													r1	m	r2		R1 + R2	R2									
7/L1	SOCKETS HOSPITAL ROOM	A	A	5	2.5	1.5	0.4	61009 RCD/	C	32	10	0	0.54	0.76	0.76	FI	✓	FI	N/A	250	100	100	✓	FI	7.82	7.54	✓	N/A
7/L2	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	
7/L3	SOCKETS ADMIN	A	A	8	2.5	1.5	0.4	61009 RCD/	C	32	10	0	0.54	0.68	0.69	1	✓	0.46	N/A	250	100	100	✓	0.62	8.87	6.98	✓	N/A
8/L1	REDUNDANT 2AMP SOCKETS HOSPITAL ROOM	A	A	2	1	1	0.4	61009 RCD/RCBO	C	10	10	0	1.75	NA	NA	NA	✓	LIM	N/A	250	100	100	✓	LIM	7.69	8.09	✓	N/A
8/L2	BOILER	A	A	1	2.5	1.5	0.4	61009 RCD/	C	10	10	0	1.75	NA	NA	NA	✓	0.69	N/A	250	100	100	✓	0.41	5.39	8.39	✓	N/A
8/L3	SOCKETS LHS OFFICES	A	A	5	2.5	1.5	0.4	61009 RCD/	C	32	10	0	0.54	0.57	0.57	0.57	✓	0.35	N/A	250	100	100	✓	0.53	8.45	8.65	✓	N/A
9/L1	TUBU HEATERS	A	A	4	2.5	1.5	0.4	61009 RCD/	C	10	10	0	1.75	NA	NA	NA	✓	0.79	N/A	250	100	100	✓	0.41	7.9	8.19	✓	N/A
9/L2	SOCKETS RANGE	A	A	3	2.5	1.5	0.4	61009 RCD/	C	20	10	0	0.87	NA	NA	NA	✓	FI	N/A	250	FI	FI	✓	FI	7.99	8.29	✓	N/A
9/L3	Lights HOSPITAL PASSAGE	A	A	3	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	0.92	N/A	250	100	100	✓	0.57	5.29	5.39	✓	N/A
10/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A	
10/L2	Lights RANGE	A	A	4	1	1	0.4	61009 RCD/	C	6	10	0	2.91	NA	NA	NA	✓	1.07	N/A	250	100	100	✓	0.86	7.59	7.29	✓	N/A
10/L3	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A	
11/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A	
11/L2	SOCKET RANGE FAR	A	A	1	2.5	1.5	0.4	61009 RCD/	C	20	10	0	0.87	NA	NA	NA	✓	0.38	N/A	250	100	100	✓	0.65	7.88	8.28	✓	N/A
11/L3	HANDRYER LADIES	A	A	1	2.5	1.5	0.4	61009 RCD/	C	16	10	0	1.09	NA	NA	NA	✓	0.62	N/A	250	100	100	✓	0.65	18.8	5.65	✓	N/A
12/L1	SER VER SUBMAIN	A	A	1	10	4	0.4	61009 RCD/	C	40	10	0	0.44	NA	NA	NA	✓	LIM	N/A	250	LIM	LIM	✓	LIM	LIM	LIM	✓	N/A
12/L2	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A	
12/L3	HANDRYER GENTS	A	A	1	2.5	1.5	0.4	61009 RCD/	C	16	10	0	1.09	NA	NA	NA	✓	0.55	N/A	250	100	100	✓	0.61	16.3	5.04	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing

Not Specified
---------------

To

Not Specified
---------------

Date(s) live testing

20/09/2021

To	20/09/2021
----	------------

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters)

ED ROWE

Position	Technician
----------	------------

Date 20/09/2021

Signature

Spand

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

FT/  
EICR 3486000001193



Company Name

Technical Electrical Engineering Ltd t/a Mr Electric

Company Address

Wheal Kitty Studios

Postcode

TR5 0RD

Branch No.

Scheme No.

019875

Client

WESSEX RFCA

Installation Address

, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL

Postcode

TR1 1DF

Distribution board details - Complete in every case

Location

OUTSIDE ADMIN OFFICE

Designation

DB 1/2

Num. of ways

12

Num. of phases

1

Supply polarity confirmed

☒

Phase sequence confirmed

☒

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from

Overcurrent protective device for the distribution circuit: Type

B

Rating

63

A

Voltage

230

V

Characteristics at this distribution board

Associated RCD(if any): BS (EN)

N/A

Operating at 1 IΔn

N/A

ms

Zs

0.33

Ω

No. of poles

N/A

30mA or below

Ipf

0.7

kA

IΔn

N/A

Operating at 5 IΔn

N/A

ms

Time delay (if applicable)

N/A

Test instrument serial number(s)

Loop impedance

1008128101650691

Insulation resistance

1008128101650691

Continuity

1008128101650691

RCD

1008128101650691

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other <div>80%</div> (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity  <div>(✓)</div>	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	DB 1/2				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check  <div>(✓)</div>	All circuits to be completed using R1R2 or R2, not both <div>R1 + R2    R2</div>	Test voltage  V	L/L, L/N  M(Ω)	L/E, N/E  M(Ω)	Above 30mA IΔn  ms			30mA or below 5 IΔn  ms	RCD  <div>(✓)</div>	AFCD  <div>(✓)</div>	
	Circuit designation													r1	rn	r2												
1/L1	SOCKET KITCHEN WALL	A	B	9	2.5	1.5	0.4	61009 RCD/	C	32	10	0	0.54	0.87	FI	FI	✓	FI	N/A	250	FI	FI	✓	FI	29.3	19.3	✓	N/A
2/L1	SOCKET ARMOURY	A	B	7	2.5	1.5	0.4	60898 MCB T	C	32	10	0	0.54	0.49	0.48	0.77	✓	0.54	N/A	250	100	100	✓	0.49	28.6	18.7	✓	N/A
3/L1	WATER HEATER MENS CHANGING	A	B	2	2.5	1.5	0.4	60898 MCB Type C	C	16	10	0	1.09	NA	NA	NA	✓	0.37	N/A	250	100	100	✓	0.5	28.6	18.6	✓	N/A
4/L1	REDUNDANT SPUR LADIES	A	B	1	2.5	1.5	0.4	60898 MCB T	C	16	10	0	1.09	NA	NA	NA	✓	0.1	N/A	250	100	100	✓	0.4	28.7	18.7	✓	N/A
5/L1	HANDRIER LADIES	A	B	2	2.5	1.5	0.4	60898 MCB T	C	16	10	0	1.09	NA	NA	NA	✓	0.17	N/A	250	100	100	✓	0.35	28.6	18.6	✓	N/A
6/L1	REDUNDANT SPUR GENTS	A	B	1	2.5	1.5	0.4	60898 MCB T	C	16	10	0	1.09	NA	NA	NA	✓	0.14	N/A	250	100	100	✓	0.41	28.6	18.6	✓	N/A
7/L1	Lights KITCHEN	A	B	2	1	1	0.4	60898 MCB T	C	10	10	0	1.75	NA	NA	NA	✓	0.71	N/A	250	100	100	✓	0.64	28.6	18.7	✓	N/A
8/L1	Lights COPY ROOM,MALE & FEMALE CHANGING	A	B	6	1	1	0.4	60898 MCB Type C	C	10	10	0	1.75	NA	NA	NA	✓	1.31	N/A	250	100	100	✓	1.06	29.8	17.8	✓	N/A
9/L1	SHOWER	A	B	2	6	2.5	0.4	60898 MCB T	C	40	10	0	0.44	NA	NA	NA	✓	0.09	N/A	250	100	100	✓	0.31	28.7	18.8	✓	N/A
10/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A
11/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A
12/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing

Not Specified

To

Not Specified

Date(s) live testing

20/09/2021

To

20/09/2021

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters)

ED ROWE

Position

Technician

Date

20/09/2021

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

FT/  
EICR 3486000001193



Company Name

Technical Electrical Engineering Ltd t/a Mr Electric

Company Address

Wheal Kitty Studios

Postcode

TR5 0RD

Branch No.

Scheme No.

019875

Client

WESSEX RFCA

Installation Address

, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL

Postcode

TR1 1DF

Distribution board details - Complete in every case

Location

MAIN CORRIDOR

Designation

DB 1/3

Num. of ways

12

Num. of phases

1

Supply polarity confirmed☒

Phase sequence confirmed☒

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from

Sub Mains(DB 1, 1/L2)

Overcurrent protective device for the distribution circuit: Type

B

 Rating

63

 A Voltage

230

 V

Characteristics at this distribution board

Associated RCD(if any): BS (EN)

N/A

Operating at 1 IΔn

N/A

 ms

Above 30mA (if applicable)

30mA or below

Ipf

0.634

 kA IΔn

N/A

Operating at 5 IΔn

N/A

 ms

Time delay (if applicable)

N/A

Test instrument serial number(s)

Loop impedance

1008128101650691

Insulation resistance

1008128101650691

Continuity

1008128101650691

RCD

1008128101650691

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity  (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	DB 1/3				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both R1 + R2    R2	Test voltage  V	L/L, L/N  M(Ω)	L/E, N/E  M(Ω)	Above 30mA IΔn  ms			30mA or below 5 IΔn  ms	RCD  (✓)	AFDD  (✓)	
1/L2	SOCKETS QPS OFFICE	A	A	16	2.5	1.5	0.4	61009 RCD/	B	32	6	0	1.09	0.45	0.55	0.73	✓	0.37	N/A	250	100	100	✓	0.37	49.8	29.8	✓	N/A
2/L2	SOCKETS EQUIPMENT STORES	A	A	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	0	1.09	0.4	0.41	0.69	✓	0.49	N/A	250	100	100	✓	0.55	45.6	45	✓	N/A
3/L2	SOCKETS LOUNGE END OFFICE	A	A	6	2.5	1.5	0.4	60898 MCB Type B	B	20	6	N/A	1.75	NA	NA	NA	✓	0.37	N/A	250	100	100	✓	0.51	N/A	N/A	✓	N/A
4/L2	.LIGHTS LOUNGE END OFFICE	A	A	5	1	1	0.4	60898 MCB Type B	B	6	6	N/A	5.82	NA	NA	NA	✓	0.87	N/A	250	100	100	✓	0.67	N/A	N/A	✓	N/A
5/L2	.LIGHTS UPSTAIRS	A	A	12	1	1	0.4	60898 MCB T	B	6	6	N/A	5.82	NA	NA	NA	✓	1.47	N/A	250	100	100	✓	0.74	N/A	N/A	✓	N/A
6/L2	.LIGHTS QPS HALLWAY OFFICE	A	A	5	1	1	0.4	60898 MCB Type B	B	10	6	N/A	3.49	NA	NA	NA	✓	0.81	N/A	250	100	100	✓	0.3	N/A	N/A	✓	N/A
7/L2	.LIGHTS EQUIPMENT STORE	A	A	4	1	1	0.4	60898 MCB Type B	B	10	6	N/A	3.49	NA	NA	NA	✓	0.67	N/A	250	100	100	✓	0.43	N/A	N/A	✓	N/A
8/L2	.LIGHTS DRILL HALL	A	A	6	1	1	0.4	60898 MCB T	B	10	6	N/A	3.49	NA	NA	NA	✓	1.67	N/A	250	100	100	✓	0.41	N/A	N/A	✓	N/A
9/L2	Unknown	A	A	FI	1	1	0.4	60898 MCB T	B	10	6	N/A	3.49	NA	NA	NA	✓	FI	N/A	250	FI	FI	✓	FI	N/A	N/A	✓	N/A
10/L2	DATA CABINET	G	A	1	2.5	2.5	0.4	60898 MCB T	B	16	6	N/A	2.18	NA	NA	NA	✓	LIM	N/A	250	LIM	LIM	✓	LIM	N/A	N/A	✓	N/A
11/L2	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A
12/L2	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	N/A	NA	NA	NA	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing

Not Specified

 To 

Not Specified

Date(s) live testing

20/09/2021

 To 

20/09/2021

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters)

ED ROWE

 Position

Technician

 Date

20/09/2021

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

FT/  
EICR 3486000001193



<b>Company Name</b>	Technical Electrical Engineering Ltd t/a Mr Electric	<b>Company Address</b>	Wheal Kitty Studios	<b>Postcode</b>	TR5 0RD	<b>Branch No.</b>		<b>Scheme No.</b>	019875
<b>Client</b>	WESSEX RFCA	<b>Installation Address</b>	, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL				<b>Postcode</b>	TR1 1DF	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>				<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>	
Location	ABOVE OFFICE DOOR	Supply to distribution board is from		Associated RCD(if any): BS (EN)		Above 30mA (if applicable)		Loop impedance	
Designation	DB GDB1	Sub Mains(DB 1 1 2 ACF CABIN, 5/L1)		N/A		Operating at 1 IΔn		1008128101650691	
Num. of ways	14	Overcurrent protective device for the distribution circuit: BS(EN) 60898 MCB Type B		Z <sub>s</sub> 6.75 Ω		30mA or below		Insulation resistance	
Num. of phases	1	Type B Rating 63 A Voltage 230 V		No. of poles N/A		Operating at 5 IΔn		1008128101650691	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>				I <sub>pf</sub> 0.34 kA		N/A		Continuity	
				Time delay (if applicable) N/A				RCD 1008128101650691	

## CIRCUIT DETAILS

## TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm <sup>2</sup> )		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other  80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB GDB1				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage  V	L/L, L/N  M(Ω)	L/E, N/E  M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD  (✓)	AFCD  (✓)		
	Circuit designation													r1	rn	r2												R1 + R2	R2
1/L1	NEXT DOOR MIDDLE LIGHTS	A	A	10	1	1	0.4	60898 MCB Type B	B	6	6	30	5.82	NA	NA	NA	✓	0.56	N/A	250	100	100	✓	7.04	56.9	23.9	✓	N/A	
2/L1	NEXT DOOR FRONT INSIDE LIGHTS	A	A	5	1	1	0.4	60898 MCB Type B	B	6	6	30	5.82	NA	NA	NA	✓	0.86	N/A	250	92.8	92.8	✓	4.59	56.9	23.9	✓	N/A	
3/L1	MAIN GARAGE LIGHTS	A	A	8	1	1	0.4	60898 MCB T	B	6	6	30	5.82	NA	NA	NA	✓	1.17	N/A	250	25.3	25.3	✓	7.51	56.9	23.9	✓	N/A	
4/L1	OUTSIDE LIGHTS	A	A	3	1	1	0.4	60898 MCB T	B	6	6	30	5.82	NA	NA	NA	✓	LIM	N/A	250	20.5	20.5	✓	6.01	56.9	23.9	✓	N/A	
5/L1	WORKSHOP STORE LIGHTS	A	A	3	1	1	0.4	60898 MCB Type B	B	6	6	30	5.82	NA	NA	NA	✓	0.46	N/A	250	20.6	20.6	✓	10.5	56.9	23.9	✓	N/A	
6/L1	OFFICE LIGHT & FAN	A	A	2	1	1	0.4	60898 MCB T	B	10	6	30	3.49	NA	NA	NA	✓	0.13	N/A	250	20.6	20.6	✓	5.14	56.9	23.9	✓	N/A	
7/L1	RCD Module Covering	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	
8/L1	RCD Module (Split board)	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	
9/L1	Unknown	A	A	FI	2.5	1.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	FI	N/A	250	1.02	1.02	✓	FI	54.4	23.5	✓	N/A	
10/L1	HEATER ABOVE WINDOW	A	A	1	2.5	1.5	0.4	60898 MCB T	B	20	6	30	1.75	NA	NA	NA	✓	0.1	N/A	250	100	100	✓	6.8	54.4	23.5	✓	N/A	
11/L1	LARGE HEATER	A	A	1	2.5	1.5	0.4	60898 MCB T	B	20	6	30	1.75	NA	NA	NA	✓	0.69	N/A	250	50.7	50.7	✓	7.01	54.4	23.5	✓	N/A	
12/L1	HEATER + SOCKET GARAGE STORES	A	A	2	2.5	1.5	0.4	60898 MCB Type B	B	20	6	30	1.75	NA	NA	NA	✓	0.1	N/A	250	5.16	5.16	✓	6.66	54.4	23.5	✓	N/A	
13/L1	LIFT	G	A	1	2.5	2.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	0.32	N/A	250	100	100	✓	6.85	54.4	23.5	✓	N/A	
14/L1	COMPRESSOR	G	A	1	2.5	2.5	0.4	60898 MCB T	B	20	6	30	1.75	NA	NA	NA	✓	0.21	N/A	250	100	100	✓	7.11	54.4	23.5	✓	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing		Not Specified	To	Not Specified	Date(s) live testing		20/09/2021	To	20/09/2021
ANY ELECTRONIC DEVICES.											
Tested by: Name (capital letters)		ED ROWE		Position		Technician		Date		20/09/2021	
								Signature			

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)

FT/ EICR 3486000001193



Company Name

Technical Electrical Engineering Ltd t/a Mr Electric

Company Address

Wheal Kitty Studios

Postcode

TR5 0RD

Branch No.

Scheme No.

019875

Client

WESSEX RFCA

Installation Address

, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL

Postcode

TR1 1DF

Distribution board details - Complete in every case

Location

BT OFFICE FRONT

Designation

DB 2

Num. of ways

10

Num. of phases

1

Supply polarity confirmed

☒

Phase sequence confirmed

☒

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from

Overcurrent protective device for the distribution circuit: Type

Rating

A

Voltage

230

V

Characteristics at this distribution board

Associated RCD(if any): BS (EN)

N/A

Operating at 1 IΔn

N/A

ms

Above 30mA (if applicable)

30mA or below

ms

Zs

0.33

Ω

No. of poles

N/A

Ipf

1.63

kA

IΔn

N/A

Operating at 5 IΔn

N/A

ms

Time delay (if applicable)

N/A

Test instrument serial number(s)

Loop impedance

1008128101650691

Insulation resistance

1008128101650691

Continuity

1008128101650691

RCD

1008128101650691

CIRCUIT DETAILS													TEST RESULTS																																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Measured Max. Zs (Ω)	RCD testing		Manual test button operation																				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)																			
														r1	rn	r2																														

*for Industrial/Commercial Premises*

FT/  
EICR 3486000001193




**Mr.  Electric™**

<b>Company Name</b>	Technical Electrical Engineering Ltd t/a Mr Electric		<b>Company Address</b>	Wheal Kitty Studios		<b>Postcode</b>	TR5 0RD		<b>Branch No.</b>			<b>Scheme No.</b>	019875	
<b>Client</b>	WESSEX RFCA		<b>Installation Address</b>	, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL						<b>Postcode</b>	TR1 1DF			
<b>Distribution board details - Complete in every case</b>			<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			<b>Characteristics at this distribution board</b>				<b>Test instrument serial number(s)</b>				
Location	BT OFFICE FRONT		Supply to distribution board is from			Associated RCD(if any): BS (EN)				(if applicable)				
Designation	DB 3					N/A								
Num. of ways	6		Overcurrent protective device for the distribution circuit:			Operating at 1 I <sub>Δn</sub>								
Num. of phases	1		BS(EN) Type Rating A Voltage V			Above 30mA N/A ms								
Supply polarity confirmed <input checked="" type="checkbox"/>			Phase sequence confirmed <input checked="" type="checkbox"/>			Z <sub>s</sub> 0.33 Ω No. of poles N/A				Loop impedance 1008128101650691				
						I <sub>p</sub> 1.63 kA I <sub>Δn</sub> N/A				Insulation resistance 1008128101650691				
						Operating at 5 I <sub>Δn</sub> N/A ms				Continuity 1008128101650691				
						Time delay (if applicable) N/A				RCD 1008128101650691				

## TEST RESULTS

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing				Date(s) dead testing		Not Specified	To	Not Specified	Date(s) live testing		20/09/2021	To	20/09/2021		
ANY ELECTRONIC DEVICES.															
Tested by: Name (capital letters)		ED ROWE		Position		Technician		Date		20/09/2021		Signature			

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other



*for Industrial/Commercial Premises*

FT/  
EICR 3486000001193




**Mr.  Electric™**

<b>Company Name</b> Technical Electrical Engineering Ltd t/a Mr Electric		<b>Company Address</b> Wheal Kitty Studios		<b>Postcode</b> TR5 0RD		<b>Branch No.</b>		<b>Scheme No.</b> 019875		
<b>Client</b> WESSEX RFCA		<b>Installation Address</b> , TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL						<b>Postcode</b> TR1 1DF		
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>		
Location GYM TOILET		Supply to distribution board is from Sub Mains(DB 3, 1/L1)			Associated RCD(if any): BS (EN) N/A			Above 30mA (if applicable)		
Designation DB 3/1		Overcurrent protective device for the distribution circuit: BS(EN) 60898 MCB Type B			Z <sub>s</sub> 0.33 Ω No. of poles N/A			Loop impedance 1008128101650691		
Num. of ways 10 Num. of phases 1		Type B Rating 6 A Voltage 230 V			I <sub>pn</sub> 0.588 kA I <sub>Δn</sub> N/A			Insulation resistance 1008128101650691		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>					Operating at 1 I <sub>Δn</sub> N/A ms			Continuity 1008128101650691		
					Operating at 5 I <sub>Δn</sub> N/A ms			RCD 1008128101650691		
					Time delay (if applicable) N/A					

## TEST RESULTS

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing				Date(s) dead testing		Not Specified	To	Not Specified	Date(s) live testing	20/09/2021	To	20/09/2021
ANY ELECTRONIC DEVICES.									Signature			
Tested by: Name (capital letters)		ED ROWE		Position	Technician		Date	20/09/2021				

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

FT/  
EICR 3486000001193



<b>Company Name</b>	Technical Electrical Engineering Ltd t/a Mr Electric	<b>Company Address</b>	Wheal Kitty Studios	<b>Postcode</b>	TR5 0RD	<b>Branch No.</b>		<b>Scheme No.</b>	019875
<b>Client</b>	WESSEX RFCA	<b>Installation Address</b>	, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL				<b>Postcode</b>	TR1 1DF	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>				<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>
Location	ABOVE OFFICE DOOR	Supply to distribution board is from		Associated RCD(if any): BS (EN)			Above 30mA (if applicable)		Loop impedance
Designation	DB GDB2	Sub Mains(DB 1 1 2 ACF CABIN, 5/L1)		N/A			Operating at 1 IΔn		1008128101650691
Num. of ways	12	Overcurrent protective device for the distribution circuit: BS(EN) 60898 MCB Type B		Z <sub>s</sub> 6.21 Ω			30mA or below		Insulation resistance
Num. of phases	1	Type B Rating 63 A Voltage 230 V		No. of poles N/A			Operating at 5 IΔn		1008128101650691
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>				I <sub>pr</sub> 0.35 kA			N/A		Continuity
				Time delay (if applicable) N/A					RCD
									1008128101650691

## CIRCUIT DETAILS

## TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
	DB GDB2				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
	Circuit designation													r1	m	r2		R1 + R2	R2									
1/L1	HEATER BELOW	A	A	1	2.5	1.5	0.4	60898 MCB T	B	20	6	30	1.75	NA	NA	NA	✓	0.25	N/A	250	80.5	80.5	✓	5.78	45.2	12.2	✓	N/A
2/L1	SOCKET ADJ + GAS BLOWER	A	A	2	2.5	1.5	0.4	60898 MCB Type B	B	20	6	30	1.75	NA	NA	NA	✓	0.67	N/A	250	85.3	85.3	✓	5.98	45.2	12.2	✓	N/A
3/L1	SOCKETS OFFICE	A	A	6	2.5	1.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	0.46	N/A	250	100	100	✓	5.89	45.2	12.2	✓	N/A
4/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	
5/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	
6/L1	RCD Module Covering	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	
7/L1	RCD Module (Split board)	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	
8/L1	SOCKETS LARGE VEHICLE AREA	F	A	7	6	2.5	0.4	60898 MCB Type B	B	20	6	30	1.75	NA	NA	NA	✓	0.18	N/A	250	163	163	✓	5.61	44.7	13.6	✓	N/A
9/L1	EXTERNAL LIGHTS OVERRIDE	A	A	1	2.5	1.5	0.4	60898 MCB Type B	B	16	6	30	2.18	NA	NA	NA	✓	0.11	N/A	250	0.77	0.77	✓	5.76	44.7	13.6	✓	N/A
10/L1	STORES WATER HEATER	A	A	1	2.5	1.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	0.26	N/A	250	100	100	✓	5.75	44.7	13.6	✓	N/A
11/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	
12/L1	SPARE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	N/A	NA	NA	NA	NA	NA	NA	NA	NA	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing Not Specified To Not Specified Date(s) live testing 20/09/2021 To 20/09/2021

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters) ED ROWE Position Technician Date 20/09/2021

Signature

*ED ROWE*

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

# ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

FT/  
EICR 3486000001193



<b>Company Name</b>	Technical Electrical Engineering Ltd t/a Mr Electric	<b>Company Address</b>	Wheal Kitty Studios	<b>Postcode</b>	TR5 0RD	<b>Branch No.</b>		<b>Scheme No.</b>	019875
<b>Client</b>	WESSEX RFCA	<b>Installation Address</b>	, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL				<b>Postcode</b>	TR1 1DF	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>				<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>	
Location	CLEANING CUPBOARD	Supply to distribution board is from				Associated RCD(if any): BS (EN)		Loop impedance	
Designation	DB 1 1 1 ACF CABIN					Above 30mA (if applicable)		Insulation resistance	
Num. of ways	12	Overcurrent protective device for the distribution circuit: Type				Operating at 1 I <sub>Δn</sub>		Continuity	
Num. of phases	1	BS(EN)				30mA or below		RCD	
Supply polarity confirmed <input checked="" type="checkbox"/>		Rating				Operating at 5 I <sub>Δn</sub>			
Phase sequence confirmed <input checked="" type="checkbox"/>		Voltage				Time delay (if applicable)			
		A				N/A			

## CIRCUIT DETAILS

## TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity  (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB 1 1 1 ACF CABIN				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both		Test voltage  V	L/L, L/N  M(Ω)	L/E, N/E  M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD  (✓)	AFDD  (✓)	
	Circuit designation													r1	m	r2		R1 + R2	R2										
1/L1	Lights CLASSROOM	A	A	4	1	1	0.4	60898 MCB T	B	6	6	30	5.82	NA	NA	NA	✓	1.25	N/A	250	100	100	✓	7.46	42.2	29.2	✓	N/A	
2/L1	Lights FRONT SIDE	A	A	7	1	1	0.4	60898 MCB T	B	6	6	30	5.82	NA	NA	NA	✓	1.3	N/A	250	100	100	✓	1.52	42.2	29.2	✓	N/A	
3/L1	Lights BACK END	A	A	8	1	1	0.4	60898 MCB T	B	6	6	30	5.82	NA	NA	NA	✓	1.45	N/A	250	100	100	✓	1.8	42.2	29.2	✓	N/A	
4/L1	WATER HEATER	A	A	1	2.5	1.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	0.15	N/A	250	100	100	✓	0.8	42.2	29.2	✓	N/A	
5/L1	LHS 3RD + 2ND HEATER CLASSROOM 2	A	A	2	2.5	1.5	0.4	60898 MCB Type B	B	16	6	30	2.18	NA	NA	NA	✓	0.58	N/A	250	100	100	✓	1.15	42.2	29.2	✓	N/A	
6/L1	KITCHEN SOCKET + CLASS ONE RHS GHEATER	A	A	2	4	2.5	0.4	60898 MCB Type B	B	32	6	30	1.09	NA	NA	NA	✓	0.34	N/A	250	100	100	✓	0.84	42.2	29.2	✓	N/A	
7/L1	OFFICE SOCKET + HEATER	A	A	2	4	2.5	0.4	60898 MCB T	B	32	6	30	1.09	NA	NA	NA	✓	0.23	N/A	250	100	100	✓	0.66	42.2	29.2	✓	N/A	
8/L1	LHS 2ND HEATER + HEATER OPPOSITE CLASSROOM + SOCKET	A	A	3	4	2.5	0.4	60898 MCB Type B	B	32	6	30	1.09	NA	NA	NA	✓	0.61	N/A	250	100	100	✓	0.94	42.2	29.2	✓	N/A	
9/L1	1ST HEATER LHS + SOCKET BELOW	A	A	2	4	2.5	0.4	60898 MCB Type B	B	32	6	30	1.09	NA	NA	NA	✓	0.37	N/A	250	100	100	✓	0.76	42.2	29.2	✓	N/A	
10/L1	4TH HEATER LHS, SOCKET BELOW + ADJ CLASSROOM 2	A	A	3	4	2.5	0.4	60898 MCB Type B	B	32	6	30	1.09	NA	NA	NA	✓	0.69	N/A	250	100	100	✓	1.05	42.2	29.2	✓	N/A	
11/L1	HANDRIER LADIES	A	A	1	2.5	1.5	0.4	60898 MCB T	B	20	6	30	1.75	NA	NA	NA	✓	0.19	N/A	250	100	100	✓	0.76	42.2	29.2	✓	N/A	
12/L1	HANDRIER GENTS	A	A	1	2.5	1.5	0.4	60898 MCB T	B	20	6	30	1.75	NA	NA	NA	✓	0.18	N/A	250	100	100	✓	1.03	42.2	29.2	✓	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	Not Specified	To	Not Specified	Date(s) live testing	20/09/2021	To	20/09/2021
ANY ELECTRONIC DEVICES.									
Tested by: Name (capital letters)		ED ROWE	Position		Technician	Date		20/09/2021	Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

*for Industrial/Commercial Premises*


FT/  
EICR 3486000001193



Mr.  Electric™

<b>Company Name</b> <input type="text" value="Technical Electrical Engineering Ltd t/a Mr Electric"/>		<b>Company Address</b> <input type="text" value="Wheal Kitty Studios"/>		<b>Postcode</b> <input type="text" value="TR5 0RD"/>		<b>Branch No.</b> <input type="text" value=""/>		<b>Scheme No.</b> <input type="text" value="019875"/>		
<b>Client</b> <input type="text" value="WESSEX RFCA"/>		<b>Installation Address</b> <input type="text" value=", TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL"/>						<b>Postcode</b> <input type="text" value="TR1 1DF"/>		
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>			<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>		
<b>Location</b> <input type="text" value="KITCHEN"/>		<b>Supply to distribution board is from</b> <input type="text" value="Sub Mains(DB 1, 1/L3)"/>			<b>Associated RCD(if any): BS (EN)</b> <input type="text" value="N/A"/>			<b>Loop impedance</b> <input type="text" value="1008128101650691"/>		
<b>Designation</b> <input type="text" value="DB 1/5"/>		<b>Overcurrent protective device for the distribution circuit:</b> Type <input type="text" value="B"/> Rating <input type="text" value="63"/> A Voltage <input type="text" value="230"/> V			<b>Operating at 1 IΔn</b> <input type="text" value="N/A"/> ms			<b>Insulation resistance</b> <input type="text" value="1008128101650691"/>		
<b>Num. of ways</b> <input type="text" value="12"/> <b>Num. of phases</b> <input type="text" value="1"/>		<b>BS(EN)</b> <input type="text" value="60898 MCB Type B"/>			<b>30mA or below</b> <input type="text" value="N/A"/> ms			<b>Continuity</b> <input type="text" value="1008128101650691"/>		
<b>Supply polarity confirmed</b> <input checked="" type="checkbox"/> <b>Phase sequence confirmed</b> <input checked="" type="checkbox"/>					<b>Operating at 5 IΔn</b> <input type="text" value="N/A"/> ms			<b>RCD</b> <input type="text" value="1008128101650691"/>		
					<b>Time delay (if applicable)</b> <input type="text" value="N/A"/>					

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing				Date(s) dead testing		Not Specified	To	Not Specified	Date(s) live testing		20/09/2021	To	20/09/2021		
ANY ELECTRONIC DEVICES.															
Tested by: Name (capital letters)		ED ROWE		Position		Technician		Date		20/09/2021		Signature			

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

*for Industrial/Commercial Premises*

FT/  
EICR 3486000001193



## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> <input type="text" value="Technical Electrical Engineering Ltd t/a Mr Electric"/>		<b>Company Address</b> <input type="text" value="Wheal Kitty Studios"/>		<b>Postcode</b> <input type="text" value="TR5 0RD"/>		<b>Branch No.</b> <input type="text" value=""/>		<b>Scheme No.</b> <input type="text" value="019875"/>		
<b>Client</b> <input type="text" value="WESSEX RFCA"/>		<b>Installation Address</b> <input type="text" value=", TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL"/>						<b>Postcode</b> <input type="text" value="TR1 1DF"/>		
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>				<b>Characteristics at this distribution board</b>			<b>Test instrument serial number(s)</b>	
<b>Location</b> <input type="text" value="CLEANING CUPBOARD"/>		<b>Supply to distribution board is from</b> <input type="text" value=""/>				<b>Associated RCD(if any):</b> BS (EN) <input type="text" value="61008"/>			<b>Loop impedance</b> <input type="text" value="1008128101650691"/>	
<b>Designation</b> <input type="text" value="DB 1 1 2 ACF CABIN"/>		<input type="text" value=""/>				<b>Operating at 1 I<sub>Δn</sub></b> <input type="text" value="42.2"/> ms			<b>Insulation resistance</b> <input type="text" value="1008128101650691"/>	
<b>Num. of ways</b> <input type="text" value="1"/>		<b>Num. of phases</b> <input type="text" value="1"/>				<b>30mA or below</b>			<b>Continuity</b> <input type="text" value="1008128101650691"/>	
<b>Supply polarity confirmed</b> <input checked="" type="checkbox"/>		<b>Phase sequence confirmed</b> <input checked="" type="checkbox"/>				<b>Operating at 5 I<sub>Δn</sub></b> <input type="text" value="29.2"/> ms			<b>RCD</b> <input type="text" value="1008128101650691"/>	
		<b>Overcurrent protective device for the distribution circuit:</b> Type <input type="text" value=""/> Rating <input type="text" value=""/> A Voltage <input type="text" value="230"/> V				<b>Time delay (if applicable)</b> <input type="text" value="N/A"/>				

## TEST RESULTS

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing	Date(s) dead testing	Not Specified	To	Not Specified	Date(s) live testing	20/09/2021	To	20/09/2021
--	----------------------	---------------	----	---------------	----------------------	------------	----	------------

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters)	ED ROWE	Position	Technician	Date	20/09/2021
-----------------------------------	---------	----------	------------	------	------------

Signature

\_\_\_\_\_

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

*for Industrial/Commercial Premises*

FT/  
EICR 3486000001193



Mr.  Electric™

<b>Company Name</b> <input type="text" value="Technical Electrical Engineering Ltd t/a Mr Electric"/>		<b>Company Address</b> <input type="text" value="Wheal Kitty Studios"/>		<b>Postcode</b> <input type="text" value="TR5 0RD"/>		<b>Branch No.</b> <input type="text"/>		<b>Scheme No.</b> <input type="text" value="019875"/>	
<b>Client</b> <input type="text" value="WESSEX RFCA"/>		<b>Installation Address</b> <input type="text" value=", TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL"/>						<b>Postcode</b> <input type="text" value="TR1 1DF"/>	
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>		<b>Characteristics at this distribution board</b>				<b>Test instrument serial number(s)</b>	
Location <input type="text" value="CLEANING CUPBOARD"/>		Supply to distribution board is from <input type="text" value="Sub Mains(DB 2, 4/L1)"/>		Associated RCD(if any): BS (EN) <input type="text" value="61008"/>				Loop impedance <input type="text" value="1008128101650691"/>	
Designation <input type="text" value="DB 2/1"/>		Overcurrent protective device for the distribution circuit: Type <input type="text" value="BS(EN)"/>		Operating at 1 IΔn <input type="text" value="42.2"/> ms				Insulation resistance <input type="text" value="1008128101650691"/>	
Num. of ways <input type="text" value="4"/>		Num. of phases <input type="text" value="1"/>		Zs <input type="text" value="0.61"/> Ω No. of poles <input type="text" value="2"/>				Continuity <input type="text" value="1008128101650691"/>	
Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input checked="" type="checkbox"/>		IΔt <input type="text" value="1.65"/> kA IΔn <input type="text" value="30"/>				RCD <input type="text" value="1008128101650691"/>	
		Voltage <input type="text" value="230"/> V		Operating at 5 IΔn <input type="text" value="29.2"/> ms					
				Time delay (if applicable) <input type="text" value="N/A"/>					

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing	Date(s) dead testing	Not Specified	To	Not Specified	Date(s) live testing	20/09/2021	To	20/09/2021
--	----------------------	---------------	----	---------------	----------------------	------------	----	------------

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters)	ED ROWE	Position	Technician	Date	20/09/2021
-----------------------------------	---------	----------	------------	------	------------

Signature 

Wiring Types. **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other



*for Industrial/Commercial Premises*

FT/  
EICR 3486000001193




**Mr.  Electric™**

## Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)

<b>Company Name</b> Technical Electrical Engineering Ltd t/a Mr Electric		<b>Company Address</b> Wheal Kitty Studios		<b>Postcode</b> TR5 0RD		<b>Branch No.</b>		<b>Scheme No.</b> 019875			
<b>Client</b> WESSEX RFCA		<b>Installation Address</b> , TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL						<b>Postcode</b> TR1 1DF			
<b>Distribution board details - Complete in every case</b>				<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>				<b>Characteristics at this distribution board</b>		<b>Test instrument serial number(s)</b>	
Location PAY OFFICE CUPBOARD		Supply to distribution board is from		Associated RCD(if any): BS (EN) 61008				Above 30mA (if applicable)		Loop impedance 1008128101650691	
Designation DB SW FUSE 4				Operating at 1 IΔn 42.2 ms						Insulation resistance 1008128101650691	
Num. of ways 1		Num. of phases 1		Zs 0.61 Ω No. of poles 2				30mA or below		Continuity 1008128101650691	
Supply polarity confirmed <input checked="" type="checkbox"/>		Phase sequence confirmed <input checked="" type="checkbox"/>		Ipf 1.65 kA IΔn 30				Operating at 5 IΔn 29.2 ms		RCD 1008128101650691	
		Overcurrent protective device for the distribution circuit: Type		BS(EN)							
		Type		Rating				A Voltage 230 V			
		Voltage		230 V							
				Time delay (if applicable) N/A							

## TEST RESULTS

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing				Date(s) dead testing		Not Specified		To		Not Specified		Date(s) live testing		20/09/2021		To		20/09/2021					
ANY ELECTRONIC DEVICES.																							
Tested by: Name (capital letters)		ED ROWE				Position		Technician				Date		20/09/2021				Signature					
Wiring Types. <b>A</b> PVC/PVC, <b>B</b> PVC cables in metallic Conduit, <b>C</b> PVC cables in non-metallic Conduit, <b>D</b> PVC cables in metallic trunking, <b>E</b> PVC cables in non-metallic trunking, <b>F</b> PVC/SWA cables, <b>G</b> SWA/XPLE cables, <b>H</b> Mineral Insulated, <b>MW</b> Metal Work, <b>FM</b> Ferrous Metal, <b>O</b> Other																							

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)

FT/  
EICR 3486000001193



Company Name

Technical Electrical Engineering Ltd t/a Mr Electric

Company Address

Wheal Kitty Studios

Postcode

TR5 0RD

Branch No.

Scheme No.

019875

Client

WESSEX RFCA

Installation Address

, TRURO DETACHMENT, MORESK ROAD, TRURO, CORNWALL

Postcode

TR1 1DF

Distribution board details - Complete in every case

Location

CLEANING CUPBOARD

Designation

DB 4/1

Num. of ways

12

Num. of phases

1

Supply polarity confirmed

☒

Phase sequence confirmed

☒

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to distribution board is from

Sub Mains(DB SW FUSE 4, 1/L1)

Overcurrent protective device for the distribution circuit: Type

mG

 Rating

100

 A Voltage

400/230

 V

BS(EN)

1-- BS 88-2 Fuse HRC gG(General)

Characteristics at this distribution board

Associated RCD(if any): BS (EN)

61008

Operating at 1 IΔn

42.2

 ms

Above 30mA (if applicable)

30mA or below

Ipf

1.65

 kA

IΔn

30

Operating at 5 IΔn

29.2

 ms

Time delay (if applicable)

N/A

Test instrument serial number(s)

Loop impedance

1008128101650691

Insulation resistance

1008128101650691

Continuity

1008128101650691

RCD

1008128101650691

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
	DB 4/1				L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)		
	Circuit designation													r1	rn	r2												R1 + R2	R2
1/L1	SOCKETS OFFICE ONE + HEATERS	A	A	3	4	2.5	0.4	60898 MCB Type B	B	32	6	30	1.09	NA	NA	NA	✓	LIM	N/A	250	100	100	✓	5.75	36.6	36.5	✓	N/A	
2/L1	SOCKETS ROOM 3 + HEATERS	A	A	3	4	2.5	0.4	60898 MCB Type B	B	32	6	30	1.09	NA	NA	NA	✓	LIM	N/A	250	100	100	✓	6.16	36.6	36.5	✓	N/A	
3/L1	WALL HEATER ROW 4	A	A	2	4	2.5	0.4	60898 MCB T	B	32	6	30	1.09	NA	NA	NA	✓	0.61	N/A	250	100	100	✓	7.6	36.6	36.5	✓	N/A	
4/L1	SOCKETS KITCHEN	A	A	1	4	2.5	0.4	60898 MCB T	B	32	6	30	1.09	NA	NA	NA	✓	0.49	N/A	250	100	100	✓	6.95	36.6	36.5	✓	N/A	
5/L1	WALL HEATERS ROW 1	A	A	4	4	2.5	0.4	60898 MCB T	B	32	6	30	1.09	NA	NA	NA	✓	0.4	N/A	250	100	100	✓	7.38	36.6	36.5	✓	N/A	
6/L1	WATER HEATER	A	A	1	2.5	1.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	0.15	N/A	250	100	100	✓	7.94	36.6	36.5	✓	N/A	
7/L1	SOCKETS CLASS 2	A	A	4	2.5	1.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	0.58	N/A	250	100	100	✓	1.14	36.6	36.5	✓	N/A	
8/L1	Lights MAIN HALL + EXTERNAL BULKHEAD	A	A	9	1	1	0.4	60898 MCB Type B	B	6	6	30	5.82	NA	NA	NA	✓	1.2	N/A	250	100	100	✓	1.71	36.6	36.5	✓	N/A	
9/L1	Lights CLASS + STORE	A	A	7	1	1	0.4	60898 MCB T	B	6	6	30	5.82	NA	NA	NA	✓	1.37	N/A	250	100	100	✓	1.84	36.6	36.5	✓	N/A	
10/L1	Lights ENTRANCE,TOILET,KITCHEN	A	A	8	1	1	0.4	60898 MCB Type B	B	6	6	30	5.82	NA	NA	NA	✓	0.84	N/A	250	100	100	✓	1.4	36.6	36.5	✓	N/A	
11/L1	GENTS HANDRIER	A	A	1	2.5	1.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	0.24	N/A	250	100	100	✓	0.69	36.6	36.5	✓	N/A	
12/L1	LADIES HANDRIER	A	A	1	2.5	1.5	0.4	60898 MCB T	B	16	6	30	2.18	NA	NA	NA	✓	0.3	N/A	250	100	100	✓	0.72	36.6	36.5	✓	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing

Not Specified

To

Not Specified

Date(s) live testing

20/09/2021

To

20/09/2021

ANY ELECTRONIC DEVICES.

Tested by: Name (capital letters)

ED ROWE

Position

Technician

Date

20/09/2021

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other



**Outcomes**

Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:
	or					

In the outcome column use the codes above. Provide additional comment where appropriate. C1/C2/C3 and FI coded items to be recorded in section K of the condition report.

DB/CU Ref:	Entire Installation	DB/CU Location:	N/A
------------	---------------------	-----------------	-----

Item No.	Description	Outcome
<b>1.0 CONSUMER UNIT/DISTRIBUTION BOARD(S)</b>		
1.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)	
1.2	Security of fixing (134.1.1)	
1.3	Condition of enclosure(s) in terms of IP rating (Barriers etc) (416.2)	
1.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	
1.5	Enclosure/obstacles not damaged/deteriorated so as to impair safety (651.2)	
1.5.1	Presence and effectiveness of obstacles (417.2)	
1.6	Presence of main linked switch (as required by 462.1.201)	
1.7	Operation of main switch (functional check) (643.10)	
1.8	Manual operation of circuit-breakers and RCD(s) (test button) to prove disconnection (643.10)	
1.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	
1.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)	
1.11	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	
1.12	Presence of alternative supply warning notice at or consumer unit/distribution board (514.15)	
1.13	Presence of other required labelling (Please specify) (Section 514)	
1.14	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	
1.15	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	
1.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)	
1.17	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	
1.18	RCD(s) provided for fault protection - includes RCBO(s) (411.4.204; 411.5.2; 531.2)	
1.19	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	
1.20	Confirmation of indication that SPD is functional (651.4)	
1.21	Confirmation that ALL conductor connections, including connections to the busbars are correctly located in terminals and are tight and secure (526.1)	
1.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
1.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	
<b>2.0 FINAL CIRCUITS</b>		
2.1	Identification of conductors (514.3.1)	
2.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	
2.3	Condition of insulation of live parts (416.1)	
2.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	
2.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	
2.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	
2.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	
2.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	
2.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	
2.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	
2.10	Connected cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	
2.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.204)	
2.12	<b>Provision of additional requirements for protection by RCD not exceeding 30 mA:</b>	
2.12.1	For all socket-outlets of rating 32 A or less unless exempt (4.11.3.3)	
2.12.2	For the supply of Mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	
2.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	
2.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	
2.12.5	For circuits supplying luminaires within domestic (household) premises (411.3.4)	
2.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	
2.14	Band II cables segregated/separated from Band I cables (528.1)	
2.15	Cables segregated/separated from communications cabling (528.2)	
2.16	Cables segregated/separated from non-electrical services (528.3)	
2.17	<b>Termination of cables at enclosures - indicate extent of sampling in section d of the report (section 526)</b>	
2.17.1	Connections soundly made and under no undue strain (526.6)	



2.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	C3
2.17.3	Connections of live conductors adequately enclosed (526.5)	C3
2.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	C3
2.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	C2
2.19	Suitability of accessories for external influences (512.2)	✓
2.20	Adequacy or working space/accessibility to equipment (132.12; 513.1)	✓
2.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓

### 3.0 ISOLATION AND SWITCHING

<b>3.1</b>	<b>Isolators (Section 460; 537)</b>	
3.1.1	Presence and condition of appropriate devices (462; 537.2.7)	NA
3.1.2	Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	NA
3.1.3	Capable of being secured in the OFF position (462.3)	NA
3.1.4	Correct operation verified (643.10)	NA
3.1.5	Clearly identified by position and/or durable marking (537.2.6)	NA
3.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	NA
<b>3.2</b>	<b>Switching off for mechanical maintenance (Section 464; 537.3.2)</b>	
3.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	NA
3.2.2	Acceptable location - state if local or remote from equipment in question (537.3.2.4)	NA
3.2.3	Capable of being secured in the OFF position (462.3)	NA
3.2.4	Correct operation verified (643.10)	NA
3.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	NA
<b>3.3</b>	<b>Emergency switching/stopping (465; 537.3.3)</b>	
3.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	NA
3.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	NA
3.3.3	Correct operation verified (643.10)	NA
3.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	NA
<b>3.4</b>	<b>Functional switching (section 463; 537.3.1)</b>	
3.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
3.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓

### 4.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)

4.1	Condition of equipment in terms of IP rating etc (416.2)	✓
4.2	Equipment does not constitute a fire hazard (Section 421)	✓
4.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
4.4	Suitability for the environment and external influences (512.2)	✓
4.5	Security of fixing (134.1.1)	✓
4.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	NA
<b>4.7</b>	<b>Recessed luminaires (downlighters)</b>	
4.7.1	Correct type of lamps fitted (559.3.1)	NA
4.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	NA
4.7.3	No signs of overheating to surrounding building fabric (559.4.1)	NA
4.7.4	No signs of overheating to conductors/terminations (526.1)	NA

### 5.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

7.01	If any special installations or locations are present, list the particular inspections applied.	
------	---	--

### 8.0 Schedule of Tests

Results to be recorded on Schedule of Test Results

8.1	External earth loop impedance, Z <sub>e</sub>	Yes	8.9	Insulation Resistance between Live Conductors	Yes
8.2	Installation earth electrode	NA	8.10	Insulation Resistance between Live Conductors & Earth	Yes
8.3	Prospective fault current, I <sub>p</sub>	Yes	8.11	Polarity (prior to energisation)	NA
8.4	Continuity of Earth Conductors	Yes	8.12	Polarity (after energisation) including phase sequence	Yes
8.5	Continuity of Circuit Protective Conductors	Yes	8.13	Earth Fault Loop Impedance	Yes
8.6	Continuity of ring final circuit	Yes	8.14	RCDs/RCBOs including selectivity	Yes
8.7	Continuity of Protective Bonding Conductors	NA	8.15	Functional testing of RCD devices	Yes
8.8	Volt drop verified	NA	8.16	Functional testing of AFDD(s) devices	NA

Inspector's Name: Ed Rowe

Date: 20/09/2021

Signature: