



**Defence  
Infrastructure  
Organisation**

**Gas Safety Management Plan  
(Section A)**

**Redruth AFCO**

**18/02/25**

**Produced to meet the requirements of the Gas Safety  
(Installation and Use) Regulations 1998**

### ESTABLISHMENT KEY PERSONALITIES (GAS) CONTACTS

Role	Name	Tel No.	Email
Head of Establishment	Lt Col Vickie Warrington	07966 230425	<a href="mailto:vickie.warrington547@mod.gov.uk">vickie.warrington547@mod.gov.uk</a>
Establishment's SHEF	Nick Summerhayes	07925 638340	nick.summerhayes@capita.com
Establishments 4C's Coordinator	Tony Hands	01209 215785 (Ext 1)	anthony.hands281@mod.gov.uk
Senior DIO Estate Representative or Equivalent	Mark Cubitt	07955 280440	wx-est-hd@rfca.mod.uk
Site DIO Estate Representative or Equivalent	Josh Palmerino	01823792672 07842319286	wx-est-mj4@rfca.mod.uk
MMO Site Manager or equivalent	Paul Wakeford	07356 101565	Paul.wakeford@vivodefence.com
Gas Safety Manager (GSM)	Justin Westcott	07793222820	justin.westcott@vivodefence.com
Gas Responsible Person (GRP)	Scott Bayton	07793223104	scott.bayton@vivodefence.com

The Content of this Gas Safety Management Plan (GSMP) have been Approved by the Gas Safety Manager:

Signature: *JP Westcott*

Date: 18/02/2025

### Authorisation for Implementation

The content and format of this GSMP has been agreed and authorised for implementation by Defence Infrastructure Organisation Technical Services Principal Gas Engineer (DIO TS PGE) and a unique reference number has been generated to support this.

**Approved – J Obbard PGE – 18<sup>th</sup> Feb 2022**

The Content of this GSMP have been agreed by the Senior DIO Estate Representative or Equivalent and future works following the findings will be supported:

Signature: *M Cubitt*

Date: 02/05/2025

The content of this GSMP have been agreed by the Head of Establishment and future works following the findings will be supported.

Signature:

Date:

## REVIEWS AND AMMENDMENTS

GSMPs are 'living documents' that should be subject to continual review and updating as required. Although the level of attention required will vary considerably depending on the size and complexity of each site, GSMPs should be reviewed at least once per quarter by the GRP, unless otherwise agreed by the PGE. Although it is likely that changes are not required at each review, the date of review and any changes made should be indicated on the tables below. The review of the GSMP will include a site visit to ensure that the site and the content of the GSMP remain valid. The reviews and amendments made will be deleted during the DIO TS three yearly review when the GSMP is re-authorised by the PGE.

Date	Page No.	Amendment
25/10/2021	All	Initial Development
08/02/2022	2,3,8	RFCA gas emergency helpdesk telephone number added
04/05/2022	2	Updated Section 1.4
04/05/2022	3	Inserted New Gas Supplier Details & Changed MAM Details
04/05/2022	3	Updated Section 1.5 and gas emergency centre number
14/02/2023	7 and Annexe	Added Gas Line Drawing Details, Icon, and Drawing
10/05/2023	N/A	No Changes
18/08/2023	ii	Updated SHEF, 4'cs and Site Manager Details
20/11/2023	4 & 6	Added Measured Installation Pipework Gas Pressure
28/02/2024	9	Added Plantroom SSOV Comment
15/05/2024	N/A	No Amendments Required
12/08/2024	N/A	No Amendments Required
18/10/2024		GSM re-authorisation (previously authorised 28/01/2022)
15/11/2024	ii, 1,2	Updated HoE and Estates Manager Details
18/02/2025		Amend all key personalities and remove DNV from the GSMP and add Vivo's details instead.
11/04/25		Amend key personalities from new list

Date	Reviewed by	Authorised by	Comments
28/01/2022	M Fenwick	N King	Initial Review
11/05/2022	M Fenwick	M Fenwick	Quarterly Review
04/08/2022	M Fenwick	M Fenwick	Quarterly Review
11/11/2022	M Fenwick	M Fenwick	Quarterly Review
14/02/2023	M Fenwick	N King	Annual Review
10/05/2023	M Fenwick	M Fenwick	Quarterly Review
18/08/2023	M Fenwick	M Fenwick	Quarterly Review
20/11/2023	M Fenwick	M Fenwick	Quarterly Review
28/02/2024	M Fenwick	N King	Annual Review
15/05/2024	M Fenwick	M Fenwick	Quarterly Review
12/08/2024	M Fenwick	M Fenwick	Quarterly Review
18/10/2024	Neville King	Neville King	GSM re-authorisation
15/11/2024	M Fenwick	M Fenwick	Quarterly Review
28/01/2025	M Fenwick	M Fenwick	DNV De-Mobilisation Review / Handover
18/02/2025	S Bayton	S Bayton	Annual review
18/02/2025	J Westcott	J Westcott	Initial review/Approval

---

## FORWARD

MOD, as a gas conveyor within Great Britain, has submitted an Exemplar Gas Safety Case (MOD GSC) to demonstrate compliance with the Gas Safety (Management) Regulations 1996 (GS(M)R). Maintenance Management Organisations (MMO's) are engaged who have the overall contractual responsibility to operate and maintain the gas network assets under their Contract, including the management of the safe flow of gas within the system and the provision of an emergency service. The MOD delegate specific duties to the MMO but accountability for gas safety on each site rests with the Head of Establishment.

Whilst gas downstream of the Emergency Control Valve (ECV) fall outside of the scope of (GS(M)R) similar criteria as those referred to above must be accommodated within an appropriate management system. The specific criteria required to adequately manage gas infrastructure downstream of the ECV are described in the Gas Safety (Installation and Use) Regulations 1998 (GS(IU)R).

The MOD GSC considers all parts of the MOD estates gas supply system that forms part of the gas supply network. This includes all parts of the MOD gas network from the Bulk Primary Meter Installation to the individual gas appliances and the safe release of the products of combustion. The MOD GSC considers primarily those matters that relate to the management of the safe flow of gas within the system and the provision of an emergency service for all aspects of the gas system.

Following initial approval of the Gas Safety Management Plans (GSMPs) by the DIO Principal Gas Engineer (PGE), the Gas Safety Manager (GSM) is required to reapprove this GSMP annually. GSMPs must be submitted to DIO PGE every three years for authorisation.

GSMP Section A document contains site specific details of the establishments utilisation infrastructure to assist with measures to ensure compliance with the GS(IU)R for installation pipework and associated components.

GSMP Section B documents contain site specific details and arrangements as a direct annex to the MOD GSC in line with the Gas Safety (Management) Regulations 1996 (GS(M)R).

GSMP Section C document contains site specific details and requirements of the establishment's LPG networks.

Although the legal status of this document applies in the UK only, the MOD apply the same requirements to the management of gas on its overseas estate, in accordance with the currently published Secretary of State's Health and Safety policy statement.

## Contents

<b>ESTABLISHMENT KEY PERSONALITIES (GAS) CONTACTS .....</b>	<b>II</b>
<b>REVIEWS AND AMMENDMENTS .....</b>	<b>III</b>
<b>FORWARD.....</b>	<b>IV</b>
<b>1 THE DUTY HOLDER AND ESTABLISHMENT LEVEL KEY PERSONALITIES.....</b>	<b>1</b>
1.1. GAS SAFETY CASE DUTY HOLDER.....	1
1.2. DIO TECHNICAL SERVICES PRINCIPAL GAS ENGINEER (PGE). ....	1
1.3. ESTABLISHMENT PERSONALITIES.....	1
1.4. MAINTENANCE MANAGEMENT ORGANISATION (MMO) .....	2
1.5. ADDITIONAL GAS CONTACTS. ....	2
<b>2 SITE SPECIFIC DETAILS.....</b>	<b>4</b>
2.1 SITE OVERVIEW. ....	4
2.2 NATURAL GAS.....	4
2.3 LPG GAS. ....	4
2.4 EXTERNAL INSTALLATION PIPEWORK. ....	5
2.5 DETAILS OF BUILDINGS SERVED. ....	5
2.6 ADDITIONAL DETAILS OF BUILDINGS BEING SERVED.....	5
<b>3 METER DETAILS .....</b>	<b>6</b>
3.1 PRIMARY METER DETAILS.....	6
3.2 UTILISATION METER DETAILS. (METERS SUPPLIED DIRECTLY FROM THE MOD GAS NETWORK) .....	6
<b>4 DIAGRAMS AND DRAWINGS.....</b>	<b>7</b>
4.1 LINE DIAGRAMS FOR BUILDING(S) INTERNAL GAS INSTALLATION PIPEWORK. ....	7
4.2 ADDITIONAL DRAWINGS. ....	7
<b>5 GAS INCIDENTS.....</b>	<b>8</b>
5.1 SITE REPORTING PROCEDURES FOR DEALING WITH GAS INCIDENTS.....	8
<b>6 GAS EQUIPMENT .....</b>	<b>9</b>
6.1 EQUIPMENT LIST.....	9
6.2 ADDITIONAL EQUIPMENT INFORMATION.....	9
<b>7 ANNEXES .....</b>	<b>10</b>

## 1 THE DUTY HOLDER AND ESTABLISHMENT LEVEL KEY PERSONALITIES

### 1.1. Gas Safety Case Duty Holder.

The duty holder for the MOD Gas Safety Case is the Permanent Under Secretary for Defence (PUS). However, day to day responsibility for the preparation and maintenance of the document is delegated to the DIO TS Head of Engineering and Construction, who also has the responsibility for managing the system in accordance with the Safety Case. PUS delegates maintenance responsibility to the Top-Level Budget Holders (TLB's), to manage safety of the gas network. The TLB's utilise MOD Contracts i.e. MMOs who have responsibility for maintaining the gas network on behalf of the MOD.

Name:	Permanent Under Secretary
Address:	Main Building Horse Guards Parade Whitehall London SW1A 2HB

### 1.2. DIO Technical Services Principal Gas Engineer (PGE).

The PGE assumes the role of Senior Authorising Authority which is a term used within the MOD to recognise the authority of the person responsible for overseeing the appointment of, and auditing Authorising Engineers (AEs). For Gas the AEs are replaced by Gas Safety Managers (GSMs).

Name:	Jeremy Obbard
Address:	DIO HQ Whittington Barracks Lichfield WS14 9TJ
☎:	07748 903260
✉:	Jeremy.obbard100@mod.gov.uk

### 1.3. Establishment Personalities.

Name of Establishment:	Redruth AFCO	
Establishment Address:	Redruth AFCO Oak House Chapel Street Redruth Cornwall TR15 2BY	
Head of Establishment (HoE)  (This is the most senior MOD person identified, by the chain of command, as responsible for the establishment. The HoE holds accountability for ensuring site compliance with the requirements of GSMR and the MOD GSC, including this GSMP.)	Name: Position: Organisation: Address:  ☎: ✉:	Lt Col Vickie Warrington RE Head of Establishment Recruiting Group  Upavon Pewsey SN9 6BE  07966 230425 vickie.warrington547@mod.gov.uk

Senior DIO representative or equivalent  (This may be the SEFM, but will vary depending on the contract this establishment falls under)	Name: Mark Cubbert Position: Head of Estates Organisation: Wessex Reserve Forces' & Cadets' Association Address: Mount House Mount Street Taunton Somerset TA1 3QE ☎: 07955 280440 ✉: wx-est-hd@rfca.mod.uk
---	--

#### 1.4. Maintenance Management Organisation (MMO).

The MMO for this establishment is: <b>VIVO Defence Services</b>	
Gas Emergency Helpdesk (Typically, MMO Helpdesk) (24 Hours)  <b>Note:</b> Please do not contact the general public National Gas Emergency Service for suspected gas escapes on RFCA infrastructure.	Organisation: VIVO Helpdesk Helpdesk 25 Goodlass Road Hunts Cross Liverpool L24 9HJ ☎: 0800 030 9320
Gas Safety Manager (GSM)	Name: Justin Westcott Organisation: VIVO Address: Bld 003 CTCRM Lympstone Nr Exmouth Devon EX8 5AR ☎: 07793222820 ✉: Justin.Westcott@vivodefence.com
Gas Responsible Person (GRP)	Name: Scott Bayton Organisation: VIVO Address: Building W75 RNAS Culdrose Helston Cornwall TR12 7RH ☎: 07793223104 ✉: Scott.Bayton@vivodefence.com

#### 1.5. Additional Gas Contacts.

Gas Supplier	Organisation: Total Energies Gas & Power Address: 55-57 High Street Redhill Surrey RH1 1RX ☎: 01737 275 746 ✉: gp.redhill.ccs@totalenergies.com
--------------	---

LPG Supplier	Organisation: Address:  ☎: ✉:	No LPG
Meter Asset Manager (MAM)	Organisation: Address:  ☎: ✉:	Energy Assets Ltd 6 Almondvale Business Park Almondvale Way Livingston EH54 6GA 0800 001 4310 box.ngm.meteringdataenquiries@nationalgrid.com
National Gas Emergency Centre (24 Hours)	☎:	0800 111 999



## 2 SITE SPECIFIC DETAILS

### 2.1 Site Overview.

A brief description of the establishment and its current use. This should include how many separate sites are present and the number of buildings being supplied by gas.

Redruth AFCO is a single site establishment with 1 building on site and this building is supplied with gas direct from the EGDN network and has a MAM owned and operated gas meter and regulator.

The building is used for recruitment for the Army and navy.

This main building is used for office space only.

The site is manned day to day with around 4 people during working hours and ordinarily there are never any more than 5 visitors at any one time.

### 2.2 Natural Gas.

A brief description of the natural gas installations, including how many MOD networks are present, the number of buildings each MOD network supplies and how many buildings are supplied direct from the EGDN. This should also include any demarcations in place between stakeholders and responsibilities.

The gas supply to Redruth AFCO is low pressure and is fed direct from the EGDN network on to site and there is a 20mm PE riser entering the building directly into the plant room to feed an internal MAM owned and operated meter and regulator which supplies the installation pipework at 23 mbar.

Meter – Elster BK-G10M  
S/N – M016 K07579 13 D6  
16m<sup>3</sup>/hr  
MPRN – 9112480901

The gas pipe enters the building via a 63 mm PE EGDN factory entry riser and on entry to the plant room the gas runs through the ECV to the MAM owned and operated gas meter and regulator. The MoD responsibility begins at the meter outlet valve and the installation pipework is made up entirely of 42mm copper pipework. This travels within the plant room for 3 metres and feeds 2 x Remeha Quinta Pro 45 boilers.

Total Load on Meter – 81.6 KW  
There is only copper pipework on this installation.

### 2.3 LPG Gas.

A brief description of the LPG installations, including how many compounds are at the establishment, condition and make up of each compound, the number and size (kg) of vessels in each compound, the number of LPG MOD networks, the number of buildings supplied from the LPG MOD networks, how many buildings are supplied direct and not from an LPG MOD network. Details of the LPG pipework after the first stage regulator up to the building(s).

*Note: The demarcation agreement between the LPG supplier and the MOD has been agreed and the MOD take responsibility from the outlet of the first stage regulator. The LPG supplier is responsible for the vessel, vessel associated components (excluding any earth bonding) pipework up to and including the first stage regulator.*

No LPG on this establishment

#### 2.4 External Installation Pipework.

A brief description of the external installation pipework (above or below ground) on each building. This is from the ECV to where it enters the building(s), the material, diameter, lengths, supports, conditions etc.

There is no external installation pipework.

#### 2.5 Details of buildings served.

A list of the buildings being supplied by gas via an MOD network, LPG compound or directly from the EGDN and the usage of the gas (catering, hot water, heating, fire training, etc) at the building.

Ser	Building Number	Building description	Supplied by	Gas usage
1	Main Building	Office space	EGDN	Heating, Hot water.

#### 2.6 Additional details of buildings being served.

Any additional detail about a building that may be required or useful in an emergency or requires more details than captured above.

NOTE: This section is to be used to capture the Service Family Accommodation (SFA) properties where it is not practical to fit above.

N/A

### 3 METER DETAILS

#### 3.1 Primary Meter Details.

The following table describes the basic arrangement of the primary meter installation(s). (These are the responsibility of the MAM)

*NOTE: More detail on the primary meters that supply MOD networks can be seen in the GSMP part B.*

<b>Number of primary meter installations:</b>		1							
Meter Name / ID	MPRN	Supplying (MOD network ID or Bldg number)	location	Incoming pressure tier – HP, IP, MP, LP	Outlet pipeline				Max Flow (M <sup>3</sup> hr)
					P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	
EGDN Single Supply	9112480901	Main Building	Internal – In Plant Room	LP	LP	23	Copper	42	16

#### 3.2 Utilisation Meter Details. (meters supplied directly from the MOD gas network)

The following table describes the basic arrangement of the utilisation meter installation(s). (These are the responsibility of the MOD)


<b>Number of utilisation meter installations:</b>		N/A – No MoD Network on Site								
Meter Name / ID	Being supplied from (MOD network ID)	Inlet pipeline				Outlet pipework				Max Flow (M <sup>3</sup> hr)
		P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	

## 4 DIAGRAMS AND DRAWINGS

### 4.1 Line diagrams for building(s) internal gas installation pipework.

This section is to contain line diagrams for building internal installation pipework and associated components. This diagram should be fixed to the building at a practical and accessible location as well as within any associated document centres. It may be embedded as a PDF to this document for online use.

NOTE: Drawings are only required for commercial installations or for installation in commercial settings (non-domestic use). This may mean more installations than listed in IGEM/UP/2 Edition 3 (4.2.14), depending on the installations intended use.

Drawing Number	Building	Comments
WX70-A-A3	Main Building	Not to Scale Gas Line Drawing.
		 WX70-A-A3.pdf

### 4.2 Additional drawings.

This section is to contain any additional drawings that may be required or may be of benefit to this GSMP or emergency procedures.

Drawing Number	Building	Comments

## 5 GAS INCIDENTS

### 5.1 Site reporting procedures for dealing with gas incidents.

This section is to contain the establishment's site-specific procedure for dealing with reports of gas incidents with regards the external installation pipework, internal installation pipework and equipment. Details of all individuals with responsibilities under this procedure should be included.

Procedure for an incident involving the gas installations on site:

- Call Vivo Helpdesk Team on **0800 030 9320** open 24 hours per day.
- The Helpdesk will in turn call National Grid **0800 111 999** to attend and make safe a gas incident.
- The Vivo Gas Responsible Person shall be informed immediately by the site personnel.

## 6 GAS EQUIPMENT

### 6.1 Equipment List.

This section is to include details of all the gas equipment being used at the establishment.

Building number	Equipment location	Equipment type (make, model)	Serial Number	Appliance kW rating	Flue classification	Comments
Main Building	Plant Room	Remeha Quinta Pro 45	1834520272990	40.8	Room Sealed	
Main Building	Plant Room	Remeha Quinta Pro 45	1834520272960	40.8	Room Sealed	

### 6.2 Additional equipment information.

This section is to contain any additional equipment information that may be required or may be of benefit to this GSMP or emergency procedures.

In-line solenoid observed in plant room, believed to be fire alarm linked, unable to validate and test.

7 ANNEXES

Gas Line Drawing

