ELECTRICAL INSTALLATION CONDITION REPORT



A Details	of the Client/Person Orde	ring the	Report	B P	eason for Pr	oducing this Repor	+	
		ing the	Report					
Client:	Wessex RFCA				rpose of this repor			
Address:	Mount House				yearly test ar	id inspect		
	Mount Street							
	Taunton Devon							
	TA1 3QE				te(s) on which Ins		9	
					d testing was carri	led out		
C. Details	of the Installation which i	s the Sub	ject of this Report	t		Domestic	Commer	rcial Industrial
Installation:	Yate Platoon				escription of remises:	N/A	1	N/A
Occupier:	Wessex				other:			
Address:	Armetrona May				N/A			
Address.	Armstrong Way Yate			E	stimated age of w	iring system:		35 yrs
	Gloucestershire				vidence of alterati		If yes	
		В	S37 5NG	0	r additions:	✓	estimate	d Age 5 yrs
Record of	N/A Records held By:	N/A				Date of previnspection:	ious	Not Known
Installation av	railable:					moposion.		
D. Extent	and Limitations Inspection	n and Te	sting					
	ctrical Installation covered by this rep	ort:				ing the reasons (See regula		
fixed wirir	ig only				e Additional P	n guidance note 3 an lage	u B5/6	7 i working at
				-				
			Agreed with name	RFC	A			
Operational L	imitations including the reasons (See	e page No	N/A)	_				
None								
This increation	and tooting detailed in this report	d	muina aabadulaa baya ba	an aarris	d out in accordan	on with DC7671-2019 (IFT	Misin a D	agulations) as amandad
to July 2018							_	
	noted that cables concealed within tre ed unless specifically agreed betwee							
other electric	al equipment.		<u> </u>		<u>'</u>			
E. Summa	ary of the Condition of the	Installati	On General condit	tion of th	e installations (In	terms of electrical safety)		
Installatio	n is in good working order b	ut needs ι	up dating					
Overall asse	essment of the installation Unsa	atisfactory	*An unsatisfactory as C2) conditions have t			angerous (code C1) and/or	potentia	lly dangerous (code
F Recom	mendations		GZ) conditions have t	been ide	intilieu.			
	verall assessment of the suitability of	the installati	on for continued use abov	ve is stat	ted as UNSATISF	ACTORY, I recommend	that any	observations classified as
'Danger prese	ent' (code C1) or 'Potentially dangero without delay is recommended for ob	us' (code C2	2) are acted upon as a ma	itter of u	rgency.			
	classified as 'Improvement recomme	nded' (code (C3) should be given due o	consider	ation.			ted by 19/12/2024
		-				stallation is further inspecte		sted by
G. Declara	which are described abo	ve, having e	kercised reasonable skill a	and care	when carrying ou	ation (as indicated by My it the inspection and testing	, hereby	declare that the
			e observations and attach ated extent and limitations			n accurate assessment of the contract of the c	he condit	ion of the electrical
Trading Title	I J Cannings & Son Ltd.,							
and address	Stratford House Water Bridge Co Mat ford Park Road,	ourt,			N	IICEIC Enrolment Number	9140	
	Exeter,					Branch No. (If Applicable)	n/a	
	Devon, EX2 8EX							
Inspected an		Docitie -	Approved Flastrisi	ion	Signotura	0~	Dota	00/04/2020
	artyn Thorpe	Position	Approved Electrici	ian	Signature		Date	09/01/2020
	orised for issue by: Illum Harrison	Position	Approved Electrici	ian	Signature	dli	Date	09/01/2020
						V	Duto	33/01/2020
H. Schedu	The attached schedule(s	are part of t	his document and this rep	oort is va	llid only when they	y are attached to it.		
2	Schedule(s) of inspection ar	nd 2	Schedule(s)	of test r	esults are attache	d		

I. Supply	Chara	acteristics	and E	arthing	<u>Arrangem</u>	nents								
Earthing Arrangeme	g				Live Conduc			Nature of	Supply	/ Paramete	rs		Supply protective	device
	N/A	a.c.	✓			d.c.	N/A	Nominal Voltage	U ⁽¹⁾	400	V	BS(EN)	.:50	
TN-C-S	✓	1-Phase (2 wire)	N/A	1-Phase (3 wire)	N/A	2 Wire	N/A	Nominal Voltage	U ₀ ⁽¹⁾	230	V	1361 F	Fuse HBC	
TN-C	N/A	2-Phase (3 wire)	N/A			3 Wire	N/A	Nominal frequency	f ⁽¹⁾		Hz	Туре		
тт М	N/A	3-Phase	N/A	3-Phase	V		n N/A	Prospective fault current External loop		3.10	kA	1 Nominal		
	N/A	(3 wire) Other N/A		(4 wire)	إنط			impedance Number of	Ze ⁽²⁾		Ω	current ra	ating 80	A
		Confirmation		y polarity		✓		supplies (Note: (1) by 6		1 r, (2) by enq	uiry or	Short circ capacity	4C E	kA
J. Particu	ulars (o in the R			by measurem	ent)					
	of eart		Uline	Elleu te				f installation Ea	orth Ele	octrode (w	here ap	enlicable)		
Distributor's	G. 52	√		e.g. rod(s),	N/A		Giane 1			N/A	1010 a _r	piloue.s,		
facility			tape etc	tc.)				Loca	tion					
Installation earth electrod	de N	N/A	Resista Earth	nce to	N/A			Ω						
								Meth meas	od of sureme	ent N/A				
Main Prot	tective	e Conduct	tors	Tick I	boxes and en	iter deta	ils as ap	plicable						
Earthing Conductor		Material		pper		csa	25	mm ²	Co	ontinuity Ve	rified	✓	Connection	Verified ✓
Main protective bonding cond		Material	Co	pper		csa	16	mm ²	Co	ontinuity Ve	rified	✓	Connection	Verified ✓
Bonding of I		ng Service								Maximur	n Dema	and (Load)		
Water installa	ation ipes	✓ Gas ins	stallation pipes	IV/A	ructural Steel N/		Lightning rotection			100	_	Amps		
Oil installat	ition N	N/A				ase State						•	ainst electric shock	
Pι	ipes L			r incoming service(s)	N/A N/A					ADS				
Main Swit	tch / S	switch-Fus	se / Cir	cuit-Bre	aker / RC	CD							**************************************	
Location	ma	ains room							Curre		100	A	if RCD mai	
										e/Device	100	A	operation current,	30 mA
									rating	g or setting			Rated time delay	N/A ms
Type BS(EN)) 610	008 RCD				o of pole	s 4		Volta rating	•	400	V	RCD Operating	47 ms
Supply Conductors	Co	pper			Supply Conducto	ors 25		mm ²					time at, I∆n	71
material					csa									
K. Observ														
Referring to t	he attac	thed schedule	(s) of Insp	pection and	Test Results	s, and su	ibject to	the limitations s	pecified	d at the Exte	ent and	Limitation	ns of the Inspection ar	nd testing section.
No remedial a	action is	required.	N/A	The follo	owing observa	ations ar	e made	✓						
Item No							Obs	ervations						Code
1	expc	osed parts i	in DB1											C3
2		ated light sw			ver									C2
3		in kitchen r	-											C3
4	supp	oly to fire ala	arm not	t wired in	FP									C2
 	-													-
One of the fo	ollowing	codes, as ap	propriate,	has been a	allocated to e	ach of th	ne obser	vations made at	nove to	indicate to	the per	son(s) resp	ponsible for the instal	lation the
degree of urg	gency fo	or remedial act	tion.							manca.	u.o _F .	30(2)	policial 12. 2. 2. 2.	
		Risk of injury. In			-		0							
	-	erous - urgent r	remedial a	ction require	ed		2							
C3 - Improver							2							
FI - Further ir	nvestiga'	ation required w	vithout del	lav			0							

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

Note: this form is suitable for many types of smaller installations, not exclusively domestic.

	Accentable		Linaccontable	State C1	Improvement	State	Further		Not				1	
Outcomes	Acceptable condition	✓	Unacceptable condition	or C2	recommended	State C3	investigation	FI	verified	N/V	Limitation	LIM	Not applicable	N/A
Item No					Description						Outo	come		Comments
1.0	EXTERNAL (CONDITI	ON OF INTAKE	EQUIPME	NT (VISUAL IN	SPECTION	ON ONLY)							
1.1	Service cable)									٧			No
1.2	Service head										٧	/		No
1.3	Earthing arra	ngement									٧	/		No
1.4	Meter tails										٧			No
1.5	Metering equ	ipment									v			No
1.6	Isolator (when	•	•								v			No
2.0			QUATE ARRAN S (551.6; 551.7		FOR OTHER S	OURCE	S SUCH AS				•	/		No
3.0			IG ARRANGEN		I.3; Chap 54)									
3.1	Presence and	d conditio	on of distributor's	earthing a	rrangement (542	.1.2.1; 5	42.1.2.2)				,	/		No
3.2	Presence and	d conditio	on of earth electr	ode connec	ction where appli	cable (5	42.1.2.3)				N.	/A		No
3.3	Provision of e	earthing/b	onding labels a	t all approp	riate locations (5	14.13.1)	· · · · · · · · · · · · · · · · · · ·				· · · · · · · · · · · · · · · · · · ·			No
3.4	Confirmation	of earthir	ng conductor siz	e (542.3; 5	43.1.1)						•	/		No
3.5	Accessibility	and cond	lition of earthing	conductor	at MET (543.3.2)	1					٧	/		No
3.6	Confirmation	of main p	orotective bondi	ng conducto	or sizes (544.1)						٧	/		No
3.7	Condition and	d accessi	bility of main pro	tective bor	nding conductor of	connection	ons (543.3.2; 54	4.1.2)			٧	/		No
3.8	Accessibility a	and cond	lition of other pro	otective bor	nding connection	s (543.3	1;543.3.2)				٧	/		No
4.0	CONSUMER	UNIT(S)	/ DISTRIBUTIO	N BOARD	(S)									
4.1	Adequacy of	working	space/accessibi	lity to consu	ımer unit/distribu	tion boa	rd (132.12; 513.	1)			٧	/		No
4.2	Security of fix	king (134.	.1.1)								٧	/		No
4.3	Condition of 6	enclosure	e(s) in terms of I	P rating etc	(416.2)						٧	/		No
4.4	Condition of e	enclosure	e(s) in terms of f	ire rating et	c (421.1.201; 520	3.5)					٧	/		No
4.5	Enclosure no	t damage	ed/deteriorated s	so as to imp	air safety (651.2)					٧	/		No
4.6	Presence of r	main linke	ed switch (as re	quired by 46	62.1.201)						٧	/		No
4.7	Operation of	main swi	tch (functional c	heck) (643.	10)						٧			No
4.8	Manual opera	ation of ci	ircuit-breakers a	nd RCDs to	prove disconne	ction (64	3.10)				٧			No
4.9	Correct identi	ification o	of circuit details	and protecti	ive devices (514.	8.1; 514	.9.1)				v			No
4.10					ar consumer unit		•				v			No
4.11	Presence of r (514.14)	non-stand	dard (mixed) cal	ole colour w	arning notice at	or near o	consumer unit/d	istributior	n board		٧			No
4.12	Presence of a	alternativ	e supply warnin	g notice at	or near consume	r unit/dis	tribution board	(514.15)			٧	/		No
4.13	Presence of o	other requ	uired labelling (p	lease spec	ify) (Section 514)					٧	/		No
4.14					ner components; iting) (411.3.2; 4						•	/		No
4.15	Single-pole s	witching	or protective de	vices in line	conductor only (132.14.	1; 530.3.3)				٧	/		No
4.16	Protection ag 522.8.1; 522.			e where cal	bles enter consu	mer unit	distribution boa	rd (132.1	4.1;		v	/		No
4.17	Protection ag (521.5.1)	ainst ele	ctromagnetic eff	ects where	cables enter cor	sumer u	nit/distribution t	oard/end	closures		٧	/		No
4.18	RCD(s) provi	ded for fa	ault protection -	includes RC	CBOs (411.4.204	; 411.5.2	2; 531.2)				٧			No
4.19	RCD(s) provi	ded for a	dditional protect	ion/require	ments - includes	RCBOs	(411.3.3;415.1)				٧			No
4.20			tion that SPD is		· · ·						v			No
4.21	terminals and	d are tight	t and secure (52	6.1)	luding connectio						٧	/		No
4.22	(551.6)				operates as a sw				ipply		•	,		No
4.23	·		nts where a gene	erating set of	operates in paral	el with t	ne public supply	(551.7)			•			No
5.0	FINAL CIRC													No
5.1			ctors (514.3.1)								٧			No No
5.2				*	521.10.202; 522.	ช.5) ———					•			No
5.3	Condition of i	nsulation	of live parts (41	16.1)							•	/		INU

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓		cceptable ndition	State C1 or C2		ovement nmended	State C3		urther estigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No						Descri	otion							Outo	ome		Comments
5.0	FINAL CIRCU	ITS (Co	ontinu	∍d)													
5.4	Non-sheathed	cables	protec	ted by en	closure in o	conduit,	ducting o	r trunkin	g (521	1.10.1)				٧	/		No
5.4.1	To include the		-				•	•	,					٧	/		No
5.5	Adequacy of c	ables fo	or curre	nt-carryin	g capacity	with re	gard for th	ie type a	ind na	ture of ins	tallation	(Section		٧	/		No
5.6	Coordination b	etween	n condu	uctors and	overload	orotectiv	e devices	s (433.1;	533.2	2.1)				•	/		No
5.7	Adequacy of p	rotectiv	e devi	ces: type	and rated o	current f	or fault pr	otection	(411.3	3)				· ·	/		No
5.8	Presence and	adequa	acy of c	ircuit prof	ective con	ductors	(411.3.1;	Section	543)					· ·	/		No
5.9	Wiring system	(s) appr	ropriate	for the ty	pe and na	ture of t	he installa	ation and	d exter	rnal influe	nces (Se	ction 522)			,		No
5.10	Concealed cal	bles inst	talled i	n prescrib	ed zones (see Se	ction D. E	xtent and	d limita	ations) (52	22.6.202)		1	v	/		No
5.11	Cables concea (see Section D						s/partition	s, adequ	uately	protected	against o	lamage		٧	/		No
5.12	Provision of a	dditional	l requir	ements fo	or protectio	n by R0	D not ex	ceeding	30 mA	۸:							
5.12.1	For all socket-	outlets	of ratin	g 32 A or	less, unles	ss an ex	ception is	permitte	ed (41	1.3.3)				٧	/		No
5.12.2	For the supply	of mob	ile equ	ipment no	ot exceedin	ıg 32 A	rating for	use outd	doors ((411.3.3)				٧			No
5.12.3	For cables cor	ncealed	in wall	s at a dep	th of less t	than 50	mm (522	6.202; 5	22.6.2	203)				٧			No
5.12.4	For cables cor	ncealed	in wall	s/partition	s containir	ng meta	l parts reg	ardless	of dep	oth (522.6	.203)			٧			No
5.12.5	Final circuits s	upplyin	g lumir	aires with	nin domesti	ic (hous	ehold) pre	emises (411.3.	.4)				٧			No
5.13	Provision of fir	e barrie	ers, sea	ıling arran	igements a	ind prot	ection aga	ainst the	rmal e	ffects (Se	ction 527	')		٧			No
5.14	Band II cables	segreg	gated/s	eparated ¹	from Band	I cables	(528.1)							٧			No
5.15	Cables segreg	jated/se	eparate	d from co	mmunication	ons cab	ling (528.	2)						٧			No
5.16	Cables segreg	jated/se	eparate	d from no	n-electrica	l service	es (528.3)							٧			No
5.17	Termination of	cables	at enc	losures -	indicate ex	tent of	sampling i	n Sectio	n D of	the repor	t (Section	า 526)					
5.17.1	Connections s	oundly i	made a	and under	no undue	strain (526.6)							v			No
5.17.2	No basic insul	ation of	a cond	luctor visi	ble outside	enclos	ure (526.8	3)						٧			No
5.17.3	Connections of	of live co	onducto	ors adequ	ately enclo	sed (52	6.5)							v			No
5.17.4	Adequately co	nnected	d at po	nt of entr	y to enclos	ure (gla	nds, bush	es etc.)	(522.8	3.5)				v			No
5.18	Condition of a	ccessor	ries inc	luding soc	ket-outlets	s, switch	es and jo	int boxes	s (651	.2(v))				v			No
5.19	Suitability of a	ccessor	ries for	external i	nfluences	(512.2)								٧			No
5.20	Adequacy of w	vorking	space/	accessibil	ity to equip	oment (132.12; 5	13.1)						٧			No
5.21	Single-pole sw	vitching	or prot	ective dev	vices in line	condu	ctors only	(132.14	.1;530	0.3.3)				ν			No
6.0	LOCATION(S) CONT	AININ	G A BATI	H OR SHO	WER											.
6.1	Additional prot	tection f	for all lo	w voltage	e (LV) circu	its by F	CD not e	xceeding	g 30 m	nA (701.41	1.3.3)			٧			No
6.2	Where used a	s a prote	ective	measure,	requireme	nts for S	SELV or F	ELV me	t (701	.414.4.5)				N/	Ά.		No
6.3	Shaver socket		-										1				No
6.4	Presence of si										01.415.2))		•			No
6.5	Low voltage (e							•					1	ν			No
6.6	Suitability of e									P rating (7	01.512.2)	1	•	,		No
6.7	Suitability of a							•									No
6.8	Suitability of c				<u> </u>	·		the loca	tion (7	701.55)				v			No
7.0	OTHER PART											. 1					
7.1	List all other spections ap		nstallat	ons or lo	cations pre	sent, if	any. (Rec	ord sepa	arately	the resul	s of parti		imber of cations		0		No

Inspected By		
Name:	Martyn Thorpe	Date: 09/01/2020
Signature:	O_	

Boar	rd Detai	ils															
			ED IN EVERY CASE		ONLY TO	O BE CO	MPLETE	:D IF THI	E DISTRI	IBUTION BOARE OF THE INSTAL		ONNE	ECTED	DIRECTI	LY TO T	HE ORIG	SIN
Locat	tion of	mains	room		Supply to		1/4						Asso	ciated R0	CD (if an	y)	
	bution	III Canada	100	l t	distributio board is f	from:	N/A				BS	(EN)		N/A			
				_	No of pha		N/A			I Voltage N/A		D No	of	N/A			
Distrib	bution	DB 1						ce for the		ition circuit	.	les					
	nation				Type BS(EN)	N/A			Rating N/A	A RO	D Rat	ting	N/A		n	nA
Circu	uit Deta	ils			7						Overcurre	nt nro	toctive				
mber				iring	nethod	serve		cuit tors csa	itted ction s)			evice	lective			RCD	Zs (Ω)
Circuit number and phase		Circuit o	designation	Type of wiring	Reference method	No of points served	Live mm ²	cpc mm ²	Max permitted disconnection times (s)	BS(EN)	AFI	DD .	Туре	Rating (A)	Short circuit capacity (kA)	Operating current (Δn)	Maximum permitted Zs (Ω)
1/L1	heater lectu	ure 1		А	В	2	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
1/L2	heater drill	hall		А	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
1/L3	heater atc o	office		А	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
2/L1	heater lectu	ure 2		А	В	2	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
2/L2	heater drill	hall		А	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
2/L3	heater atc			А	В	2	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
3/L1	SPARE			-	-	-	-	-	-	-	-		-	-	-	-	-
3/L2	heater drill	hall		А	В	2	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
3/L3	Water heate	er wc		А	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
4/L1	Lecture rom	nm and off	fice skts	A	В	9	2.5	1.5	0.4	3871 MCB			2	32	10	30	1667
4/L2	drill hall skt	is		А	В	4	2.5	1.5	0.4	3871 MCB			2	16	10	30	1667
4/L3	fire alarm			А	В	1	1.5	1	0.4	3871 MCB			2	6	10	30	1667
5/L1	Lts lecture i	room		А	В	12	1.5	1	0.4	3871 MCB			2	6	10	30	1667
5/L2	Lts drill hall	ī		А	В	13	1.5	1	0.4	3871 MCB			2	6	10	30	1667
5/L3	kit water he	ater		A	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
6/L1	heater ACF	- office		А	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
6/L2	frost heater	rs		А	В	4	1.5	1	0.4	60898 MCB			С	6	10	30	1667
6/L3	kit water he	ater		А	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
7/L1	Store Its			А	В	3	1.5	1	0.4	3871 MCB			2	6	10	30	1667
7/L2	Corridor he	ater		А	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
7/L3	office skts ,	,corridor		А	В	8	2.5	1.5	0.4	3871 MCB			2	32	10	30	1667
8/L1	WC Its			А	В	8	1.5	1	0.4	3871 MCB			2	6	10	30	1667
8/L2	alarm			А	В	1	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
8/L3	Corridor off	fice Its		A	В	10	1.5	1.5	0.4	3871 MCB			2	6	10	30	1667
Wirir	ng Code	е															
		A	В	С	\top	D	\top	E		F	G	T		H		0	1
		Z/PVC bles	PVC cables in metallic conduit	PVC cable in non-metal conduit	Ilic	PVC cable in metallic trunking	: 1	PVC cabl in non-meta trunkin	allic	PVC/SWA cables	XLPE/SW cables			insulated bles	0	ther	

Board 7	rests															
		TO BE C	OMPLETED) IN EVERY	CASE				TE	ST INSTRI	IMENIT	S (SERIAL N	LIMBERS) LISED		
Correct	supply pola	arity confirme	d 🗸		equence co		V			01 11401110	JIVILIVI	O (OLIVI) I	OWIDEIRO) GOLD		
Su	pplementa	ary Conductor	rs 🗸	(where a	ppropriate)			Earth fau	22	5710		RCD	2257	710		
ONLY TO		MPLETED IF					ECTED	Insulation	1 22	5710		Multi-				
Zs N/	A s	Σ lpf N/	A kA					resistano	e			functi	On			
Operatin	g times of	associated R	CD (if any)	At I Δ n N	/A m	ıs		Continuit	у 22	5710		Other	N/A			
Details	of circu	ıits and/oı	r equipm	nent vuln	erable t	o dama	ge									
N/A																
Circuit	Tests															
Onodit	. 00.0	Circ	uit Impedar Ω	nces			Insu	lation resis	tance				RC	D	Ę	_
Circuit	Dia	q final circuits		All cir							3	Maximum measured	- ue		AFDD Test button operation	Remarks see continuation sheet
number and		easure end to		(At lea	mn	Test	Live/	Live/	Live/	Earth/	Polarity (earth fault loop	ing tir (ms)	buttor	D Test bu	Remai contin
phase	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	to be cor	(R ₂)	Voltage	Live MΩ	Neutral MΩ	Earth MΩ	Neutral MΩ	۵	impedance Ω	Operating time at I∆ n (ms)	Test button operation	AFDE	see
1/L1	N/A	N/A	N/A	0.29	N/A	500	N/A	200	200	200		0.41	47			NO
1/L2	N/A	N/A	N/A	0.35	N/A	500	N/A	200	200	200	√	0.47	47	✓		NO
1/L3	N/A	N/A	N/A	0.57	N/A	500	N/A	200	200	200		0.69	47			NO
2/L1	N/A	N/A	N/A	0.59	N/A	500	N/A	200	200	200	√	0.71	47	√		NO
2/L2	N/A	N/A	N/A	0.57	N/A	500	N/A	200	200	200	· ·	0.69	47	· ·		NO
2/L3	N/A	N/A	N/A	0.52	N/A	500	N/A	200	200	200	v	0.64	47	· ·		NO
3/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3/L2	N/A	N/A	N/A	0.71	N/A	500	N/A	200	200	200	1	0.83	47	1		NO
3/L3	N/A	N/A	N/A	0.25	N/A	500	N/A	200	200	200	1	0.37	47	1		NO
4/L1	0.78	0.78	1.30	0.15	N/A	500	N/A	200	200	200	1	0.27	47	1		NO
4/L2	N/A	N/A	N/A	0.29	N/A	500	N/A	200	200	200	1	0.41	47	1		NO
4/L3	N/A	N/A	N/A	0.11	N/A	500	N/A	200	200	200	1	0.23	47	1		NO
5/L1	N/A	N/A	N/A	0.39	N/A	500	N/A	200	200	200	1	0.51	47	1		NO
5/L2	N/A	N/A	N/A	0.35	N/A	500	N/A	200	200	200	1	0.47	47	1		NO
5/L3	N/A	N/A	N/A	0.34	N/A	500	N/A	200	200	200	1	0.46	47	1		NO
6/L1	N/A	N/A	N/A	0.67	N/A	500	N/A	200	200	200	1	0.79	47	1		NO
6/L2	N/A	N/A	N/A	0.64	N/A	500	N/A	200	200	200	1	0.76	47	1		NO
6/L3	N/A	N/A	N/A	0.28	N/A	500	N/A	200	200	200	1	0.40	47	✓		NO
7/L1	N/A	N/A	N/A	0.29	N/A	500	N/A	200	200	200	1	0.41	47	1		NO
7/L2	N/A	N/A	N/A	0.47	N/A	500	N/A	200	200	200	1	0.59	47	1		NO
7/L3	0.69	0.68	1.13	0.25	N/A	500	N/A	200	200	200	1	0.37	47	1		NO
8/L1	N/A	N/A	N/A	0.19	N/A	500	N/A	200	200	200	1	0.31	47	1		NO
8/L2	N/A	N/A	N/A	0.15	N/A	500	N/A	200	200	200	1	0.27	47	1		NO
8/L3	N/A	N/A	N/A	0.19	N/A	500	N/A	200	200	200	1	0.31	47	1		NO
Tested	Ву															
Signa	ture			a				Position	1	Approve	ed Ele	ctrician				
Name	;	Martv	n Thorpe	:				Date of testing		09/01/2	020					
		,						testing							_	

Boar	rd Detai	ls															
T	O BE CO	MPLETE	D IN EVERY CASE		ONLY T	O BE CO	MPLETE	D IF THI	E DISTR	IBUTION BOARE OF THE INSTAL			IECTED	DIRECTI	LY TO T	HE ORIO	3IN
Logat	tan of	mains	room		Supply to	,							Asso	ociated RC	DD (if an	y)	
Distrib	bution	IIIaiiio	100111		distributio board is f	on 1	N/A				4	BS(EN)		N/A			
Board					No of pha		N/A		Nominal	Voltage N/A	V	RCD N					
Distril	bution	DB 1		41	Overcurre	ent protec	ctive devi	ce for the	e distribu	ition circuit		Poles	0 01	N/A			
board		ו אט			Type BS((EN)	N/A			Rating N/A	А	RCD R	ating	N/A		n	nA
Circu	uit Deta	ils															
				DE DE	poq	rved	Cir	rcuit	D. C.		Overd	current pr device	rotective			RCD	(Ω)
Circuit number and phase		Circuit o	designation	Type of wiring	Reference method	No of points served	conduct Live mm ²	cpc mm ²	Max permitted disconnection times (s)	BS(EN)		AFDD	Туре	Rating (A)	Short circuit capacity (kA)	Operating current (∆n)	Maximum permitted Zs (Ω)
9/L1	Unknown			A	В	0	2.5	1.5	0.4	3871 MCB			2	20	10	30	1667
9/L2	timer			А	В	1	1.5	1	0.4	3871 MCB			2	6	10	30	1667
9/L3	O/S Its			A	В	5	1.5	1	0.4	3871 MCB			2	6	10	30	1667
10/L1	Store heate	r		А	В	1	2.5	1.5	0.4	3871 MCB			3	16	10	30	1667
10/L2	Sub Mains(DB 2)		F	С	1	6	6	5	3871 MCB			3	45	10	30	1667
10/L3	kit hand drie	ər		A	В	1	2.5	1.5	0.4	3871 MCB			3	10	10	30	1667
11/L1	Staff wc har	nd drier		А	В	1	2.5	1.5	0.4	3871 MCB			3	10	10	30	1667
11/L2	SPARE			-	-	-	-	1	-	-		-		-	-	-	-
11/L3	SPARE			-	-	-	-	-	-	-		-	-	-	-	-	-
12/L1	girls wc han	nd drier		А	В	1	2.5	1.5	0.4	3871 MCB			3	10	10	30	1667
12/L2	SPARE			-	-	-	-	-	-	-		-	-	-	-	-	-
12/L3	SPARE			-	-	-	-	-	-	-		-	-	-	-	-	-
				+													
				+													
				+				<u> </u>									
				+				<u> </u>	 					\vdash			
								<u> </u>									
				+	-		<u> </u>	<u> </u>	<u> </u>					\vdash			
					-		<u> </u>	<u> </u>	<u> </u>								
					 	<u> </u>	<u> </u>	<u> </u>	<u> </u>								
	<u> </u>				<u> </u>		<u> </u>	<u> </u>	<u> </u>								
	<u> </u>						<u> </u>	<u> </u>	<u> </u>								
Wirir	ng Code	9															
	A	4	В	С		D		Е		F		G		Н		0	
	PVC/ cab		PVC cables in metallic conduit	PVC cable in non-metal conduit	Ilic	PVC cable in metallic trunking	: 1	PVC cabl in non-meta trunkin	allic	PVC/SWA cables		E/SWA ables		l insulated ables	0	other	

Board 7	Tests															
Board	. 00.0	TO BE C	OMPLETED) IN EVERY	CASE				TE	OT INOTOL	INACNIT	O (OEDIAL N	LIMPEDO) LICED		
Correct	supply pol	arity confirme	d 🗸	Phase se	equence co	nfirmed	<u> </u>	-	IE:	STINSTRU	JIVIEN I	S (SERIAL N	UMBERS) USED		
Su	pplementa	ary Conductor	s 🗸		ppropriate)		•	Earth fau		5710		RCD	2257	710		
	O BE CON	MPLETED IF	THE DISTR				ECTED	impedan Insulation	ce			Multi-				
- N/		ECTLY TO T			STALLATIO	ON		resistano		5710		function	on N/A			
Zs N/		2 Ipf N/A associated R			/A m	ıs		Continuit	y 22	5710		Other	N/A			
		its and/or					ge									
N/A	OI OII OC	nto arra/or	Счирп	icht vani	CIUDIC (o dama	gc									
IN/A																
Circuit	Tests	Circ	cuit Impedar	2000												
		Circ	Ω				Insu	lation resis	tance			Maximum	RC	D	ıtton	tion
Circuit number		g final circuits		All cir (At lea	st one						ity (v)	measured earth fault	time	To Lo	AFDD Test button operation	Remarks see continuation sheet
and phase	(me	easure end to	end)	to be cor		Test Voltage	Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral	Polarity (loop	ating n (ms	Test button operation	DD Te	Ren e con sh
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂₎	(R ₂)		ΜΩ	ΜΩ	ΜΩ	ΜΩ		Ω	Operating time at I∆ n (ms)	Teg ob	AFI	S. O.
9/L1	N/A	N/A	N/A	0	N/A	500	N/A	200	200	200	1	lim	47	1		NO
9/L2	N/A	N/A	N/A	0.37	N/A	500	N/A	200	200	200	1	0.49	47	1		NO
9/L3	N/A	N/A	N/A	0.37	N/A	500	N/A	200	200	200	1	0.49	47	1		NO
10/L1	N/A	N/A	N/A	0.19	N/A	500	N/A	200	200	200	1	0.31	47	1		NO
10/L2	N/A	N/A	N/A	0.20	N/A	500	N/A	200	200	200	1	0.32	47	1		NO
10/L3	N/A	N/A	N/A	0.39	N/A	500	N/A	200	200	200	1	0.51	47	1		NO
11/L1	N/A	N/A	N/A	0.38	N/A	500	N/A	200	200	200	1	0.50	47	1		NO
11/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12/L1	N/A	N/A	N/A	0.49	N/A	500	N/A	200	200	200	1	0.61	47	1		NO
12/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Tested	Ву															
Signa	ture			a				Position		Approve	ed Ele	ectrician				
Name	e	Marty	n Thorpe					Date of testing		09/01/2	020					
								9								

Boar	d Deta	ils														
			ED IN EVERY CASE		ONLY	TO BE CO	OMPLETE	D IF TH	E DISTR	IBUTION BOARD IS OF THE INSTALL		NECTED	DIRECT	LY TO T	HE ORIC	SIN
Locati Distrib Board	bution	range			Supply distribut	tion s from:	SubMai			L2) I Voltage 230 v	BS(EN)		ociated R0	CD (if an		
										ition circuit	RCD No Poles	o of	4			
Distrib board design		DB 2			Type BS		3871 M			Rating 45		ating	30		n	nA
Circu	uit Deta	ails														
				- BE	podi	irved	Cir	rcuit	p u	(Overcurrent produce				RCD	(Ω)
Circuit number and phase		Circuit (designation	Type of wiring	Reference method	No of points served	Live mm ²				AFDD	Туре	Rating (A)	Short circuit capacity (kA)	Operating current (∆n)	Maximum permitted Zs(Ω)
1/L2	Skts			A	В	4	2.5	1.5	0.4	61009 RCD/RCB0)	В	32	10	30	1667
2/L2	office heate			A	В	1	2.5	1.5	0.4	60898 MCB		В	16	10	30	1667
3/L2	heater rang	je		A	В	1	2.5	1.5	0.4	60898 MCB		В	16	10	30	1667
4/L2	heater rang	je		A	В	1	2.5	1.5	0.4	60898 MCB		В	16	10	30	1667
5/L2	Lts			A	В	14	1.5	1	0.4	60898 MCB		В	10	10	30	1667
6/L2	flood light			А	В	1	1.5	1	0.4	60898 MCB		В	10	10	30	1667
7/L2	fans			А	В	2	1.5	1	0.4	60898 MCB		В	10	10	30	1667
8/L2	SPARE			-	-	-	-	-	-	-	-	-	-	-	-	-
9/L2	SPARE			-	-	-	-	-	-	-	-	-	-	-	-	-
10/L2	SPARE			-	-	-	-	-	-	-	-	-	-	-	-	-
11/L2	SPARE			-	-	-	-	-	-	-	-	-	-	-	-	-
12/L2	SPARE			-	-	-	-	-	-	-	-	-	-	-	-	-
13/L2	SPARE			-	-	-	-	-	-	-	-	-	-	-	-	-
14/L2	SPARE			-	-	† -	-	-	-	-	-	-	-	-	-	-
15/L2	SPARE			-	-	-	-	-	-	-	-	-	-	-	-	-
16/L2	SPARE			-	-	-	-	-	-	-	-	-	-	-	-	-
						+	†									
					+	+										
				+		†										
	<u> </u>			+	+	+	+									
				+		+	+									
				+-	+	+	+									
				+	+	+	+									
					+	_	+									
Wirir	ng Code	e														
		A	В	С	$\neg \neg$	D	\top	E	$\overline{}$	F	G	Т	Н	_	0	1
	PVC	Z/PVC bles	PVC cables in metallic conduit	PVC calc in non-met condu	tallic	PVC cable in metallic trunking	С	PVC cabl in non-meta trunkin	allic	PVC/SWA cables	XLPE/SWA cables	Mineral	il insulated ables	4	other	

Board 7	Tests																	
		TO BE CO	OMPLETED	IN EVERY	CASE				Т	TEST	INSTRU	MENT	S (SERIA	ı_ NUI	MBERS	USED		
Correct	supply pola	arity confirmed	d 🗸		quence co		√						- (,		
Su	ıpplementa	ary Conductor	rs 🗸	(where ap	ppropriate)			Earth fau	2	257	10		R	CD	2257	710		
ONLY T		MPLETED IF T					ECTED	Insulation resistance	2	257°	10			ulti- nction	N/A			
Zs 0.3	32 Ω	2 lpf 0.6	699 kA					Continuit		257°	10			ther	N/A			
Operatir	ig times of	associated R	CD (if any)	At I∆ n 47	7 m	IS		Continuit	, _[2	.231	10				IN/A			
Details	of circu	uits and/or	r equipm	ent vulne	erable t	o damaç	ge											
none																		
Circuit	Tests	Cina	wit leaves le										1					
		Circ	cuit Impedar Ω				Insul	lation resist	ance				Maximu	.m	RC	D	tton	ion
Circuit number and		g final circuits		All circ (At leas colui	st one	Test	Live/	Live/	Live	2/	Earth/	Polarity (v)	measur earth fa	ed ult	Operating time at l∆ n (ms)	Test button operation	AFDD Test button operation	Remarks see continuation sheet
phase				to be com	,	Voltage	Live	Neutral	Earth	h N	Neutral	Pol	loop impedar	nce	eratin ∆ n (r	est b	FDD op	Re see co
4 // 0		r _n (Neutral)		(R _{1 + R₂)}	(R ₂)	500	ΜΩ	ΜΩ	ΜΩ		ΜΩ		Ω			-	∢	
1/L2	0.41	0.41	0.67	0.45	N/A	500	N/A	200	200		200	✓	0.77		19	✓		NO
2/L2	N/A	N/A	N/A	0.15	N/A	500	N/A	200	200		200	✓	0.47		47	✓		NO
3/L2	N/A	N/A	N/A	0.17	N/A	500	N/A	200	200		200	✓	0.49		47	✓		NO
4/L2	N/A	N/A	N/A	0.29	N/A	500	N/A	200	200		200	✓	0.61		47	✓		NO
5/L2	N/A	N/A	N/A	1.38	N/A	500	N/A	200	200	'	200	✓	1.70		47	✓		NO
6/L2	N/A	N/A	N/A	0.34	N/A	500	N/A	200	200		200	✓	0.66		47	✓		NO
7/L2	N/A	N/A	N/A	0.17	N/A	500	N/A	200	200		200	✓	0.49		47	✓		NO
8/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
9/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
10/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
11/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
12/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
13/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
14/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
15/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
16/L2	-	-	-	-	-	-	-	-	-		-	-	-		-	-	-	-
Tested	Ву																	
Signa				a				Position		Α	pprove	d Ele	ctrician					
Name	2	Morty	n Thorpe					Date of testing		09	9/01/20	20						

Agreed limitations including the reasons, Continued. from page 1
heights regs apply

CONDITION REPORT GUIDANCE FOR RECIPIENTS (to be appended to the Report)

This Report is an important and valuable document which should be retained for future reference.

- 1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
- The person ordering the Report should have received the 'original' Report and the inspector should have retained a duplicate.
- 3. The 'original' Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
- Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested six-monthly. For safety reasons it is important that this instruction is followed.
- 5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
- 6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
- 7. For items classified in Section K as C1 ('Danger present'), the safety of those using the installation is at risk, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
- 8. For items classified in Section K as C2 ('Potentially dangerous'), the safety of those using the installation may be at risk and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
- 9. Where it has been stated in Section K that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
- 10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit/ distribution board.