

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR		(*Where applicable)		DETAILS OF THE CLIENT		DETAILS OF THE INSTALLATION	
Registration No:	028288000	Branch No*:	000	Contractor Reference Number (CRN):	25177	Occupier:	N/A
Trading Title:	R J Electrical Services Ltd			Name:	Wessex RFCA	UPRN:	N/A
Address:	Unit 3a, Barnack Industrial Esta, Kingsway, Salisbury			Address:	Wessex Reserve Forces & Cadets Association, Mount House, Mount Street, Taunton, Somerset	Address:	Wessex ACF, Tilshead, Salisbury, Wiltshire
Postcode:	SP2 0AW	Tel No:	01722741091	Postcode:	TA1 3QE	Tel No:	N/A
						Postcode:	SP3 4RX
						Tel No:	N/A

PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required:
Scheduled inspection

Date(s) when inspection and testing was carried out: (27/02/2024 - 29/02/2024) Records available (651.1): () Previous inspection report available (651.1): () Previous report date: (21/10/2018)

PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): Good except observations

Description of premises Dwelling: (N/A) Commercial: (N/A) Industrial: (N/A) Other (include brief description): Training center

Estimated age of electrical installation: (30) years Evidence of additions or alterations: (if Yes, estimated age 2 years) Overall assessment of the installation for continued use: **Satisfactory/Unsatisfactory**** (delete as appropriate)

**An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified (listed in PART 5 of this report) and it is recommended that these are acted upon as a matter of urgency.

PART 4 : DECLARATION

INSPECTION AND TESTING

I/We, being the person responsible for the inspection and testing of the electrical installation (as indicated by my/our signature below), particulars of which are described in PART 6, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (PART 5) and the attached Schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in PART 6 of this report.

Name (capitals) on behalf of the contractor identified in PART 1: IAN TANNER Signature:  Date: 27/02/2024

I/We further RECOMMEND, subject to the necessary remedial action being taken, that the installation is inspected and tested by: 27/02/2029 (date)

Give reason for recommendation: Training center used by students

The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE CONTRACTOR

Name (capitals) on behalf of the contractor identified in PART 1: ROBERT COOMBS Signature:  Date: 05/03/2024

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 5 : OBSERVATIONS

One of the following Codes, as appropriate, has been allocated to each of the observations made below to indicate to the person(s) responsible for the electrical installation the degree of urgency for remedial action:

Code C1 Danger Present
Risk of injury. Immediate remedial action required

Code C2 Potentially Dangerous
Urgent remedial action required

Code C3 Improvement Recommended

Code F1
Further Investigation Required

Referring to the **Schedule of Items Inspected** (see PART 9), the attached **Schedule of Circuit Details and Test Results** (see PART 11A & 11B), and subject to any **agreed limitations** listed in PART 6

No remedial action is required (X), OF

The following observations are made

Item No	Observation(s)	Code	Location Reference
(.1....)	(3.1 Unable to verify main earthing arrangement.	(FI....)	(Main intake.....)
(.2....)	4.3 Neutral bar support in DB AB2C has deteriorated to the point where it could be a possible fire hazard from arcing between the two sections. Temporary link has been fitted to support this. Replacement DB required.	(C2....)	(Accom block 2.....)
(.3....)	5.23RCD's protecting distribution circuits for DB 5&7 and workshop are inside the main distribution board and not accessible without removing panels. this would mean shutting down the hole site to reset. Poor design.	(C3....)	(MCP1.....)
(.4....)	(6.3 Low insulation reading on Cct 1 Lighting.	(FI....)	(Accom block 2.....)
(.5....)	(..... External socket to block with office broken and requires replacement	(C2....)	(building near gate.....)
(.6....)	(..... 3 showers failed, two electrically and third has water leak, two in male cadets and third in adult male shower room.	(C3....)	(shower rooms.....)
(.7....)	(..... Two heaters have failed, one in male cadets and one in female cadets	(C3....)	(Shower rooms.....)
(.8....)	(..... Photo cell to bollard lighting has failed so lights on permanently.	(C3....)	(accom blk 3.....)
(.9....)	(..... Single insulated tales to drying room container travel through metal structure from external adaptable box with no mechanical protection.	(C2....)	(Drying room.....)
(.10....)	(..... r1r2 and zs readings high on sockets for length of run in classroom, DB5. one circuit starts as 6mm in fuse board and is 2.5mm at socket outlets. possible poor connections	(FI....)	(Classroom building.....)
(.11....)	Heaters in classroom building wired in 1.5mm and two circuits protected by 20mcb's. the other two by 16a mcb's. switched fuse spurs are used for heaters so in effect they can only pull a max of 13amps:	(C3....)	(classroom blockDB5.....)
(.12....)	(..... Lighting in male shower area not functioning, possible sensor failure	(FI....)	(male showers.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
		Additional pages? (.....)	State page numbers: (.....)
Immediate remedial action required for items:	(N/A.....)	Improvement recommended for items:	(3,6,7,8,11.....)
Urgent remedial action required for items:	(2,5,9.....)	Further investigation required for items:	(1,4,10,12.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 6 : DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671: 2018, as amended to N/A (date). Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the electrical installation covered by this report: Fixed wiring only (see additional page No. N/A)

Agreed limitations including the reasons, if any, on the inspection and testing (653.2): Visual check of outside lighting only, where isolators to heaters are within the cages, these heaters have not been tested, new led strip lighting to shower and toilet blocks are difficult to open without damaging so r2 tests have been carried out on these at the earthing screw on the end and zS readings taken on emergency lights.

Agreed with (print name): POC

Extent of sampling: 25% (see additional page No. N/A)

Operational limitations including the reasons: none (see additional page No. N/A)

PART 7 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements			Number and type of live conductors			Nature of supply parameters		
TN-C: (N/A)	TN-S: (N/A)	TN-C-S: (N/A)	AC 1-phase, 2-wire: (N/A)	2-phase, 3-wire: (N/A)	N/A	Nominal voltage between lines, $U^{[1]}$: (400) V	[1] By enquiry	[2] By enquiry or by measurement
TT: (N/A)	IT: (N/A)		3-phase, 3-wire: (N/A)	3-phase, 4-wire: (N/A)	✓	Nominal line voltage to Earth, $U_0^{[1]}$: (230) V		
Supply protective device			DC 2-wire: (N/A)	3-wire: (N/A)	Other: (N/A)	Nominal frequency, $f^{[1]}$: (50) Hz		
BS EN: (LIM)	Type: (N/A)	Rated current: (LIM) A	Confirmation of supply polarity:			Prospective fault current, $I_{pf}^{[2]*}$: (2.5) kA		
			Other sources of supply (Schedule of Test Results)			External earth fault loop impedance, $Z_e^{[2]*}$: (0.08) Ω		
			Page No: (N/A)					

PART 8 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Maximum demand (load): (N/A) XX/X (delete as appropriate)	Main protective conductors	Main protective bonding connections	Main switch / Switch-fuse / Circuit-breaker / RCD
Means of Earthing			
Distributor's facility: (N/A)	Earthing conductor: (material N/A)	Water installation pipes: (N/A)	Location: (in mains cupboard)
Installation earth electrode(s): (N/A)	csa (N/A ..) mm ² Connection/continuity verified: (N/A)	Gas installation pipes: (N/A)	BS EN: (60947-3) Type: (3) A Rating / setting of device: (....) A
Earth electrode type – rod(s), tape, etc: (N/A)	Main protective bonding conductors: (material Copper)	Structural steel: (N/A)	No. of poles: (3) Current rating: (400) A Voltage rating: (415) V
Location: (N/A)	csa (N/A ..) mm ² Connection/continuity verified: (N/A)	Oil installation pipes: (N/A)	
Electrode resistance to Earth: (N/A) Ω		Lightning protection: (N/A)	Where an RCD is used as the main switch
		Other (state): (N/A)	RCD rated residual operating current, $I_{\Delta n}$: (....) mA RCD Type: (AC)
		(N/A)	Rated time delay: (N/A) ms Measured operating time: (N/A) ms

*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I_{pf} , and external earth fault loop impedance, Z_e , must be recorded.

All fields must be completed. Enter either, as appropriate: '✓' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists, or
Code appropriately: CODE 'C1' 'C2' 'C3' or 'F1' (codes to be recorded in PART 5, with additional comments (where appropriate) on attached numbered sheets)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

1.0 Intake equipment (visual inspection only)

An outcome against an item in section 1.1, other than access to live parts, should not be used to determine the overall assessment of the installation. Where inadequacies are identified, a cross should be put against the appropriate item and a comment made in Part 5 of this report.

1.1 Distributor / supplier intake equipment

- Service cable (.....✓.....)
- Service head (.....✓.....)
- Earthing arrangement (.....✓.....)
- Meter tails (.....✓.....)
- Metering equipment (.....✓.....)
- Isolator, where present (.....✓.....)

Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and / or dutyholder must be informed.

It is strongly recommended that the person ordering the work informs the appropriate authority.

1.2 Consumer's isolator, where present (.....✓.....)

1.3 Consumer's meter tails (.....✓.....)

2.0 Presence of adequate arrangements for parallel or switched alternative sources

2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6) (N/A.....)

2.2 Adequate arrangements where a generating set operates in parallel with the public supply (551.7) (N/A.....)

3.0 Methods of protection

3.1 Automatic disconnection of supply (ADS)

- Main earthing / bonding arrangement (411.3; Chap. 54) (FI.....)
- Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or presence of installation earth electrode arrangement (542.1.2.3) (.....✓.....)
- Adequacy of earthing conductor size (542.3; 543.1.1) (.....✓.....)
- Adequacy of earthing conductor connections (542.3.2) (.....✓.....)
- Accessibility of earthing conductor connections (543.3.2) (.....✓.....)
- Adequacy of main protective bonding conductor sizes (544.1.1) (.....✓.....)
- Adequacy and location of main protective bonding conductor connections (544.1.2) (LIM.....)

- Accessibility of all protective bonding connections (543.3.2) (.....✓.....)
- Provision of earthing / bonding labels at all appropriate locations (514.13.1) (.....✓.....)
- 3.2 FELV - requirements satisfied (411.7) (N/A.....)
- 3.3 Other methods of protection

Where any of the methods listed below are employed, details should be provided on separate sheets

 - Non-conducting location (418.1) (N/A.....)
 - Earth-free local equipotential bonding (418.2) (N/A.....)
 - Electrical separation (413; 418.3) (N/A.....)
 - Double insulation (412) (N/A.....)
 - Reinforced insulation (412) (N/A.....)
 - Provisions where automatic disconnection of supply is not feasible (419) (N/A.....)
- 4.0 Distribution equipment, including consumer units and distribution boards
 - 4.1 Adequacy of working space / accessibility to equipment (132.12; 513.1) (.....✓.....)
 - 4.2 Security of fixing (134.1.1) (.....✓.....)
 - 4.3 Condition of insulation of live parts (416.1) (C2.....)
 - 4.4 Adequacy security of barriers or enclosures (416.2.3) (.....✓.....)
 - 4.5 Condition of enclosure(s) in terms of IP rating, etc. (416.2) (.....✓.....)
 - 4.6 Condition of enclosure(s) in terms of fire rating, etc. (421.1.201; 421.1.6; 526.5) (.....✓.....)
 - 4.7 Enclosure not damaged / deteriorated so as to impair safety (651.2) (.....✓.....)
 - 4.8 Presence and effectiveness of obstacles (417.2) (.....✓.....)
 - 4.9 Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2) (.....✓.....)
 - 4.10 Operation of main switch(es) (functional check) (643.10) (.....✓.....)
 - 4.11 Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10) (.....✓.....)
 - 4.12 Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check) (643.10) (.....✓.....)
 - 4.13 RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.4.5; 411.5.2; 531.2) (.....✓.....)
 - 4.14 RCD(s) provided for additional protection / requirements, where required - includes RCBOs (411.3.3; 415.1) (.....✓.....)
 - 4.15 Presence of RCD six-monthly test notice, where required (514.12.2) (.....✓.....)
- 4.16 Confirmation that integral test button / switch, where present, causes AFDD to trip when operated (643.10) (.....✓.....)
- 4.17 Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1) (.....✓.....)
- 4.18 Presence of alternative supply warning notice at or near equipment, where required (514.15) (N/A.....)
- 4.19 Presence of next inspection recommendation label, where required (514.12.1) (.....✓.....)
- 4.20 Presence of other required labelling (please specify) (514) (.....✓.....)
- 4.21 Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (432; 433; 434) (.....✓.....)
- 4.22 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) (.....✓.....)
- 4.23 Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11) (.....✓.....)
- 4.24 Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1) (.....✓.....)

5.0 Distribution circuits

- 5.1 Identification of conductors (514.3) (.....✓.....)
- 5.2 Cables correctly supported throughout their run (521.10.202; 522.8.5) (.....✓.....)
- 5.3 Condition of insulation of live parts (416.1) (.....✓.....)
- 5.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1) (.....✓.....)
- 5.5 Suitability of containment systems for continued use (including flexible conduit) (522) (.....✓.....)
- 5.6 Cables correctly terminated in enclosures (526) (.....✓.....)
- 5.7 Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1) (.....✓.....)
- 5.8 Examination of cables for signs of unacceptable thermal or mechanical damage / deterioration (421.1; 522.6) (.....✓.....)
- 5.9 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (523) (.....✓.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or Fl, as applicable)

5.10 Adequacy of protective devices; type and rated current for fault protection (411.3)	(.....)	6.2 Cables correctly supported throughout their run (521.10.202; 522.8.5)	(.....)	▪ *For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203) (.....)
5.11 Presence and adequacy of circuit protective conductors (411.3.1; 543.1)	(.....)	6.3 Condition of insulation of live parts (416.1)	(.....)	▪ *For final circuits supplying luminaires within domestic (household) premises (411.3.4) (.....)
5.12 Coordination between conductors and overload protective devices (433.1; 533.2.1)	(.....)	6.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	(.....)	
5.13 Cable installation methods / practices with regard to the type and nature of installation and external influences (522)	(.....)	6.5 Suitability of containment systems for continued use (including flexible conduit) (522)	(.....)	*Older installations designed prior to BS 7671: 2018 may not have required RCDs for additional protection.
5.14 Where exposed to direct sunlight, cable of a suitable type (522.11.1)	(.....)	6.6 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (523)	(.....)	6.14 Provision of fire barriers, sealing arrangements and protection against thermal effects (527) (.....)
5.15 Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) –	(.....)	6.7 Adequacy of protective devices; type and rated current for fault protection (411.3)	(.....)	6.15 Band II cables segregated / separated from Band I cables (528.1) (.....)
▪ Installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)	LIM (.....)	6.8 Presence and adequacy of circuit protective conductors (411.3.1; 543.1)	(.....)	6.16 Cables segregated / separated from non-electrical services (528.3) (.....)
▪ Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204)	(.....)	6.9 Co-ordination between conductors and overload protective devices (433.1; 533.2.1)	(.....)	6.17 Termination of cables at enclosures - identify / record numbers and locations of items inspected (526) –
5.16 Provision of fire barriers, sealing arrangements and protection against thermal effects (527)	(.....)	6.10 Wiring system(s) appropriate for the type and nature of the installation and external influences (522)	(.....)	▪ Connection under no undue strain (526.6) (.....)
5.17 Band II cables segregated / separated from Band I cables (528.1)	(.....)	6.11 Where exposed to direct sunlight, cable of a suitable type (522.11.1)	(.....)	▪ No basic insulation of a conductor visible outside enclosure (526.8) (.....)
5.18 Cables segregated / separated from non-electrical services (528.3)	(.....)	6.12 Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) –	(.....)	▪ Connections of live conductors adequately enclosed (526.5) (.....)
5.19 Condition of circuit accessories (651.2)	(.....)	▪ Installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)	LIM (.....)	▪ Adequately connected at point of entry to enclosure (glands, bushes, etc.) (522.8.5) (.....)
5.20 Suitability of circuit accessories for external influences (512.2)	(.....)	▪ Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204)	LIM (.....)	6.18 Condition of accessories including socket-outlets, switches and joint boxes (651.2) (.....)
5.21 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	(.....)	6.13 Provision of additional protection by RCD having rated residual operating current not exceeding 30 mA –	(.....)	6.19 Suitability of accessories for external influences (512.2) (.....)
5.22 Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment - identify / record numbers and locations of items inspected (526)	(.....)	▪ *For all socket-outlets of rating 32 A or less (411.3.3)	(.....)	6.20 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) (.....)
5.23 Presence, operation and correct location of appropriate devices for isolation and switching (Chap. 46; 537)	C3 (.....)	<i>Additional protection by RCD may not have been provided as a noted exception in certain non-domestic installations covered by indent (ii) of Regulation 411.3.3.</i>		
5.24 General condition of wiring system (651.2)	(.....)	▪ *For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	(.....)	
5.25 Temperature rating of cable insulation (522.1.1; Table 52.1)	(.....)	▪ *For cables concealed in walls at a depth of less than 50 mm (522.6.202)	(.....)	
6.0 Final circuits				
6.1 Identification of conductors (514.3)	(.....)			

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or F1, as applicable)

7.2 Switching off for mechanical maintenance -	(.....)	8.5 Security of fixing (134.1.1)	(.....)	▪ Low voltage (e.g. 230 volt) socket-outlets sited at least 2.5 m from zone 1 (701.512.3) (N/A)
▪ Presence and condition of appropriate devices (464.1; 5373.2)	(.....)	8.6 Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: list number and location of luminaires inspected (separate page) (527.2)	(.....)	▪ Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2) (.....)
▪ Capable of being secured in the OFF position where not under continuous supervision (464.2)	(.....)	8.7 Recessed luminaires (downlighters) -	(.....)	▪ Suitability of accessories and controlgear etc. for a particular zone (701.512.3) (.....)
▪ Correct operation verified (643.10)	(.....)	▪ Correct type of lamps fitted (559.3.1)	(N/A)	▪ Suitability of current-using equipment for particular position within the location (701.55) (.....)
▪ Clearly identified by position and / or durable marking (5373.2.4)	(.....)	▪ Installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	(N/A)	9.2 Other special installations or locations -
7.3 Emergency switching off -	(.....)	▪ No signs of overheating to surrounding building fabric (559.4.1)	(N/A)	N/A (.....)
▪ Presence and condition of appropriate devices (465; 5373.3; 5374)	(.....)	▪ No signs of overheating to conductors / terminations (526.1)	(N/A) (.....)
▪ Readily accessible for operation where danger might occur (5373.3.6)	(.....)		 (.....)
▪ Correct operation verified (643.10)	(.....)		 (.....)
▪ Clearly identified by position and / or durable marking (5373.3.5; 5373.3.6; 5374.3; 5374.4)	(.....)			
7.4 Functional switching -	(.....)			
▪ Presence and condition of appropriate devices (5373.1.1; 5373.1.2)	(.....)			
▪ Correct operation verified (643.10)	(.....)			
8.0 Current-using equipment (permanently connected)				
8.1 Condition of equipment in terms of IP rating, etc. (416.2; 422.3; 422.4; 522.4)	(.....)	9.1 Location(s) containing a bath or shower -	(.....)	10.0 Prosumer's low voltage installation (N/A)
8.2 Equipment does not constitute a fire hazard (421)	(.....)	▪ Additional protection by RCD having rated residual operating current not exceeding 30 mA for all low voltage (LV) circuits serving the location or passing through zones 1 and / or 2 of the location (701.411.3.3) (.....)		
8.3 Enclosure not damaged / deteriorated so as to impair safety (134.1.1; 416.2)	(.....)	▪ Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5) (.....)		
8.4 Suitability for the environment and external influences (512.2)	(.....)	▪ Shaver supply units complying with BS EN 61558-2-5 formerly BS 3535 (701.512.3) (.....)		
		▪ Presence of supplementary bonding conductors, unless not required by BS 7671: 2018 (701.415.2) (.....)	(.....)	

PART 10 : SCHEDULES AND ADDITIONAL PAGES (the pages identified are an essential part of this report (see Regulation 653.2))

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 9.2 above)	Schedules relating to Prosumer's installations (indicated in item 10 above)	Continuation sheets
Page No(s): (.....)	Page No(s): (.....)	Page No(s): (.....)	Page No(s): (.....)	Page No(s): (.....)	Page No(s): (.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 11A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part 11B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART 11B)	Reference Method (BS 16/1)	Number of points served	Circuit conductor (number & csa)		Max disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z_s^* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I_{dn} (mA)
1tp	DBAB2C	F	D	1	16	Sheath	5	60947-2	MCCB	100						
2tp	DB SH	D		1	120	70	5	60947-2	MCCB	160						
3tp	DBAB3N	F	D	1	16	Sheath	5	60947-2	MCCB	100						
4tp	DB 6	F	D	1	50	Sheath	5	60947-2	MCCB	160						
5tp	Surge protection	B		1	10	10	0.4	60947-2	MCCB	32						
6tp	spare															
7tp	spare															
8tp	spare															
911	DB LTG	D		1	16	16		60947-2	MCCB	60						
912	Not used							60947-2	MCCB	60			61008	A	63	30
913	DB 5	F	D	1	16	Sheath	5	60947-2	MCCB	60			61008	A	63	30
10tp	DBAB1S	F	D	1	16	Sheath	5	60947-2	MCCB	100						
11tp	DB PWR	D		1	25	16	5	60947-2	MCCB	100						
1211	DB 7	F	D	1	16	Sheath	5	60947-2	MCCB	60			61008	A	63	30
1212	DB WORKSHOP	F	D	1	16	Sheath	5	60947-2	MCCB	60			61008	A	63	30
1213	DRYING ROOM	D		1	16	16	5	60947-2	MCCB	60						

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: MCP 1

Plant room rear of
Location of DB: male/female shower

Z_{db} 0.08 (Ω)

I_{pr} at DB 2.5 (kA)

Confirmation of supply polarity: (✓) Phase sequence confirmed: (✓)

SPD Details** Types: T1 (N/A) T2 (✓) T3 (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (✓)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART 11B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: N/A

Overcurrent protective device for the distribution circuit

BS (EN): (N/A) Type: (N/A) Nominal voltage: (N/A) V Rating: (N/A) A No. of phases: (N/A)

Associated RCD (if any)

BS (EN): (N/A) RCD Type: (N/A) I_{dn} : (N/A) mA No. of poles: (N/A) Operating time: (N/A) ms


ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 11B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part 11A)

Circuit number	Continuity (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Zs	RCD		AFDD**	Comments and additional information, where required	
	Ring final circuits only (measured end to end)		All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)		(Ω)	Operating time*	Test button		
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂					(ms)	(✓)		
1tp				lim		500	500	1000	✓	0.26			
2tp				lim		500	500	1000	✓	0.08			
3tp				lim		500	500	1000	✓	0.30			
4tp													
5tp													
6tp													
7tp													
8tp													
911													
912													
913				lim		500	500	500	✓	0.34	20.8	✓	
10tp				lim		500	500	1000	✓	0.59			
11tp				lim		500	500	1000	✓	0.1			
1211				lim		500	500	1000	✓	0.52	20.7	✓	
1212				lim		500	500	1000	✓	0.19	20.8	✓	
1213				lim		500	500	1000	✓	0.18			

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

 TESTED BY Name (capitals): IAN TANNER Position: electrician Signature:  Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

 * RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z_s^* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I_{dn} (mA)
1I1	male shower 1	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
1I2	male shower 2	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
1I3	male shower 3	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
2I1	male shower 4	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
2I2	male shower 5	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
2I3	male shower 6	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
3tp	metering															
4tp	metering below via 1a fuses not tested															
5I1	adult shower 1	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
5I2	adult shower 2	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
5I3	adult shower 3	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
6I1	adult shower 4	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
6I2	female shower 1	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
6I3	female shower 2	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
7I1	female shower 3	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
7I2	female shower 4	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
7I3	female shower 5	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30
8I1	female shower 6	O	LIM	1	10	6	0.4	61009	C	45	16		61009	A	45	30

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB SH

Location of DB: Adjacent incoming mains

$Z_{db} = 0.08$ (Ω)

I_{pr} at DB = 2.7 (kA)

Confirmation of supply polarity: () Phase sequence confirmed: (N/A)

SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: MCP 1 - 2tp

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2) Type: (MCCB) Nominal voltage: (400) V Rating: (160) A No. of phases: (3)

Associated RCD (if any)

BS (EN): (N/A) RCD Type: (N/A) I_{dn} : (.....) mA No. of poles: (N/A) Operating time: (N/A) ms


CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Zs	RCD		AFDD**	Comments and additional information, where required	
	Ring final circuits only (measured end to end)		All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)		(Ω)	Operating time*	Test button		
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂					(ms)	(✓)		
111				0.14		500	500	500	✓	0.24	29.2	✓	
112				0.10		500	500	500	✓	0.17	29.2	✓	
113				0.11		500	500	500	✓	0.22	29.2	✓	
211				0.13		500	500	500	✓	0.19	29.2	✓	
212				0.13		500	500	500	✓	0.20	29.2	✓	
213				0.12		500	500	500	✓	0.16	29.2	✓	
3tp													
4tp													
511				0.08		500	500	500	✓	0.20	29.2	✓	
512				0.04		500	500	500	✓	0.11	29.6	✓	
513				0.10		500	500	500	✓	0.21	29.2	✓	
611				0.10		500	500	500	✓	0.19	29.2	✓	
612				0.09		500	500	500	✓	0.18	30	✓	
613				0.14		500	500	500	✓	0.29	30.4	✓	
711				0.10		500	500	500	✓	0.21	29.2	✓	
712				0.11		500	500	500	✓	0.20	29.2	✓	
713				0.13		500	500	500	✓	0.24	29.2	✓	
811				0.14		500	500	500	✓	0.24	30.2	✓	

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

 TESTED BY Name (capitals): IAN TANNER Position: electrician Signature:  Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

 * RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): LS&F
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	---------------------

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

@ Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (X) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitals): IAN TANNER Position: electrician Signature: *IST* Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function:
A112321

Continuity:
N/A

Insulation resistance:
N/A

Earth fault loop impedance:
N/A

Earth electrode resistance:
N/A

RCD:
N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{Ap})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state): LS&F

This certificate is based on the model forms shown in Appendix 6 of *BS 7671: 2018+A2:2022*
© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z_s^* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I_{dn} (mA)
111	Male heaters	O	LIM	2	4	1.5	0.4	61009	C	20	10	1.09	61009	A	20	30
112	Male entrance heaters/power	O	LIM	3	4	1.5	0.4	61009	C	20	10	1.09	61009	A	20	30
113	Adult shower ring male	O	LIM	4	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
211	Male heaters	O	LIM	2	4	1.5	0.4	61009	C	20	10	1.09	61009	A	20	30
212	Female entrance heater/power	O	LIM	2	4	1.5	0.4	61009	C	20	10	1.09	61009	A	20	30
213	Adult entrance heater/power ring	O	LIM	2	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
311	hand driers plus extractor, males	O	LIM	3	4	1.5	0.4	61009	C	20	10	1.09	61009	A	20	30
312	Female heaters	O	LIM	3	4	1.5	0.4	61009	C	20	10	1.09	61009	A	20	30
313	Adult heater ring female	O	LIM	3	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
411	immersion bottom	O	B	1	4	1.5	0.4	61009	C	20	10	1.09				
412	immersion top	O	B	1	4	1.5	0.4	60898	C	20	10	1.09				
413	spare															
511	Cold water pump, heater, power	O	B	3	4	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
512	Female shower ring	O	LIM	3	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
513	Disabled toilet ring	O	LIM	4	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
6tp	metering via 1 amp fuses, not tested															

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB POWER

Location of DB: Adjacent mains intake

Z_{db} : 0.1.....(Ω) I_{pr} at DB: 2.4.....(kA)

Confirmation of supply polarity: (N/A)..... Phase sequence confirmed: (N/A).....

SPD Details** Types: T1 (N/A)..... T2 (N/A)..... T3 (N/A)..... N/A (N/A).....

Status indicator checked (where functionality indicator is present): (N/A).....

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: MCP 1 - 11tp

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2)..... Type: (MCCB)..... Nominal voltage: (400)..... V Rating: (100)..... A No. of phases: (3).....

Associated RCD (if any)

BS (EN): (N/A)..... RCD Type: (N/A)..... I_{dn} : (.....) mA No. of poles: (N/A)..... Operating time: (N/A)..... ms

Circuit number	Continuity (Ω)					Insulation resistance			Polarity	Max measured earth fault loop impedance, Z_S	RCD		AFDD**	Comments and additional information, where required				
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (M Ω)	Live / Earth (M Ω)	Test voltage DC (V)			(ms)	(✓)						
	(Line) r_1	(Neutral) r_n	(cpc) r_2	($R_1 + R_2$)	R_2													
111				0.26		38	500	✓	0.29	39.2	✓							
112				0.18		200	500	✓	0.24	29.6	✓							
113	0.24	0.24	0.52	0.17		200	500	✓	0.22	28.8	✓							
211				0.15		200	500	✓	0.19	30.8	✓							
212				0.12		200	500	✓	0.23	29.6	✓							
213	0.26	0.26	0.37	0.15		200	500	✓	0.21	29.2	✓							
311				0.26		200	500	✓	0.37	29.2	✓							
312				0.31		86	500	✓	0.42	29.1	✓							
313	0.24	0.24	0.36	0.15		200	500	✓	0.24	29.2	✓							
411				0.12	500	500	500	✓	0.20									
412				0.09	500	500	500	✓	0.18									
413																		
511				0.24	500	500	500	✓	0.32	28.8	✓							
512	0.37	0.39	0.57	0.24		200	500	✓	0.34	24.2	✓							
513	0.42	0.42	0.68	0.26		200	500	✓	0.35	28.2	✓							
6tp																		

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitals): IAN TANNER Position: electrician Signature: *IST* Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op}).

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state): LS&F

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z_s^* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I_{dn} (mA)
1	meter															
2	male shower lights	A	E	12	1.5	1	0.4	61009	C	10	10	2.19	61009	A	10	30
3	male toilet lights	A	E	14	1.5	1	0.4	61009	C	10	10	2.19	61009	A	10	30
4	adult shower lights	A	E	15	1.5	1	0.4	61009	C	10	10	2.19	61009	A	10	30
5	adult toilet lights	A	E	14	1.5	1	0.4	61009	C	10	10	2.19	61009	A	10	30
6	female toilet lights	A	E	17	1.5	1	0.4	61009	C	10	10	2.19	61009	A	10	30
7	female shower lights	A	E	17	1.5	1	0.4	61009	C	10	10	2.19	61009	A	10	30
8	plant room lights	A	E	6	1.5	1	0.4	61009	C	10	10	2.19	61009	A	10	30
9	spare															
10	spare															
11	spare															
12	spare															
13	spare															
14	spare															
15	spare															
16	spare															

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB LTG

Location of DB: Adjacent incoming mains

Z_{db} 0.1 (0) I_{pr} at DB 2.4 (kA)

Confirmation of supply polarity: () Phase sequence confirmed: (N/A)

SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: MCP 1 - 9I1

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2) Type: (MCCB) Nominal voltage: (230) V Rating: (60) A No. of phases: (1)

Associated RCD (if any)

BS (EN): (N/A) RCD Type: (N/A) I_{dn} : (.....) mA No. of poles: (N/A) Operating time: (N/A) ms

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Zs	RCD		AFDD**	Comments and additional information, where required	
	Ring final circuits only (measured end to end)		All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC		(✓)	(Ω)	(ms)		
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂	(MΩ)	(MΩ)	(V)					
1													
2			0.59		lim	220	500		✓	0.72	34	✓	
3			0.56		lim	500	500		✓	0.66	32.8	✓	
4			0.33		lim	500	500		✓	0.76	29.2	✓	
5			0.27		lim	500	500		✓	0.53	29.2	✓	
6			0.60		lim	500	500		✓	0.59	30.8	✓	
7			0.62		lim	500	500		✓	0.68	29.2	✓	
8			0.36		lim	500	500		✓	0.46	29.2	✓	
9													
10													
11													
12													
13													
14													
15													
16													

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

 TESTED BY Name (capitals): RICHARD STOCK Position: Electrician Signature:  Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

 * RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

@ Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (X) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z_s^* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I_{dn} (mA)
1	lights south	A	B	15	1.5	1	0.4	60898	B	6	6	7.28	4293	AC		30
2	lights center	A	B	13	1.5	1	0.4	60898	B	6	6	7.28	4293	AC		30
3	lights north	A	B	9	1.5	1	0.4	60898	B	6	6	7.28	4293	AC		30
4	Not used												4293	AC		30
5	Water heater	A	B	1	2.5	1.5	0.4	60898	B	16	6	2.73	4293	AC		30
6	sockets north	A	LIM	10	2.5	1.5	0.4	60898	B	32	6	1.37	4293	AC		30
7	disabled water heater	A	B	1	2.5	1.5	0.4	60898	C	20	6	1.09	4293	AC		30
8	disabled alarm for wc	A	B	1	2.5	1.5	0.4	60898	B	10	6	4.37	4293	AC		30
9	sockets south	A	LIM	12	2.5	1.5	0.4	60898	B	32	6	1.37	4293	AC		30
10	spare															
11	Heater time clock/stat..not tested	A	N/A	2	1	1	0.4	60898	B	6	6	7.28	4293	AC		30
12	sockets center	A	LIM	4	2.5	1.5	0.4	60898	B	32	6	1.37	4293	AC		30
13	heaters	A	LIM	2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC		30
14	heaters	A	LIM	2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC		30
15	heaters	A	LIM	2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC		30
16	disabled door opener	A	B	1	2.5	1.5	0.4	60898	B	16	6	2.73	4293	AC		30
17	heaters	A	LIM	2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC		30
18	heaters	A	LIM	2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC		30

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB AB2C

Location of DB: Accommodation hut 2

Z_{db} 0.26 (0)

I_{pr} at DB N/A (kA)

Confirmation of supply polarity: () Phase sequence confirmed: (N/A)

SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: MCP 1 - 1tp

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2) Type: (MCCB) Nominal voltage: (400) V Rating: (100) A No. of phases: (3)

Associated RCD (if any)

BS (EN): (4293) RCD Type: (AC) I_{dn} : (30) mA No. of poles: (4) Operating time: (27) ms


CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Zs	RCD		AFDD**	Comments and additional information, where required	
	Ring final circuits only (measured end to end)		All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)		(Ω)	Operating time*	Test button		
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂					(ms)	(✓)		
1				1.48		lim	0.04	500	✓	1.77	27		
2				1.40		lim	200	500	✓	1.77	27		
3				0.77		lim	200	500	✓	1.02	27		
4													
5				0.18		200	200	500	✓	0.38	27		
6	0.69	0.70	1.15	0.39		200	200	500	✓	0.60	27		
7				0.35		200	200	500	✓	0.64	27		
8				0.36		200	200	500	✓	0.66	27		
9	0.62	0.59	1.02	0.41		200	200	500	✓	0.74	27		
10													
11										27			
12	0.27	0.26	0.53	0.19		200	200	500	✓	0.49	27		
13				0.19		200	200	500	✓	0.49	27		
14				0.37		200	200	500	✓	0.71	27		
15				0.26		200	200	500	✓	0.50	27		
16				0.58		200	200	500	✓	0.88	27		
17				0.44		200	200	500	✓	0.72	27		
18				0.44		200	200	500	✓	0.78	27		

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

 TESTED BY Name (capitals): IAN TANNER Position: electrician Signature:  Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

 * RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

@ Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (X) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitals): IAN TANNER Position: electrician Signature: *IST* Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function:
A112321

Continuity
N/A

Insulation resistance:
N/A

Earth fault loop impedance:
N/A

Earth electrode resistance:
N/A

RCD:
N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state): N/A

This certificate is based on the model forms shown in Appendix 6 of *BS 7671: 2018+A2:2022*
© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z_s^* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I_{dn} (mA)
1	lights south	A	B	14	1.5	1	0.4	60898	C	6	6	3.64	4293	AC	63	30
2	lights north	A	B	12	1.5	1	0.4	60898	C	6	6	3.64	4293	AC	63	30
3	spare															
4	time clock supply	A	B	1	1	1	0.4	60898	C	6	6	3.64	4293	AC	63	30
5	water heater wc	A	B	1	2.5	1.5	0.4	60898	B	16	6	2.73	4293	AC	16	30
6	Water heater kitchen	A	B	1	2.5	1.5	0.4	60898	B	16	6	2.73	4293	AC	63	30
7	sockets south	A	B	13	2.5	1.5	0.4	60898	B	32	6	1.37	4293	AC	63	30
8	spare															
9	spare															
10	sockets north	A	B	10	2.5	1.5	0.4	60898	B	32	6	1.37	4293	AC	63	30
11	spare															
12	spare															
13	heaters south	A	B	2	2.5	1.5	0.4	60898	C	20	6	1.09	4293	AC	63	30
14	heaters south	A	B	2	2.5	1.5	0.4	60898	C	20	6	1.09	4293	AC	63	30
15	heaters center	A	B	2	2.5	1.5	0.4	60898	C	20	6	1.09	4293	AC	63	30
16	heaters north	A	B	2	2.5	1.5	0.4	60898	C	20	6	1.09	4293	AC	63	30
17	heaters mess	A	B	2	2.5	1.5	0.4	60898	C	20	6	1.09	4293	AC	63	30
18	space heater below	A	B	1	2.5	1.5	0.4	60898	C	16	6	1.37	4293	AC	63	30

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB AB3N

Location of DB: Accommodation block 3

Z_{db} 0.3 (Ω)

I_{pr} at DB N/A (kA)

Confirmation of supply polarity: () Phase sequence confirmed: (N/A)

SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: MCP 1 - 3tp

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2) Type: (MCCB) Nominal voltage: (400) V Rating: (100) A No. of phases: (3)

Associated RCD (if any)

BS (EN): (N/A) RCD Type: (N/A) I_{dn} : (.....) mA No. of poles: (N/A) Operating time: (N/A) ms

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Zs (Ω)	RCD		AFDD** AFDD test button	Comments and additional information, where required				
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)					(✓)	(ms)						
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂											
1				0.77		45	45	500	✓	1.17	22	✓				
2				0.74		45	45	500	✓	1.14	22	✓				
3																
4				0.01		45	45	500	✓	0.31	22	✓				
5				0.18		45	45	500	✓	0.48	22	✓				
6				0.14		45	45	500	✓	0.44	22	✓				
7	0.65	0.65	1.13		0.37	45	45	500	✓	0.67	22	✓				
8																
9																
10	0.64	0.65	1.14	0.29		45	45	500	✓	0.59	22	✓				
11																
12																
13				0.19		45	45	500	✓	0.49	22	✓				
14				0.22		45	45	500	✓	0.52	22	✓				
15				0.17		45	45	500	✓	0.47	22	✓				
16				0.29		45	45	500	✓	0.59	22	✓				
17				0.30		45	45	500	✓	0.60	22	✓				
18				0.16		45	45	500	✓	0.46	22	✓				

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

 TESTED BY Name (capitals): RICHARD STOCK Position: Electrician Signature:  Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

 * RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): fp200
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	----------------------

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

@ Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (X) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitals): RICHARD STOCK Position: Electrician Signature: Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state): **fp200**

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Zs	RCD		AFDD**	Comments and additional information, where required	
	Ring final circuits only (measured end to end)		All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)		(Ω)	Operating time*	Test button		
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂					(ms)	(✓)		
1				0.71		80	80	500	✓	1.14	29.8	✓	
2				0.77		200	80	500	✓	1.59	28.8	✓	high Zs reading on one socket. requires investigation
3				0.49		200	200	500	✓	0.89	28.8	✓	
4				0.19		200	200	500	✓	0.69	28.8	✓	
5				0.30		200	200	500	✓	0.82	28.2	✓	
6				0.19		200	200	500	✓	0.63	28.8	✓	
7				1.99	lim	80	250	✓	2.55	28.8	✓		

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitals): IAN TANNER Position: electrician Signature: *IST* Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function:
A112321

Continuity:
N/A

Insulation resistance:
N/A

Earth fault loop impedance:
N/A

Earth electrode resistance:
N/A

RCD:
N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state): fp200

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Zs [*] (Ω)	BS (EN)	Type	Rating (A)	Operating current, I _{Δn} (mA)
1	lights south	A		10	1.5	1	0.4	60898	B	6	6	7.28	4293	AC	63	30
2	lights center	A		9	1.5	1	0.4	60898	B	6	6	7.28	4293	AC	63	30
3	lights north	A		10	2.5	1.5	0.4	60898	B	6	6	7.28	4293	AC	63	30
4	sockets center	A		4	2.5	1.5	0.4	60898	B	32	6	1.37	4293	AC	63	30
5	heater time clock	A		1	1	1	0.4	60898	B	6	6	7.28	4293	AC	63	30
6	water heater	A		1	2.5	1.5	0.4	60898	B	16	6	2.73	4293	AC	63	30
7	sockets south	A		12	2.5	1.5	0.4	60898	B	32	6	1.37	4293	AC	63	30
8	spare															
9	spare															
10	sockets north	A		12	2.5	1.5	0.4	60898	B	32	6	1.37	4293	AC	63	30
11	trooping shed 1	F		1	6	2.5	0.4	60898	B	32	6	1.37	4293	AC	63	30
12	trooping shed 2	F		1	6	2.5	0.4	60898	B	32	9	1.37	4293	AC	63	30
13	heaters	A		2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC	63	30
14	heaters	A		2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC	63	30
15	heaters	A		2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC	63	30
16	heaters	A		2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC	63	30
17	spare															
18	heaters	A		2	2.5	1.5	0.4	60898	B	20	6	2.19	4293	AC	63	30

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB AB1S

Location of DB: accommodation block 1

Z_{db} 0.59 (Ω)

I_{pr} at DB: N/A (kA)

Confirmation of supply polarity: () Phase sequence confirmed: (N/A)

SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: MCP 1 - 10tp

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2) Type: (MCCB) Nominal voltage: (400) V Rating: (100) A No. of phases: (3)

Associated RCD (if any)

BS (EN): (N/A) RCD Type: (N/A) $I_{Δn}$: (.....) mA No. of poles: (N/A) Operating time: (N/A) ms

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)				Insulation resistance			Polarity	Max. measured earth fault loop impedance, Zs	RCD		AFDD**	Comments and additional information, where required		
	Ring final circuits only (measured end to end)		All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)			Operating time*	Test button				
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂					(ms)	(✓)				
1				0.76		59	60	500	✓	1.35	11.1	✓			
2				0.72		59	60	500	✓	1.31	11.1	✓			
3				0.90		59	60	500	✓	1.49	11.1	✓			
4	0.41	0.41	0.66	0.20		59	60	500	✓	0.79	11.1	✓			
5				0.02		59	60	500	✓	0.61	11.1	✓			
6				0.10		59	60	500	✓	0.69	11.1	✓			
7	0.69	0.68	1.10	0.45		59	60	500	✓	0.96	11.1	✓			
8															
9															
10	0.75	0.75	1.43	0.41		59	60	500	✓	1.01	11.1	✓			
11				0.09		59	60	500	✓	0.68	11.1	✓			
12				0.23		59	60	500	✓	0.72	11.1	✓			
13				0.40		59	60	500	✓	0.99	11.1	✓			
14				0.43		59	60	500	✓	1.03	11.1	✓			
15				0.38		59	60	500	✓	0.97	11.1	✓			
16				0.41		59	60	500	✓	1	11.1	✓			
17															
18				0.50		59	60	500	✓	1.09	11.1	✓			

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

 TESTED BY Name (capitals): RICHARD STOCK Position: Electrician Signature:  Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

 * RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

@ Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (X) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuit number	Continuity (Ω)				Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z_s	RCD		AFDD**	Comments and additional information, where required		
	Ring final circuits only (measured end to end)				All circuits (complete at least one column)					Live / Live (M Ω)	Live / Earth (M Ω)	Test voltage DC (V)			
	(Line) r_1	(Neutral) r_n	(cpc) r_2		$(R_1 + R_2)$	R_2									
19				0.02		59	60	500	✓	0.61	11.1	✓			
20															
21															
22															
23															
24				1.2		59	60	500	✓	1.79	11.1	✓			

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitalise): RICHARD STOCK Position: Electrician Signature: Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op}).

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state): N/A

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitalise): RICHARD STOCK Position: Electrician Signature: Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state): N/A

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitalise): RICHARD STOCK Position: Electrician Signature: Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op}).

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Mineral-insulated / sheathed cables (B) Mineral-insulated cables in metallic conduit (C) Mineral-insulated cables in non-metallic conduit (D) Mineral-insulated cables in metallic trunking (E) Mineral-insulated cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state) N/A

This certificate is based on the model for

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitalise): RICHARD STOCK Position: Electrician Signature: Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op}).

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A)	Thermoplastic insulated / sheathed cables	(B)	Thermoplastic cables in metallic conduit	(C)	Thermoplastic cables in non-metallic conduit	(D)	Thermoplastic cables in metallic trunking	(E)	Thermoplastic cables in non-metallic trunking	(F)	Thermoplastic / SWA cables	(G)	Thermosetting / SWA cables	(H)	Mineral-insulated cables	Other (state) N/A
---------------------------------	------------	---	------------	--	------------	--	------------	---	------------	---	------------	----------------------------	------------	----------------------------	------------	--------------------------	--------------------------------

This certificate is based on the model for

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z_s^* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I_{dn} (mA)
1tp	dishwasher	C		1	2.5	2.5	0.4	60898	C	16	10	1.37	4293	AC	100	100
211	still boiler	A		1	2.5	1.5	0.4	61009	C	16	10	1.37	61009	AC	16	30
212	dining room heaters	A		2	2.5	1.5	0.4	61009	C	16	10	1.37	61009	AC	16	30
213	canopy extract fan	A		1	2.5	1.5	0.4	61009	C	16	10	1.37	61009	AC	16	30
311	dining room heaters	A		2	2.5	1.5	0.4	61009	C	16	10	1.37	61009	AC	16	30
312	spare															
313	serving hatch socket	A		1	6	1.5	0.4	61009	C	32	10	0.68	61009	AC	32	30
411	ring pantry sockets	A		2	2.5	1.5	0.4	61009	C	32	10	0.68	61009	AC	32	30
412	kitchen ring	A		3	2.5	1.5	0.4	61009	C	32	10	0.68	61009	AC	32	30
413	dining room ring	A		10	2.5	1.5	0.4	61009	C	32	10	0.68	61009	AC	32	30
511	Potato pealer	A		1	6	2.5	0.4	61009	C	32	10	0.68	61009	AC	32	30
512	spare															
513	spare															
6tp	spare															
7tp	spare															
8tp	fryer	F		1	10	Sheath	0.4	60898	C	63	10	0.35	61008	AC	100	100
911	double socket under canopy	F		1	6	6	0.4	61009	C	32	10	0.68	61009	AC	32	30
912	dining room lights and fans	A		16	1.5	1	0.4	61009	C	10	10	2.19	61009	AC	10	30

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB 6 KITCHEN

Location of DB: KITCHEN BUILDING

 $Z_{db} = 0.17$ (Ω)

 I_{pr} at DB = 1.3 (kA)

 Confirmation of supply polarity: () Phase sequence confirmed: ()

SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: MCP 1 - 4tp

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2) Type: (MCCB) Nominal voltage: (400) V Rating: (160) A No. of phases: (3)

Associated RCD (if any)

 BS (EN): (N/A) RCD Type: (N/A) I_{dn} : (.....) mA No. of poles: (N/A) Operating time: (N/A) ms

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Zs	RCD		AFDD**	Comments and additional information, where required			
	Ring final circuits only (measured end to end)		All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)		(✓)	Operating time* (ms)					
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂										
1tp				lim		140	96	500	LIM	lim	10.3	✓	isolator not accessible for testing		
211				0.12		500	500	500	✓	0.39	28.5	✓			
212				0.31		99	99	500	✓	0.48	28.8	✓			
213				0.38		120	120	500	✓	0.55	28.7	✓			
311				0.35		100	100	500	✓	0.51	28.6	✓			
312															
313				0.08		500	500	500	✓	0.25	88.6	✓			
411	0.26	0.26	0.39	0.13		89	67	500	✓	0.40	28.5	✓			
412	0.52	0.52	0.80	0.20		200	220	500	✓	0.37	28.4	✓			
413	0.97	0.97	1.41	0.43		140	140	500	✓	0.60	28.3	✓			
511				0.7		400	400	500	✓	0.24	88.7	✗			
512															
513															
6tp															
7tp															
8tp				0.08		500	500	1000	✓	0.25	10.3	✓			
911				0.06		200	200	500	✓	0.23	28.7	✓			
912				0.59		120	120	500	✓	0.76	28.8	✓			

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitals): RICHARD STOCK

Position: Electrician

 Signature: 

Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function:

A112321

Continuity:

N/A

Insulation resistance:

N/A

Earth fault loop impedance:

N/A

Earth electrode resistance:

N/A

RCD:

N/A

 * RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

@ Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuit number	Continuity (Ω)				Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z_{S3}	RCD		AFDD**	Comments and additional information, where required			
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (M Ω)	Live / Earth (M Ω)	Test voltage DC (V)		Operating time* (ms)	Test button (✓)					
	(Line) r_1	(Neutral) r_n	(cpc) r_2	($R_1 + R_2$)	R_2											
913				0.65		100	100	500	✓	0.82	28.6	✓				
1011				0.72		150	150	500	✓	0.89	28.4	✓				
1012				0.23		40	40	500	✓	0.40	28.6	✓				
1013				0.80		90	90	500	✓	0.97	28.7	✓				
1111				0.12		200	200	500	✓	0.29	28.6	✓				
1112				0.16		100	100	500	✓	0.33	88.7	✓				
1113				0.32		400	400	500	✓	0.49	28.7	✓				
1211				0.12		200	200	500	✓	0.29	28.7					
1212				0.05		300	300	500	✓	0.22	28.7	✓				
1213				0.14		200	200	500	✓	0.31	28.6	✓				
1311				0.07		200	200	500	✓	0.24	28.7	✓				
1312				0.14		500	500	500	✓	0.31	28.7	✓				
1313				0.08		500	500	500	✓	0.25	28.6	✓				
14tp				0.16		500	500	500	✓	0.33	10.3	✓				
15tp				0.08		500	500	500	✓	0.25	10.3	✓				
16tp				0.08		500	500	500	✓	0.25	10.3	✓				

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitals): RICHARD STOCK Position: Electrician Signature: Date: 27/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op}).

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Mineral-insulated / sheathed cables (B) Mineral-insulated cables in metallic conduit (C) Mineral-insulated cables in non-metallic conduit (D) Mineral-insulated cables in metallic trunking (E) Mineral-insulated cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state) N/A

This certificate is based on the model forms shown in Appendix 6 of *BS 7671: 2018+A2:2022*
© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter **(✓)**, **(✗)** or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capitals): IAN TANNER Position: electrician Signature: *ISTT* Date: 29/02/2024

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function: A112321	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
----------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{op}).

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables Other (state) tuff flex

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018+A2:2022

© Copyright Certsure LLP (March 2022)

For an EIC, enter a (✓) or value in the respective fields, as appropriate.

For an EICR, enter (✓), (✗) or value in the respective fields, as appropriate

Where an item is not applicable insert N/A

NOTES FOR RECIPIENT

THIS CONDITION REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service. This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected and tested, taking into account the stated extent of the installation and the limitations of the inspection and testing.

This report has been issued in accordance with the national standard for the safety of electrical installations, *BS 7671: 2018+A2:2022 – Requirements for Electrical Installations*.

The report identifies any damage, deterioration, defects and/or conditions found by the inspector which may give rise to danger (see PART 5), together with any items for which improvement is recommended.

You should have received the report marked 'Original' and the contractor should retain a duplicate. If you were the person ordering this report, but not the owner or user of the installation, you should pass this report, or a full copy of it, including these notes, the schedules and additional pages (if any), immediately to the owner or user of the installation.

This report should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. NICEIC* recommends that you engage the services of an NICEIC contractor for the inspection. Only an NICEIC contractor is authorised to issue this NICEIC Electrical Installation Condition Report, which has a unique serial number that is traceable to the contractor to which it was supplied by NICEIC.

The recommended date by which the next inspection should be carried out is stated in PART 4 of this report. With the exception of domestic (household) premises, there should also be a notice at or near the main switchboard or distribution board/consumer unit indicating when the next inspection of the installation is due.

This report is intended to be issued only for the purpose of reporting on the condition of an existing electrical installation and must not be issued to certify new electrical installation work including the replacement of a distribution board or consumer unit.

The report consists of at least eight numbered pages. The report is only valid if the Schedule of Items Inspected (PART 9) has been completed to confirm that all relevant inspections have been carried out and the Schedule of Circuit Details (PART 11A) and the Schedule of Test Results (PART 11B) are attached. For installations having more than one distribution board (or consumer unit) or more circuits than can be recorded in PARTS 11A & 11B, one or more additional Schedule of Circuit Details and Schedule of Test Results, should form part of the report. Additional numbered pages may have been provided to permit further relevant information relating to the installation to be recorded. The report is invalid if any of the additional pages, listed in PART 10 are missing.

Where the installation includes a residual current device (RCD) it should be tested every six months by pressing the button marked "T" or "Test". The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions should be followed with respect to test button operation.

Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice.

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, this should be identified in PART 7 Supply Characteristics and Earthing Arrangements, and the Schedules of Circuit Details and Test Results (PART 11A & 11B) compiled accordingly.

PART 6 (Details and limitations) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in PART 6. It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration should have been given by the inspector in PART 4 of the report. The declaration must reflect the statement given in PART 3, which summarises the observations and recommendations made in PART 5. Where one or more observations have been made in PART 5, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation as code C1 (danger present) the safety of those using the installation is at risk. Wherever practicable, items classified as C1 should be made safe on discovery, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation as code C2 (potentially dangerous) the safety of those using the installation may be at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated that an item requires further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where inadequacies in the intake equipment have been observed (Item 1 of PART 9), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

For further information about electrical safety and how NICEIC can help you, visit:
www.niceic.com

* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

GUIDANCE FOR RECIPIENTS ON THE CLASSIFICATION CODES

ONLY ONE CLASSIFICATION CODE SHOULD BE GIVEN FOR EACH RECORDED OBSERVATION

Classification code C1 (Danger present)

Where an observation has been given a Classification code C1, the safety of those using the installation is at risk and immediate remedial action is required.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the danger. The NICEIC contractor issuing this report will be able to provide further advice.

NICEIC makes available 'Electrical Danger Notification' forms to enable inspectors to record, and then to communicate to the person ordering the report, any dangerous condition discovered.

Classification code C2 (Potentially dangerous)

Classification code C2 indicates that, whilst those using the installation may not be at immediate risk, urgent remedial action is required to remove potential danger. The NICEIC contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given for the next inspection date in PART 4 of this report is conditional upon all items which have been given a Classification code C1 and code C2 being remedied immediately and as a matter of urgency, respectively.

It would not be reasonable for the inspector to indicate that the installation is in a satisfactory condition if any observation in this report has been given a code C1 or code C2 classification.

Classification code C3 (Improvement recommended)

Where an observation has been given a Classification code C3, the inspection and/or testing has revealed a non-compliance with the current safety standard which, whilst not presenting immediate or potential danger, would result in a significant safety improvement if remedied. Careful consideration should be given to the safety benefits of improving these aspects of the installation. The NICEIC contractor issuing this report will be able to provide further advice.

Code FI (Further investigation required without delay)

It should usually be possible for the inspector to attribute a Classification code to each observation without indicating a need for further investigation.

However, where 'FI' has been entered against an observation the inspector considers that further investigation of that observation is likely to reveal danger or potential danger that, due to the agreed extent or limitations of the inspection and/or testing (entered in PART 6), could not be fully identified at the time.

It would not be appropriate for the inspector to indicate that the installation is in a satisfactory condition if there is reasonable doubt as to whether danger or potential danger exists. Consequently, where the inspector has indicated 'Further investigation required without delay' (FI) the overall assessment of the installation (PART 3) should be marked as 'Unsatisfactory'.

If the inspector has indicated that an observation requires further investigation without delay, the person ordering this report is advised to arrange for the NICEIC contractor issuing the report (or another skilled person or persons competent in such work) to undertake further examination of that aspect of the installation as a matter of urgency, to determine whether or not danger or potential danger exists.

Further information

Further information on the application of Classification codes, primarily aimed at inspectors but of possible interest to persons ordering condition reports, can be found in Electrical Safety First's Best Practice Guide No 4 *Electrical installation condition reporting: Classification Codes for domestic and similar electrical installations*. The guide can be viewed or downloaded free of charge from www.electricalsafetyfirst.org.uk

For further information about electrical safety and how NICEIC can help you, visit

www.niceic.com