



Defence Infrastructure Organisation

Gas Safety Management Plan (Section B)

Trowbridge JCC ACF ATC

25/02/2025

**Produced to meet the requirements of the Gas Safety
(Management) Regulations 1996**

**(Gas Safety Management Plan (Section B) covers the requirements of the
Gas Safety (Management) Regulations 1996**

ESTABLISHMENT KEY PERSONALITIES (GAS) CONTACTS

Role	Name	Tel No.	Email
Head of Establishment	Neville Holmes MBE	01823 217930 07850 655017	wx-ce@rfca.mod.uk
Establishment's SHEF	Joey Clough	07850 024704	wx-wil-cqm@rfca.org.uk
Establishments 4C's Coordinator	Steven Davies	07775 675268	wx-wil-ccoy@rfca.org.uk
Senior DIO Estate Representative or Equivalent	Mark Cubitt	01823 217949 07955 280440	wx-est-hd@rfca.mod.uk
Site DIO Estate Representative or Equivalent	Rory Simpson	07957 436139 01823 217941	wx-est-mgr1@rfca.mod.uk
MMO Site Manager or equivalent	Paul Wakeford	07356 101565	paul.wakeford@vivodefence.com
Gas Safety Manager (GSM)	Justin Westcott	07793 222820	justin.westcott@VIVOdefence.com
Gas Responsible Person (GRP)	Ian Bradley	07793 222771	ian.bradley1@VIVOdefence.com

The Content of this Gas Safety Management Plan (GSMP) have been Approved by the Gas Safety Manager:

Signature: *JP Westcott*

Date: 25/02/2025

Authorisation for Implementation

The content and format of this GSMP has been agreed and authorised for implementation by Defence Infrastructure Organisation Technical Services Principal Gas Engineer (DIO TS PGE) and a unique reference number has been generated to support this.

Approved – J Obbard PGE –05/12/2023

The Content of this GSMP have been agreed by the Senior DIO Estate Representative or Equivalent and future works following the findings will be supported:

Signature:

M Cubitt

Date: 09/05/2025

The content of this GSMP have been agreed by the Head of Establishment and future works following the findings will be supported

Signature:

N Holmes

Date: 09/05/2025

Reviews and Amendments

GSMPs are 'living documents' that should be subject to continual review and updating as required. Although the level of attention required will vary considerably depending on the size and complexity of each site, GSMPs should be reviewed at least once per quarter by the GRP. Although it is likely that changes are not required at each review, the date of review and any changes made should be indicated on the tables below. The review of the GSMP will include a site visit to ensure that the site and the content of the GSMP remain valid. The reviews and amendments made will be deleted during the DIO TS three yearly review when the GSMP is re-authorised by the PGE.

Date	Page No.	Amendment
28/02/2022	All	Initial Development
28/05/2022	3	Updated Gas Emergency Helpdesk details
28/05/2022	4	Updated gas supplier details.
27/07/2022	N/A	No update required (awaiting HoE details)
28/10/2022	N/A	No update required (awaiting HoE details)
26/01/2023	N/A	No update required (awaiting HoE details)
26/04/2023	N/A	No update required (awaiting HoE details)
26/07/2023	N/A	No update required (awaiting HoE details)
01/11/2023	ii, 1	HoE details updated in line with other Wiltshire ACF sites
26/01/2024	N/A	No update required
26/04/2024	ii & 1	Updated Key Personnel details
20/06/2024	4	2.2 Updated to reflect changes to ECV relocation
07/10/2024	ii & 2	Updated Senior DIO Estate Representative details
07/10/2024	ii	Updated Site DIO Estate Representative details
18/10/2024		GSM re-authorisation (previously authorised 01/11/2023)
10/01/2025	N/A	No update or amendment required
25/02/2025	Various	Update due to VIVO taking over Gas Management Contract, Changes in RP & GSM – Emergency details

Date	Reviewed by	Authorised by	Comments
28/02/2022	D Cooper	N King	Initial Review
28/05/2022	D Cooper		Q1 review
27/07/2022	D. Cooper		Q2 review
28/10/2022	D. Cooper		Q3 review
26/01/2023	D. Cooper		Annual review
26/04/2023	D. Cooper		Q1 review
26/07/2023	D. Cooper		Q2 review
01/11/2023	D. Cooper	N King	Q3 review
26/01/2024	D. Cooper		Annual review site visit
26/04/2024	D. Cooper		Q1 review
20/06/2024	D. Cooper		Site Visit
07/10/2024	D. Cooper		Review
18/10/2024	Neville King	Neville King	GSM re-authorisation
10/01/2025	D. Cooper		DNV demobilisation review
25/02/2025	Ian Bradley	J Westcott	Initial review after site visit
25/02/2025	J Westcott	J Westcott	Initial review/approval Noting Network PPM to be undertaken by VIVO with a view to de classification subject to adequate PPM measures.

FORWARD

MOD, as a gas conveyor within Great Britain, has submitted an Exemplar Gas Safety Case (MOD GSC) to demonstrate compliance with the Gas Safety (Management) Regulations 1996 (GSMR). Maintenance Management Organisations (MMO's) are engaged who have the overall contractual responsibility to operate and maintain the gas network assets under their Contract, including the management of the safe flow of gas within the system and the provision of an emergency service. The MOD delegate specific duties to the MMO but accountability for gas safety on each site rests with the Head of Establishment.

The MOD GSC considers all parts of the MOD estates gas supply system that forms part of the gas supply network. This includes all parts of the MOD estates network from the External Gas Distribution Network (EGDN) connection point to the emergency control valve (ECV) of individual consumers. The MOD GSC considers primarily those matters that relate to the management of the safe flow of gas within the system and the provision of an emergency service.

The conclusions of the assessments within the MOD GSC are:

- There is an adequate safety management system in place to manage the flow of gas safely in its gas supply system.
- Adequate arrangements are in place to comply with the requirements of GSMR and allow co-operation with other bodies that have duties under the regulations.
- Adequate arrangements are in place for ensuring that gas conveyed within the system meets the standards for composition and pressure.
- Adequate arrangements are in place for dealing with reports of gas escapes and investigation of incidents.
- Adequate arrangements have been made to ensure that the risk of a supply failure is minimised.
- Adequate arrangements have been made to ensure that supply emergencies are managed safely.

The MOD GSC is a generic document that outlines the gas safety systems and processes in place for gas networks within the MOD estate. Site-specific details and arrangements are contained within this establishment Gas Safety Management Plan (Section B) (GSMP). As a site-specific component of the MOD GSC, this GSMP has the same legal standing under GSMR.

The layout and structure of this GSMP mirrors that of its parent GSC

Following initial approval by the DIO PGE, the GSM is required to reapprove this GSMP annually. GSMP must be submitted to DIO TS every three years for PGE authorisation.

The HoE and Senior DIO Estate Representative or Equivalent would only be required to re-sign this GSMP annually following the GSM reapproval, unless significant changes to the gas system or a change in one of these key personalities occurs.

GSMP Section A documents detail MOD measures to ensure compliance with the Gas Safety (Installation and Use) Regulations 1998 (GSIUR) for installation pipework (downstream of Emergency Control Valves) Although the legal status of this document applies in the UK only, the MOD apply the same requirements to the management of natural gas networks on its overseas estate in accordance with the currently published Secretary of State's Health and Safety policy statement.

Contents

ESTABLISHMENT KEY PERSONALITIES (GAS) CONTACTS	II
FORWARD.....	V
1 THE DUTY HOLDER AND ESTABLISHMENT LEVEL KEY PERSONALITIES.....	1
1.1. GAS SAFETY CASE DUTY HOLDER.....	1
1.2. DIO TECHNICAL SERVICES PRINCIPAL GAS ENGINEER (PGE).....	1
1.3. ESTABLISHMENT PERSONALITIES.....	1
1.4. MAINTENANCE MANAGEMENT ORGANISATION (MMO).....	3
1.5. ADDITIONAL GAS CONTACTS.	4
2 OPERATION UNDERTAKEN	5
2.1 SITE OVERVIEW.	5
2.2 DOCUMENT CENTRE.	5
2.3 PURPOSE OF PIPELINE(S).....	5
2.4 CONSUMERS.	6
2.5 DESCRIPTION OF MOD GAS NETWORKS.	6
2.6 PRIMARY METER DETAILS.	7
2.7 UTILISATION METERS (METERS SUPPLIED DIRECTLY FROM THE MOD GAS NETWORK).....	7
2.8 SECONDARY PRESSURE REGULATING INSTALLATIONS (PRIS).	7
2.9 EMERGENCY CONTROL VALVES (ECVs).....	7
2.10 MOD NETWORK PIPELINE DETAILS.	8
2.11 NETWORK INTERCONNECTION.....	9
2.12 SENSITIVE AND CRITICAL LOADS.	10
2.13 STANDBY ALTERNATIVE FUEL SUPPLIES.	10
3 PLANT AND PREMISES.....	11
3.1 DRAWINGS.....	11
3.2 ADDITIONAL DRAWINGS.	11
3.3 RESPONSIBILITY INTERFACES AND ACCESS ARRANGEMENTS.....	11
4. OPERATION AND MAINTENANCE DOCUMENTATION	12
4.1 MOD NETWORK MAINTENANCE.....	12
4.2 IRON PIPEWORK.....	13
5. RISK ASSESSMENTS	14
5.1 MODEL RISK ASSESSMENTS.	14
5.2 ADDITIONAL SITE-SPECIFIC RISK ASSESSMENTS.	14
6. SAFETY MANAGEMENT SYSTEMS	15
7. EMPLOYEE COMPETENCE	15
8. CONTRACTORS	15
9. HEALTH AND SAFETY COMMUNICATION – INTERNAL.....	15
9.1 HEALTH AND SAFETY COMMUNICATION.....	15
10. HEALTH AND SAFETY COMMUNICATION – EXTERNAL	16
11. AUDITS.....	17
11.1 GSM AUDIT.....	17
12. CO-OPERATION	18
12.1 EMERGENCY EXERCISES.....	18
13. EMERGENCY SERVICE RESPONSE TO GAS ESCAPES	18

14. INVESTIGATIONS	18
15. GAS QUALITY.....	19
16. CONTINUITY OF SUPPLY	19
17. ADEQUATE NETWORK PRESSURE	20
17.1 NETWORK ANALYSIS.	20
17.2 DESIGN MINIMUM PRESSURE.	20
17.3 NETWORK ANALYSIS RESULTS.....	20
17.4 NETWORK VALIDATION SURVEY.	22
17.5 NETWORK VALIDATION SURVEY RESULTS.	22
17.6 CORRECTIVE MEASURES.	23
18. GAS SUPPLY EMERGENCIES	23
19. GAS QUALITY – SOLE CONVEYER	24
20. DISCONTINUING GAS SUPPLY.....	24
21. RESTORATION OF SUPPLIES.....	24
ANNEX A - ABBREVIATIONS	25
ANNEX B - SITE LAYOUT DRAWINGS.	26
ANNEX C - MODEL RISK ASSESSMENTS	1
ANNEX D - ADDITIONAL SITE-SPECIFIC RISK ASSESSMENT TEMPLATE	16

1 THE DUTY HOLDER AND ESTABLISHMENT LEVEL KEY PERSONALITIES

1.1. Gas Safety Case Duty Holder.

The duty holder for the MOD Gas Safety Case is the Permanent Under Secretary for Defence (PUS). However, day to day responsibility for the preparation and maintenance of the document is delegated to the DIO TS Head of Engineering and Construction, who also has the responsibility for managing the system in accordance with the Safety Case. PUS delegates maintenance responsibility to the Top-Level Budget Holders (TLB's), to manage safety of the gas network. The TLB's utilise MOD Contracts i.e. MMOs who have responsibility for maintaining the gas network on behalf of the MOD.

Name:	Permanent Under Secretary
Address:	Main Building Horse Guards Parade Whitehall London SW1A 2HB

1.2. DIO Technical Services Principal Gas Engineer (PGE).

The PGE assumes the role of Senior Authorising Authority which is a term used within the MOD to recognise the authority of the person responsible for overseeing the appointment of, and auditing Authorising Engineers (AEs). For Gas the AEs are replaced by Gas Safety Managers (GSMs).

Name:	Jeremy Obbard
Address:	DIO HQ Whittington Barracks Lichfield WS14 9TJ
☎:	07970 171303
✉:	Jeremy.obbard100@mod.gov.uk

1.3. Establishment Personalities.

Name of Establishment:	Trowbridge JCC ACF ATC	
Establishment Address:	Frome Road, Trowbridge, Wiltshire, BA14 0DQ	
Head of Establishment (HoE) (This is the most senior MOD person identified, by the chain of command, as responsible for the establishment. The HoE holds accountability for ensuring site compliance with the requirements of GSMR and the MOD GSC, including this GSMP.)	Name: Neville Holmes MBE Position: Chief Executive Officer Organisation: Wessex Reserve Forces' and Cadets' Association Address: Mount House Mount Street Taunton Somerset TA1 3QE ☎: Tel:01823 217930 Mob:07850 655017 ✉: wx-ce@rfca.mod.uk	

Establishment 4C's	Name: Position: Organisation: Address: ☎: 07775 675268 ✉: wx-wil-ccoy@rfca.org.uk	
Establishment SHEF	Name: Position: Organisation: Address: ☎: 07850 024704 ✉: wx-wil-cqm@rfca.org.uk	
Senior DIO representative or equivalent (This may be the SEFM, but will vary depending on the contract this establishment falls under)	Name: Position: Organisation: Address: ☎: 01823 217949 Mob:07955280440 ✉: wx-est-hd@rfca.mod.uk	
Site Guardroom (24 Hours)	☎: No site guardroom.	
Site emergency services (Are they 24 Hours?)	Fire ☎: 999 Police ☎: 999 Medical ☎: 999	

1.4. Maintenance Management Organisation (MMO).		
The MMO for this establishment is:		VIVO Defence Services
MMO Customer Services (not 24 hours)	Organisation: Address: ☎: ✉:	VIVO Helpdesk 25 Goodlass Road Hunts Cross Liverpool L24 9HJ 0800 046 6010 helpdesk@VIVOdefence.com
MMO Helpdesk – Gas Emergencies only (24 Hours) Note: Please do not contact the general public National Gas Emergency Service for suspected gas escapes on RFCA infrastructure	Organisation: ☎: ✉:	VIVO Helpdesk 25 Goodlass Road Hunts Cross Liverpool L24 9HJ 0800 046 6010 helpdesk@VIVOdefence.com
Site Contact	Name: Organisation: Address: ☎: ✉:	Steven Davies CAA RFCA Frome Road, Trowbridge, Wiltshire, BA14 0DQ 07775 675268 wx-wil-ccoy@rfca.org.uk
Gas Safety Manager (GSM)	Name: Organisation: Address: ☎: ✉:	Justin Westcott VIVO Building 002, CTCRM Lympstone Nr Exmouth Devon, EX8 5AR 07793 222820 justin.westcott@VIVOdefence.com
Gas Responsible Person (GRP)	Name: Organisation: Address: ☎: ✉:	Ian Bradley VIVO Trenchard Line, Upavon, Pewsey, Wiltshire. SN9 6BE 07793 222771 ian.bradley1@VIVOdefence.com

1.5. Additional Gas Contacts.		
External Gas Distribution Network (EGDN)	Organisation: Address: ☎: ✉:	Wales & West Utilities Ltd Wales & West House Spooner Close Celtic Springs Coedkernew Newport, NP10 8FZ 0800 912 2999 Steve.harding@wwutilities.co.uk
Meter Asset Manager (MAM)	Organisation: Address: ☎: ✉:	Energy Assets Ltd 6 Almondvale Business Park, Almondvale Way, Livingston EH54 6GA 01506 405405 info@energyassetsnetworks.co.uk
Gas Supplier	Organisation: Address: ☎: ✉:	TotalEnergies Gas & Power 55-57 High Street, Redhill, Surrey, RH1 1RX. 01737 275 746 gp.redhill.ccs@totalenergies.com
DIO SD EUS (Service, Delivery, Energy, Utility and Sustainability)	☎: ✉:	01213 113854 DIOSDEUS-enaccounts@mod.gov.uk
National Gas Emergency Centre (24 Hours) Note: Please do not contact the general public National Gas Emergency Service for suspected gas escapes on RFCA infrastructure	☎:	0800 111 999
National Emergency Services (24 Hours)	Fire ☎: Police ☎: Medical ☎:	999 999 999

2 OPERATION UNDERTAKEN

2.1 Site Overview.

A brief description of the establishment and its current use. This should include how many separate sites are present, number of buildings being supplied by gas, what the gas is used for and number of personnel who will be affected by a gas outage. Any critical loads should be initial highlighted here (quick reaction forces, large medical facilities, temp controlled ammunition stores etc)

Trowbridge ACF ATC is a single site establishment with two building on site, only one of which is supplied with gas. The gas for this is supplied direct from the EGDN network and has a MAM owned and operated gas meter and regulator.

This site is used by Wiltshire ACF (Trowbridge Detachment) and Trowbridge Squadron 2196 ATC and is open on Wednesday and Friday evenings for parade nights.

The building contains classrooms, offices, parade hall, toilets and kitchen area.

2.2 Document Centre.

Location of the establishment Gas Document Centre containing all information relating to the gas systems at this establishment (Ref: MOD GSC 10.2) and contact details if different to the GRP.

The Gas document centre is held electronically by VIVO, it can be accessed by the GSM & GRP

2.3 Purpose of Pipeline(s).

A brief description of demarcation agreements between the EGDN, MAM and MOD. Number of MOD networks including operating pressures and number of buildings being supplied direct from the EGDN. End users of gas being supplied such as accommodation, workshops, catering facilities etc.

The gas supplied to Trowbridge JCC ACF ATC is fed from a Wales and West Utilities single feed low pressure network which supplies the site bulk fiscal meter. This feeds the MoD Low pressure network on site at 21 mbar which then supplies gas to one building.

The gas is used for Heating and hot water. The building on site is used as offices, training facilities, store and kitchen (electric only). There are no additional EGDN supplied buildings on site.

The MoD is responsible from the meter outlet valve of the primary meter up to and including the appliances (2 boilers) in the plantroom.

2.4 Consumers.

Consumers can be broadly categorised as domestic or industrial / commercial. Gas supplies to domestic consumers are normally prioritised above industrial / commercial consumers.

Domestic consumers supplied from the MOD network:	0
Industrial / commercial consumers supplied from the MOD network:	1

2.5 Description of MOD Gas Networks.

A description of the MOD gas network(s) including location of primary meter(s), twin stream or single stream, primary meter kiosk construction and condition. Pipeline length, material, diameter, pressure, age and condition. Are any PRIs present and number of buildings being supplied?

The gas supply to Trowbridge JCC ACF ATC is supplied from the WWU low pressure network and enters the site at the East Corner of the establishment into a GRP meter kiosk.

There is a 2" steel riser entering a gas meter kiosk, ECV, regulator and single stream gas meter installation.

The MoD's responsibility begins after the gas meter outlet valve (22mm). The outlet gas pressure is 21mbar, so the MoD network is a low pressure (LP) network. The MoD network is estimated to have been installed in 2017.

The MOD network leaves the Bulk Fiscal meter in 22mm copper and drops below ground in 63mm PE (50mm ID). There is assumed to be one section of 63mm PE travelling to the 80mm ECV in a GRP housing.

The building does not have an individual PRI.

The MoD Network is 97metres in length.

2.6 Primary Meter Details.

The following table describes the basic arrangement of the incoming primary meter installation(s). (These are the responsibility of the MAM)

Number of primary meter installations:		1								
Meter Name / ID	MAM Responsible	Inlet pipeline (responsibility of the EGDN)				Outlet pipeline (responsibility of the MOD)				Max Flow (M ³ hr)
		P tier – HP, IP, MP, LP	Pressure (mbar)	Material (EGDN Network)	Diameter (mm)	P tier – HP, IP, MP, LP	Pressure (mbar)	Material (MOD Network)	Diameter (mm)	
G4 – K0035764 17 01	Energy Assets Ltd	LP	No test point.	PE	50 (ID)	LP	21.4	PE	50 (ID)	6

2.7 Utilisation Meters (meters supplied directly from the MOD gas network)

Utilisation Meter Details can be seen in the GSMP section A.

Number of utilisation meter installations: 0

2.8 Secondary Pressure Regulating Installations (PRIs).

The following table describes the basic arrangement of the PRIs. (This does not include utilisation meter governors installed downstream of the consumers ECV)

Number of PRI installations:		None								
PRI Name / ID	Nominal Reg size (mm)	Inlet pipeline				Outlet pipeline				Kiosk construction / condition
		P tier – MP, LP	Pressure (mbar)	Material (MOD Network)	Diameter (mm)	P tier – MP, LP	Pressure (mbar)	Material (MOD Network)	Diameter (mm)	

2.9 Emergency Control Valves (ECVs).

The ECV(s) are included in the scope of the network and are therefore the responsibility of the MOD.

The MOD gas networks at this establishment terminates at:				1 ECV in GRP housing					
Building Name / Number	Incoming Gas Pressure	Appliance / Process / Domestic	ECV No. / Code	Indoors / Outdoors	Key required to access the ECV – Where from?	ECV Location	Handle Fitted	ECV correctly labelled	Nominal Valve Size
Main Building	19 mbar	Boilers	TROW-001	Outdoors	Triangle Key	Within kiosk	Yes	Yes	50mm

2.10 MOD Network Pipeline Details.

The table below shows the total pipeline lengths for the different pipe diameters and operating pressures.

[illegible]

2.11 Network Interconnection.

The outlet pipework system from each of the primary meter installations can be isolated networks or may be interconnected with other MOD systems. For isolated systems turning off the gas supply at a single primary meter installation will shut off supply to all buildings / processes on that pipe system. Interconnected systems will require two or more primary meter installations to be turned off. Figures 2.1 and 2.2 below show the differences.

The MOD pipework system on this establishment are:		
Supply from Primary Meter (Name / ID)	Pressure (mbar)	Can the interconnection be isolated?
None	N/A	N/A




Figure 2.1 – Isolated MOD pipework systems




Figure 2.2 – Interconnected MOD pipework systems

2.12 Sensitive and Critical Loads.

The MOD does not have any 'interruptible consumers. Historically large industrial / commercial consumers, who had an alternative fuel supply, could opt to pay a lower rate for an interruptible contract which enabled the supplier to isolate their supply at short notice in order to preserve the gas supply to the public and 'firm contract' industrial consumers in the event of a supply shortage.

However, all industrial and commercial supplies are, effectively, 'interruptible' isolation of these will usually be requested by the supplier in times of supply emergencies in order to preserve domestic supplies for as long as possible.

Where Industrial / commercial consumers have particularly sensitive or critical end users these can be taken into consideration by the EGDN when requesting isolation. Sensitive consumers could include supplies such as a school, medical facility, temperature-controlled ammunition stores etc.

The number of sensitive loads at this establishment is: None

Facility / Consumers	Supplied from primary meter name / ID	Approx. max throughput (m ³ hr)
None	N/A	N/A

2.13 Standby Alternative fuel Supplies.

Where operational critical supplies are present on site a standby alternative fuel supply should be considered which would enable continued operation in the event of either a local or national supply emergency.

Facility / Consumers	Supplied from primary meter name / ID	Approx. max throughput (m ³ hr)	Alternative fuel supply
None	N/A	N/A	N/A

3 PLANT AND PREMISES

3.1 Drawings.

The gas layout drawings provide an overview of the gas network and the interfaces(s) with the EGDNs network.

The layout drawings should detail:

- a) The site boundaries.
- b) The primary meter installations.
- c) Secondary PRIs.
- d) Valve locations.
- e) Pipeline routes, diameters, material and depth.
- f) Operating pressure tier.
- g) Demarcations
- h) Responsibilities (EGDN / MOD)

The layout drawings are located at Annex B either embed as a PDF or hard copies. The drawings will be subject to the GRP quarterly review and following any physical changes or system updates. Hard copies of the drawings are located in the gas document centre.

Gas Layout Drawing Number	Revision Date	Scale	Detail
WX89-B-A1	15/1/24	1:250	Site layout drawing

3.2 Additional Drawings.

In addition to layout drawings the below additional drawings are available from the gas documents centre and GRP.

Additional Drawing Number	Revision Date	Scale	Detail
SW-Trowbridge RFCA-GAS-SCH-001	31/01/25	NTS	Gas Installation

3.3 Responsibility Interfaces and Access Arrangements.

For gas incidents or maintenance that affect the EGDN, the EGDN representative will become the network emergency controller. The EGDN establishment direct contact will be as detailed below who will make the relevant arrangements for access to the primary meter(s) and plant room access (for emergency isolation etc).

As the MOD establishments are high security, all EGDN personnel who attend for gas supply emergencies or to carry out maintenance work will be granted access to site on an individual basis.

All EGDN personnel attending this establishment will be subject to site specific security procedures and will be required to be escorted whilst on site, access and escorting may vary depending on the nature of the visit, time of incident etc.

Below are the site-specific arrangements in place to allow the EGDN access during an emergency, as agreed by the HOE:

Working Hours Contact: Devizes 01380 724114. No out of hours contact.

4. OPERATION AND MAINTENANCE DOCUMENTATION

4.1 MOD Network Maintenance.

Network maintenance is mandated in GSMR and all network maintenance requirements and tasks on MOD establishments are detailed in the MOD Gas Network Technical Standard TS/GAS-01. TS/GAS-01 has been written in line with legislation, industry standards and guidelines.

The testing, inspecting and maintenance frequencies vary depending on the task, the table below shows the intervals at which it should be conducted and the date the tasks have been complete.

TS/GAS-01 Job No.	Maximum Interval Period	Brief Description of Task	Task was completed on
1	General		
1.1	5 Years	Network Analysis – to model the adequacy of network design	Completed by DNV 18/10/2022
1.2	5 Years	Network Validation Survey – to check network analysis model with measured data	Completed by DNV as part of the network survey for the site 9/01/2022
2	Iron Pipelines, mains and services (includes buried outlet pipework from Primary Meter Installations and PRIs.) Note: iron pipes are not permitted for use with LPG – any such pipes must be immediately scheduled for replacement		
2.3	12 Month	FIM (or similar) leakage survey – Pipes within 30m of a building	N/A – no iron pipe
2.4	12 Month	Over line pipe survey – Pipes within 30m of a building	N/A – no iron pipe
2.5	5 Years	FIM (or similar) leakage survey – all pipe routes within site, regardless of proximity to buildings	N/A – no iron pipe
2.6	5 Years	Over line pipe survey – all pipe routes within site, regardless of proximity to buildings	N/A – no iron pipe
3	Steel Pipelines, mains and services (includes buried outlet pipework from Primary Meter Installations and PRIs.) Note: buried steel pipes are not permitted for use with LPG – any such pipes must be immediately scheduled for replacement, and the SME(Gas) informed		
3.1	12 Month	Cathodic Protection (CP) monitoring survey	N/A
3.2	12 Month	Leakage survey (where no CP installed) – pipes within 5m of buildings	N/A
3.3	5 Years	Leakage survey (where no CP installed) – regardless of proximity to buildings	N/A
3.4	5 Years	Over line pipe survey (where no CP installed) – regardless of proximity to buildings	N/A
3.5	10 Years	Close Interval Potential Survey (CIPS) – for buried pipelines, mains and services with CP installed	N/A
4	Polyethylene (PE) Pipelines, mains and services		

4.1	5 Years	Leakage survey – All pipes within site regardless of proximity to buildings	Completed by DNV as part of the network survey for the site 19/01/2022
4.2	5 Years	Over line pipe survey – All pipes within site regardless of proximity to buildings	Completed by DNV as part of the network survey for the site 19/01/2022
5	This section refers to LPG installations only – refer to TS/GAS-01		
6	Secondary Pressure Regulating Installations (PRIs). Note: this is for secondary network PRIs only – it does not include the PRIs associated with the Primary Meter Installation(s), first-stage LPG regulators or the Meter regulator(s) installed downstream of the consumers / user ECVs		
6.1	12 Month	Functional check of PRI including safety / redundant systems	N/A – no PRI
6.2	12 Month	Visual inspection of pipework within PRI housing	N/A – no PRI
7	Meter and PRI Housings Scope for this activity includes the housing of all meter and PRI installations		
7.1	12 Month	Inspection of PRI housing (where present)	N/A – no PRI
8	Valves		
8.1	12 Month	Inspection of valve chambers	
8.2	12 Month	Leakage detection survey within valve chamber	

4.2 Iron Pipework.

Where cast iron (including spun iron) or ductile iron pipework exists on an MOD establishment it is to be risk assessed in accordance with section 4.3 of the MOD GSC and, where required, entered into a mains replacement programme in order to comply with the UK mains replacement enforcement policy.

Below is the amount of Cast Iron and / or Ductile Iron pipe, and details, identified at this establishment from a survey:

Cast Iron (m):		Not Applicable				
Ductile Iron (m):		0				
Pressure (mbar)	Nominal Diameter (")	Cast Iron or Ductile Iron	Total Length (m)	Closet Proximity to buildings (m)	Risk Score	Planned Replacement Date
N/A	N/A	N/A	0	N/A	N/A	N/A

5. RISK ASSESSMENTS

5.1 Model Risk Assessments.

The Model Risk Assessment (RA) shown in the table below, highlight the factors that will affect the safe management of the flow of gas, and the provision of the emergency response service. These RA, reviewed and modified as appropriate to this establishment, are shown at Annex C. (These RA must be reviewed and authorised by the GRP as being correct for this establishment with the date entered at the top of the RA).

RA No.	Title (Model Risk Assessments)
1	Any gas leak considered hazardous to persons or property (Under med/low pressure conditions).
2	Fire or explosion near to, or directly involving, a pipeline or gas facility.
3	A failure of operation of pipeline/plant onsite, or immediately downstream of site, that is maintained by the gas transporter.
4	A failure of operation of pipeline/plant onsite that is maintained by site services.
5	Failure of safety critical equipment.
6	Under-pressure in the gas system.
7	Over-pressure in the gas system.
8	Failure in system during load shedding.
9	General changes to the gas network.
10	Failure of PPM, general operation of the gas network plant/equipment and safety inspections.
11	Emergency Shutdowns.
12	Interface with Gas Transporter.
13	Interface with the consumers.
14	Interface with Emergency Services.
15	Natural Disasters, civil disturbances, other unforeseen events.

5.2 Additional Site-Specific Risk Assessments.

In addition to the model RA shown above, the site-specific RAs shown below have been identified. These RA are shown in Annex D (As with the Model RAs above, these must be reviewed and authorised by the GRP as being correct for this establishment with the date entered at the top of the RA).

16	
17	
18	
19	

6. SAFETY MANAGEMENT SYSTEMS

Site-specific considerations (refer to MOD Gas Safety Case Section 6) as stated below:

JSP375 Chapter 8 is followed for this site.

All operatives being used to work on any gas system are to be verified as competent and appointed as a gas skilled person prior to undertaking any gas work.

Works on the network are also controlled as per SCO requirements with permits issued as required.

7. EMPLOYEE COMPETENCE

Site-specific considerations (refer to MOD Gas Safety Case Section 7) as stated below:

The gas responsible person for this site has been appointed and maintains adequate familiarisation of the network(s) and systems. Persons undertaking any gas works to be pre-approved and skills appointed as per the gas safety case and JSP 375 Ch8

8. CONTRACTORS

Site-specific considerations (refer to MOD Gas Safety Case Section 8) as stated below:

All contractors to be pre-approved to undertake any works on site as per the gas safety case – JSP 375 Ch8

9. HEALTH AND SAFETY COMMUNICATION – INTERNAL

9.1 Health and Safety Communication

This section describes the systems in place to enable effective communications within this establishment. Different forms of communication are used to pass information to people within the MOD/MMOs depending on the type of information and the audience including in the event of an emergency.

9.1.1 Public Address System.

The public address arrangements for this establishment are shown below

No public address system on this site.

9.1.2 Internal Electronic Correspondence.

Details of any internal email or intranet correspondence are shown below

The site has the facility for email to be used for communication. Email addresses for Key site personalities are listed in section 1 of this document.

9.1.3 Direct Contact.

Details of any site-specific arrangements for direct MOD / MMO contact with site personnel and families are shown below

Face to face meetings with key personnel are possible on a regular basis if required.

9.1.4 Emergency Plans.

Details of any site-wide emergency plans and arrangements, including MMO documents are shown below

All Gas incidents & Escapes are reported to the VIVO Helpdesk on 0800 030 9320.

The call centre will record the incident via the Maximo system and pass the incident to the appropriate person for action.

All works on site are co-ordinated by the **VIVO DM, Supply chain Supervisor and RP Gas.**

VIVI Helpdesk to contact National Emergency Gas Centre (0800 111 999) if needed, and notify the EGDN.

RP to follow guidance from Gas safety Case: fig 13.1, fig 13.2, fig 13.3, fig 13.4, fig13.5, fig 13.6.

9.1.5 On-Site Emergency Services.

Details of site-specific arrangements for communication with site emergency services, such as fire, are shown below

There are no on-site emergency services. Site personnel will dial 999 for Police, Fire and Emergency Medical services. For Gas Emergencies site will dial 0800 030 9320

10. HEALTH AND SAFETY COMMUNICATION – EXTERNAL

Site-specific considerations (refer to MOD Gas Safety Case Section 10) as stated below:

External Health and Safety communications can be received by the establishment and the Gas responsible Persons from various external sources both in postal mail and through electronic communications.

These can be from sources such as the MAM following site inspections.

Safety alerts/updates communicated from the Gas Safe Register.

Manufacturer specific information conveyed through email.

Through to direct communications from the Principal Gas Engineer where safety critical information has to be cascaded for site review.

11. AUDITS

11.1 GSM Audit.

The audit process in place monitors and measures compliance with legislation and company policy and is aimed at ensuring the safe flow of gas within the MOD networks and downstream of the consumers ECV.

The GSM audit role is primarily concerned with assuring that the GRP duties are being effectively undertaken and that the gas risks are being effectively managed on the site. All GSM Audits will be carried out using the standard audit template prepared by the DIO PGE. Every site with gas networks shall be audited as frequently as practicable, ideally annually and in accordance with a programme agreed with the DIO PGE. Every site shall be audited at least once every three years. Each GSM shall implement an audit programme which must be agreed by the DIO PGE. All completed audit reports shall be sent to the DIO PGE for review and filing.

As agreed with the PGE, GSM audits on this establishment will be carried out:	On a maximum three-yearly basis
The last GSM audit was conducted on:	No previous GSM audit
The last GSM audit was carried out by:	No previous GSM audit
The qualitative assessment of the GSM audit concluded this establishment is: (safe to continue / safe to continue subject to caveats / unsafe to continue)	No previous GSM audit
Audit findings:	No previous GSM audit
Points addressed following last audit:	No previous GSM audit

12. CO-OPERATION

12.1 Emergency Exercises.

On MOD networks, the MMO utilises EGDN to provide a gas emergency response service for dealing with reported gas escapes. However, the EGDN response would normally be to isolate MOD supplies at the incoming meter installation(s). As this is likely to cause considerable inconvenience and expense to MOD facilities, where possible MMO staff / contractors would attempt to attend the emergency in advance of the EGDN personnel to assess the emergency and advise EGDN accordingly.

It is the responsibility of the HoE to ensure that a gas emergency exercise is conducted on the establishment at least once in a three-year period. The HoE will require the support and involvement of the MMO and all key stakeholders such as the EGDN. Lessons learnt should be actioned and kept within the gas document centre.

Date of last emergency exercise:	No previous emergency exercises
Date of next planned emergency exercise:	Requirement for emergency exercises has been issued to the RFCA for distribution to HoE's, not currently planned in for completion.
Date of last actual emergency involving EGDN:	No previous actual emergency reporting
Were the EGDN involved in the last emergency exercise:	No previous emergency exercises
Were the MOD emergency services involved in the last emergency exercise or actual emergency:	No previous emergency exercises
Summary of lessons learnt from the last emergency exercise or actual emergency:	No previous emergency exercises
Date MMO emergency contact numbers and procedures were last tested:	No previous testing

13. EMERGENCY SERVICE RESPONSE TO GAS ESCAPES

Site-specific considerations (refer to MOD Gas Safety Case Section 13) as stated below:

There are no site-based emergency services at Trowbridge RFCA. If required in the event of an incident the civilian emergency services will be contacted. The EGDN responder will be suitably qualified and competent to action assistance as required.

14. INVESTIGATIONS

Site-specific considerations (refer to MOD Gas Safety Case Section 14) as stated below:

Any gas incidents on site will be subject to investigation, these include items such as pipe strikes or unsafe occurrences. Incidents are then logged on the MOD NLIMMS so reports can be requested, or closure actions confirmed if required.

15. GAS QUALITY

Site-specific considerations (refer to MOD Gas Safety Case Section 15) as stated below:

As the gas is supplied directly by the EGDN it is deemed to already be of the correct quality as required by them to supply to the MOD as a consumer. The MOD have no further control over gas quality.

16. CONTINUITY OF SUPPLY

Site-specific considerations (refer to MOD Gas Safety Case Section 16) as stated below:

If any supply emergencies are notified by the supplier, the site will review usage to reduce any non-critical consumption or reduce potential maximum demands. Assets fed from the MOD network are subject to network modelling to ensure continuity of supply so any operations on the network are subject to analysis before they are permitted.

17. ADEQUATE NETWORK PRESSURE

17.1 Network Analysis.

Network Analysis is the primary tool by which the MOD satisfies itself that anticipated levels of demand can be supplied from its MP and LP networks to gas consumers. It allows different scenarios to be examined. The technique ensures the efficient management and operation of the MP and LP gas supply systems. It enables a detailed understanding of the gas supply system to be developed upon which cost effective planning and operating decisions can be made.

In accordance with industry recommendations Network Analyses must be repeated at every site containing an MOD Network at least five-yearly, or sooner, if for gas system modification purposes or when demand profiles have changed or are expected to change.

For this establishment the network analysis was undertaken by:

DNV

For this establishment the network analysis was undertaken on:

18/10/2022

17.2 Design Minimum Pressure.

The MOD utilises nominal minimum design pressures, in compliance with IGE/GL/1. These minimum pressures will be seen at the extremities of the systems under extreme conditions. To ensure that all gas equipment downstream of the meter can be safely operated, it is a gas industry recommendation that the network should maintain a minimum of 20.75 mbar at the end of any service pipe. However, for existing networks, it is permitted to have a pressure as low as 19 mbar at the end of any service under 1 in 20 peak six-minute conditions. This value must also include any temporary contingencies to support maintenance activities. Where any appliances have elevated minimum recommended operating pressures (P_{ign}), the DmP must allow for this, taking into account any pressure losses across the meter (4mbar) and through installation pipework (10% of P_{ign}).

The minimum modelled pressure (based on 1:20 peak 6 minutes flow conditions) at the outlet of the consumers ECV at the system extremity is:

21.0 mbar

The location of the minimum pressure is:

Main building plant room

The declared minimum pressure (DmP) is:

19.0 mbar

17.3 Network Analysis Results.

A brief description of the network analysis results is below;

Pipe Data

The pipe model was built from the 'WX89-B-A1.dwg' and 'WX89-B-A1.pdf' files produced by DNV from drawing records supplied by the RFCA. The files included the pipe lengths, connectivity, diameters and materials all used in the modelling.

Demand Data

The demand levels used in the analysis are the maximum estimated flows that the network is likely to experience. This criterion is stated in IGE/GL/1 Planning of Gas Distribution Systems of MOP not Exceeding 16 bar, section 4.2.1:

'Any system should be designed to meet the maximum demands placed upon it.

Note: Experience has shown that this is likely to be the maximum demand that will occur in any period of not less than 6 minutes, expressed as an hourly rate.'

The Trowbridge JCC ACF ATC network is comprised of a mixture of building types and usage, and the principal uses for gas are for catering, space and water heating. The effects of diversity have not been considered. This undiversified demand modelling ensures that the worst-case scenario is assessed.

Details of installed appliances were available for all of the buildings on site. The appliance input ratings (kW) were used to calculate the peak instantaneous flow rates (sm³/h). These values represent the maximum flow within the pipe network and are undiversified values.

Supply Data

Gas is supplied to Trowbridge JCC ACF ATC from a low pressure (LP) main. Supply pressure data obtained by DNV in the form of instantaneous pressure readings shows the outlet pressure of the main site regulators to be as follows:

Bulk Fiscal Primary Meter (BFPM), located in the Meter Kiosk had an outlet pressure of 21.4 mbar (working).

For the modelling, the instantaneous pressure recorded at the meters by the pressure gauge have been used.

Regulator and BFPM Capacity

<i>Meter Location</i>	<i>Supply Regulator Make and Model</i>	<i>BFPM Make and Model</i>	<i>Supply Meter Capacity (sm³/h)</i>	<i>Estimated Maximum Flow (sm³/h)</i>
<i>Meter Kiosk: BFPM</i>	<i>Elster</i>	<i>G4</i>	<i>6</i>	<i>6.28</i>

Network Supply Details

The capacity of the main meter is 6 sm³/h which is less than the estimated maximum flow through the meter (6.28 sm³/h). This indicates that the meter may be undersized.

Pressure Survey and Network Analysis Results

In accordance with the recommendations of Section 8.3.2 of IGE/GL/1, a pressure survey would normally be carried out on the Trowbridge JCC ACF ATC network in order to verify that the results from the network model were indicative of the recorded pressures on the network. This is a practice which is widely used throughout the gas industry to provide confidence in network analysis models.

The network was surveyed on the 19th of January 2022. Single point pressure readings using a Druck pressure gauge or similar were recorded. These were attached to the outlet of the BFPM test point and at the plant room ECV.

A simple pressure survey of short-term single readings was undertaken at 2 locations in the modelled area. The recorded pressures taken in this type of survey may be standing pressures where the appliances are not operational, or working pressures, where they are. There may be several mbar differences between these pressures.

Pressure Modelling and Comparison

The network model was built and analysed as detailed above. The pressure data collected during the survey was compared with the modelled pressures, as shown in the table below. 19 mbar is used in this report as the minimum pressure requirement under maximum flow conditions for this network. This is taken as the pressure requirement for the inlet to the appliances. It is expected that the modelled pressures will fall below those recorded as the modelled demand is the estimated maximum and it is unlikely that these conditions were experienced whilst the survey was undertaken. Providing that the modelled pressures are not significantly lower than those recorded, or below the minimum pressure requirement,

this should not be a cause for concern as the difference can be attributed to the lower demand flows being experienced.

Building	Modelled Flow (sm ³ /h)	Pressure (mbarg)	
		Single Read	Modelled
Meter Kiosk: BFPM		21.4 (Working)	21.4
Main Building: Plantroom	6.28	19 (Working)	21.0

Modelled Pressure Results

Whilst no comparison data was available for network pressures, there is still reasonable level of confidence in the modelling of the network since the pipe network and demands are well defined.

The minimum modelled pressure on the network is 21.0 mbar at the inlets to the Plant Room. This shows a modelled pressure drop of 0.4 mbar from the supply (21.4 mbar).

17.4 Network Validation Survey.

As part of the network analysis validation procedure, pressure monitoring points are to be installed on MOD networks to enable pressure surveys to be conducted. In accordance with the recommendations of Section 8.3.2. of IGE/GL/1, pressure surveys will need to be carried out on MOD networks to verify that the results from the network models were indicative of the recorded pressures on the network. This is a practice which is widely used throughout the gas industry to check network models provide realistic results.

It is the responsibility of the MMO to ensure adequate pressure surveys are conducted at regular intervals to validate the pressures predicted by network analysis results. This must be conducted at a minimum of once every five years, in conjunction with a Network Analysis or when demand profiles on the network have changed. Similarly, if the results of a previous Network Analysis are suspected to be inaccurate (for example, low extremity pressures being experienced), a repeat Network Analysis should be undertaken.

For this establishment the latest validation survey was undertaken by:	DNV
---	-----

For this establishment the latest validation survey was undertaken on:	19/08/2022
---	------------

17.5 Network Validation Survey Results.

A brief description of the network validation survey results is below which includes a comparison of the modelled pressure and actual pressure record;

The pipe data available at the time of producing this report, and which has been used to build the Synergi network analysis model of Trowbridge JCC ACF ATC, was of a good quality.

Demands were estimated based upon appliance ratings determined during the site survey.

The BFPM has a smaller capacity than the calculated maximum demand (6 sm³/h vs 6.28 sm³/h), indicating that the meter may be undersized.

There is a good degree of confidence in the pressures predicted by the network model as a result of the pressure comparison against the recorded pressures.

Modelling of the documented infrastructure and maximum estimated gas demands shows that all the buildings modelled should receive gas with a pressure above the minimum limit of 19 mbar within the network.

17.6 Corrective measures.

Following the network analysis and network validation survey the below corrective or mitigation measures have been planned at this establishment;

MOD network name / ID:	Network 01
-------------------------------	------------

The results for the Trowbridge JCC ACF ATC model as a whole are satisfactory

18. GAS SUPPLY EMERGENCIES

Site-specific considerations (refer to MOD Gas Safety Case Section 18) as stated below:

Generally, any Gas Supply Emergency will be related to a pressure issue from the incoming EGDN supply, the site will be notified to enable load shedding or appliances to be isolated.

If a supply emergency is caused through a fault with an EGDN regulator or MOD network section pressure reduction installation the MMO will respond. For low pressure emergencies the MMO will again review the asset list and any appliance which contain a pilot light and isolate those first. Other appliances across the site will have safety devices to shut them down if low pressure is experienced. A load shedding exercise will then take place to minimise potential demands and assess what assets can be maintained in operation until the pressure issue is resolved.

If a full pressure loss is experienced a longer process of testing and re commissioning will have to take place to ensure the system is correctly purged to greater than 90% gas in air before any appliances can be re commissioned.

19. GAS QUALITY – SOLE CONVEYER

Site-specific considerations (refer to MOD Gas Safety Case Section 19) as stated below:

The gas for the MoD is supplied at the relevant Quality via the EGDN therefore the provisions of GSMR Schedule 1 Paragraph 19 does not apply.

20. DISCONTINUING GAS SUPPLY

Site-specific considerations (refer to MOD Gas Safety Case Section 20) as stated below:

If the site was advised by the EGDN that an interruption of the site supply was required a dynamic risk assessment will be undertaken by DIO, The Gas RP and the establishment to assess what critical activities are being undertaken on site and to enable prioritisation of which supplies could be safely shut down and in which order.

21. RESTORATION OF SUPPLIES


Site-specific considerations (refer to MOD Gas Safety Case Section 21) as stated below:


To re-establish any isolated supplies following an emergency isolation the Gas RP will ensure that each supply/service is methodically re-instated following suitable pressure testing and purging if the mains/services have de pressurised and where there is a possibility of an air/gas mixture within the pipelines.
These works will take place under a specific safe system of work procedure.

ANNEX A**ANNEX A - ABBREVIATIONS**

4C's	Co-ordination, Co-operation, Communication and Control
AE	Authorising Engineer
CI	Cast Iron
CIPS	Close Interval Potential Survey
CP	Cathodic Protection
DI	Ductile Iron
DIO SD EUS	Defence Infrastructure Organisation Service Delivery, Energy, Utility and Sustainability
DIO TS	Defence Infrastructure Organisation Technical Services
DIO	Defence Infrastructure Organisation
DmP	Design Minimum Pressure
ECV	Emergency Control Valve
EGDN	External Gas Distribution Network
FIM	Functional Independence Measure
GRP	Gas Responsible Person
GSIUR	Gas Safety (Installation and Use) Regulations 1998
GSMR	Gas Safety (Management) Regulations 1996
GSC	Gas Safety Case
GSM	Gas Safety Manager
GSMP	Gas Safety Management Plan
HoE	Head of Establishment
HP	High Pressure
IGEM	Institute of Gas Engineers and Managers
IP	Intermediate Pressure
LP	Low Pressure
LPG	Liquefied Petroleum Gas
MAM	Meter Asset Manager
MMO	Maintenance Management Organisation
MOD	Ministry of Defence
MP	Medium Pressure
NA	Network Analysis
NG	Natural Gas
NVS	Network Validation Survey
PE	Polyethylene
PGE	Principal Gas Engineer
PRI	Pressure Reduction Installation
PUS	Permanent Under Secretary
RA	Risk Assessment
SHEF	Safety, Health, Environment and Fire
TLB	Top Level Budget Holder

ANNEX B - SITE LAYOUT DRAWINGS.





ANNEX C

ANNEX C - MODEL RISK ASSESSMENTS

Site Reviewed Model Risk Assessment - 01	
For: Trowbridge JCC ACF ATC	
Any gas leak considered hazardous to persons or property	
Approved by: Ian Bradley	
Date reviewed: 25/02/2025	
Risk	Any leak at any pressure can be quantified as a hazard. The higher the pressure and/or depending on the location of the leak the risk to the surrounding area varies
	Depending on the severity of the leak, other hazards such as explosions, fires, supply failures, pollution and associated financial implications could arise
	Depending on how quickly & thoroughly the gas leak is dealt with the resulting hazards from the incident will vary.
Caused By	Damage to pipelines from digging
	Failure of control equipment
	Damage caused by general construction
	Failure of mechanical joints and seals
	Deterioration or rupture of pipeline
	Poor communication between involved parties can exacerbate the problem
	Length of response time by first responders
Hazards Resulting from Risk	Damage to pipelines caused by uncontrolled escaping gas
	Risk of causing a supply emergency
	Damage to persons & property
	Risk of Explosions & Fire
	Pollution of environment
	Purging maybe required after corrective action
Current Preventative Methods	Permits to Dig
	Planned Preventative Maintenance
	Type & Quality control of materials used in gas network
	Strict adherence to emergency procedures in the event of an emergency
	Installation of gas network to industry standards
	Gas Safety Management Plan (GSMP) Part A and B
Further Required Preventative Methods	Training and simulated gas emergency drills – not carried out or managed
	Emergency signage not to standard – not carried out or managed

Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.	
Site Reviewed Model Risk Assessment – 02		
For: Trowbridge JCC ACF ATC		Approved by: Ian Bradley
Fire or explosion near to, or directly involving, a pipeline or gas facility		Date reviewed: 25/02/2025
Risk	Any fire or explosion directly involving a gas pipeline or facility could cause a major incident.	
	Any fire or explosion near to a gas pipeline or facility may cause personal injury and or damage to property.	
Caused By	Undetected trapped gas	
	Unresolved gas leaks	
	Failure of control equipment, pipelines, seals, joints etc.	
	Damage to gas pipelines through digging and/or general construction	
	Incorrect initial procedure when dealing with a gas leak	
	Inadequate action by first responder	
Hazards Resulting from Risk	Fire and/or explosions causing death and/or injury to general populous	
	Damage and/or destruction of surrounding properties	
	Damage to gas pipelines, gas control centres & other gas related equipment	
	Disruption of gas supply	
	Secondary Explosions & Fire resulting from inaction	
Current Preventative Methods	Scheduled Maintenance	
	Designed for purpose	
	Permits to Dig	
	Strict adherence to emergency procedures, including ventilating and evacuating area	
	Gas Safety GSMP Part A and B	
Further Required Preventative Methods	Training and simulated gas emergency drills – not carried out or managed	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.	

Site Reviewed Model Risk Assessment - 03	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
A failure of operation of pipeline/plant onsite, or immediately downstream of site, that is maintained by the EGDN	
Date reviewed: 25/02/2025	
Risk	Any incident directly involving the medium pressure pipelines onsite can only be dealt with by Wales and West Utilities in the event of a leak the response time by Wales and West Utilities has an impact on the severity of the incident
	The level of cooperation and communication between EGDN and the onsite parties has an impact on the eventual severity of the incident
Caused By	Poor response time by Wales and West Utilities
	Poor communication between onsite parties and Wales and West Utilities
	Poor coordination of onsite parties and Wales and West Utilities
	Poor communication of procedures
	Lack of supply resulting in drop in supply pressure, resulting in site wide gas supply failure
Hazards Resulting from Risk	Disruption of gas supply to whole site
	Re-commissioning & purging after corrective action
	Re-ignition of non-automatic ignition systems
	Long down time due to above hazards
Current Preventative Methods	General communication between site and Southern Gas Networks
	Use of GSMP
Further Required Preventative Methods	Communication of site procedures to SGN – not carried out or managed
	Understanding SGN procedures – not carried out or managed
	Training and simulated gas emergency drills – not carried out or managed
	Training for quicker response time – not carried out or managed
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 04	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
A failure of operation of pipeline/plant onsite that is maintained by site services	
Date reviewed: 25/02/2025	
Risk	Any incident directly involving the low or medium pressure pipelines onsite can be dealt with by the onsite gas operatives. In the event of a leak the response time by the onsite operatives has an impact on the severity of the incident
	The level of cooperation and communication between onsite parties such as emergency services and gas operatives has an impact on the eventual severity of the incident
Caused By	Poor response time by site services
	Poor communication between onsite parties
	Poor coordination of onsite parties
	Poor communication of procedures
Hazards Resulting from Risk	Disruption of gas supply to whole site
	Re-commissioning & purging after corrective action
	Re-ignition of non-automatic ignition systems
	Long down time due to above hazards
Current Preventative Methods	Scheduled Maintenance
	Designed for purpose
	Permits to Dig
	Strict adherence to emergency procedures
	Gas Safety Management Plan Part A and B
Further Required Preventative Methods	Training and simulated gas emergency drills – not carried out or managed
	Training for quicker response time – not carried out or managed
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 05	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
Failure of safety critical equipment	
Date reviewed: 25/02/2025	
Risk	Failure of safety critical equipment can have a severe impact on the safety of the gas network.
Caused By	Lack of/or poor maintenance
	Incorrect use of equipment
	Ageing equipment
Hazards Resulting from Risk	Lack of control over gas network, resulting in a gas incident
	Lack of control over gas network during a gas incident
Current Preventative Methods	Scheduled Maintenance
	Designed for purpose
	Regular operational training
Further Required Preventative Methods	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 06	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
Under-pressure in the gas system	
Date reviewed: 25/02/2025	
Risk	If at any point the pressure in a gas network drops below a certain level, gas safety regulators will stop the flow of gas. These regulators are fitted to gas appliances and in some instances will also be downstream of the gas meter into individual houses. There is also a regulator on the main intake to the site.
	If the pressure in a gas network, leading into a house or facility, drops below a certain level a gas safety regulator will terminate the flow of gas. This will cause the pilot lights to be extinguished. On this site, due to the multitude of buildings and houses, it may take up to 3 days to re-ignite all the systems.
Caused By	Gas leaks
	Poor gas network management
	Failure of Compressors
	Inadequate supply of gas in the system
	Failure of pressure control system
Hazards Resulting from Risk	Loss of gas supply
	Gas safety regulators being tripped (requires manually resetting on older models)
	Long recovery period
	Potential for air in the gas network
Current Preventative Methods	Scheduled Maintenance
	Designed for purpose
	Pressure monitoring
Further Required Preventative Methods	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 07	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
Over-pressure in the gas system	
Date reviewed: 25/02/2025	
Risk	If at any point the pressure in a gas network climbs above a certain level, gas safety regulators will stop the flow of gas. These regulators are fitted to gas appliances and in some instances will also be downstream of the gas meter into individual houses. There is also a regulator on the main intake to the site
	If the pressure in a gas network, leading into a house or facility, climbs above a certain level a gas safety regulator will terminate the flow of gas. This will cause the pilot lights to be extinguished. On this site, due to the multitude of buildings and houses, it may take up to 3 days to re-ignite all the systems.
Caused By	Failure of pressure control system
	Incorrect pipe/valve sizing
	Blockages in system
	Poor gas network management
Hazards Resulting from Risk	Rupture of gas pipes due to high pressure related
	Damage to valves and other control equipment
	Damage to seals and joints
	Loss of gas supply
Current Preventative Methods	Scheduled Maintenance
	Designed for purpose
	Pressure monitoring
Further Required Preventative Methods	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 08	
<div> <div>For: N/A for this site - one supply to one plant room with two boilers</div> <div>Approved by: Ian Bradley</div> </div>	
<div> <div>Failure in system during load shedding</div> <div>Date reviewed: 25/02/2025</div> </div>	
Risk	In the event of a gas supply emergency, load shedding can be used to stabilise the pressure in the system. However, if a section is isolated and the consumers on that branch use their gas supply the pressure in that branch will drop below acceptable levels and the pressure safety regulators will trip
Caused By	Insufficient communication between onsite parties and the end user
	Insufficient means of monitoring pressure
Hazards Resulting from Risk	
Current Preventative Methods	
Further Required Preventative Methods	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 09	
For: Trowbridge JCC ACF ATC	Approved by: Ian Bradley
General changes to the gas network	Date reviewed: 25/02/2025
Risk	If during the design phase the sizing of the system is under/oversized, it could result in under/over pressure scenarios.
	If during the installation of a gas network, the work is not carried out to the relevant British Standards and if the work is not undertaken by operatives trained and skilled to the same British Standards, failure may take place.
Caused By	Incorrect pipe sizing at design phase
	Underestimating impact on overall site gas supply
	Incorrect installation of plant and pipelines
	Under qualified gas operatives used for gas works
Hazards Resulting from Risk	Damage to pipelines and gas network plant and equipment
	Risk of causing a supply emergency
	Damage to persons & property
	Risk of Explosions & Fire
Current Preventative Methods	Using trained individuals to carry out work to the gas network
	Checking credentials of design authority for gas network redesign
	Refer to the Gas Safety Management Plan Part A and B
	Monitoring competence of gas network operatives
	Checking commissioning of completed works
Further Required Preventative Methods	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 10	
For: Trowbridge JCC ACF ATC	Approved by: Ian Bradley
Failure through PPM, general operation of the gas network plant/equipment and safety inspections	Date reviewed: 25/02/2025
Risk	Inadequate action during maintenance can cause failure in the system
	If safety inspections are not carried out regularly, the system may be vulnerable to failure
	The day-to-day operation of the system is vital to the overall performance of the gas network. If the day-to-day operation is not undertaken to industry standards, the gas network could be vulnerable to failure
Caused By	Gas plant & pipelines are not sufficiently maintained
	Scheduled activities do not take place.
	Operatives are insufficiently trained
	Inadequate co-ordination of operation
	Inadequate communication between onsite parties
	Inadequate planning of scheduled activities
	Inadequate inspection and testing of equipment
Hazards Resulting from Risk	Damage to pipelines and gas network plant and equipment
	Risk of causing a supply emergency
	Damage to persons & property
	Risk of Explosions & Fire
Current Preventative Methods	Monitored and maintained
	Using trained individuals to carry out work to the gas network
	Using qualified operatives
	Monitoring competence of gas network operatives
Further Required Preventative Methods	Following PPM schedules to carry out works – not carried out or managed.
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 11	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
Emergency Shutdowns	
Date reviewed: 25/02/2025	
Risk	Emergency shutdowns can be used in the event of a gas incident which warrants the gas network or part thereof to be shut down. If this process fails, it can have a severe impact on the resolution of the incident
Caused By	Failure of emergency shutdown valves Ageing emergency shutdown valves Lack of sufficient facilities for segregated shutdowns
Hazards Resulting from Risk	Escalating hazard cause by existing emergency Damage to pipelines and gas network plant and equipment Risk of causing a supply emergency Long down time
Current Preventative Methods	Site to immediately contact RFCA Emergency Service Provider on 0800 317 960 Contact site Gas Responsible Person or Gas Safety Manager Refer to the Gas Safety Management Plan Part A and B
Further Required Preventative Methods	Following PPM schedules to carry out works – not carried out or managed
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 12	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
Interface with Gas Transporter	
Date reviewed: 25/02/2025	
Risk	If interfaces between the site team and the gas transporter are not managed carefully, the fallout from gas incidents can become more pronounced
Caused By	Poor response time by EGDN Poor communication between onsite parties and EGDN Poor coordination of onsite parties and EGDN Poor communication of procedures
Hazards Resulting from Risk	Damage to pipelines Resultant hazards from any gas incident can escalate Risk of causing a supply emergency Damage to persons & property Risk of Explosions & Fire
Current Preventative Methods	Communication with EGDN
Further Required Preventative Methods	Training and simulated gas emergency drills – not carried out or managed
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 13	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
Interface with Consumer	
Date reviewed: 25/02/2025	
Risk	If communication between the site team and the end user are not carefully established, the fallout from gas shortages could result in the system having to be purged and the pilot lights re-ignited. On a large site such as this, it could take up to three days to re-ignite all pilot lights.
Caused By	Poor communication Lack of understanding No method of checking on gas usage
Hazards Resulting from Risk	Risk of causing a supply emergency Loss of pressure in system Long recovery period Potential for air in the gas network
Current Preventative Methods	Contact sites Gas Responsible Person or Gas Safety Manager Refer to the site Gas Safety Management Plan Part A and B Communication with all departments on the site
Further Required Preventative Methods	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 14	
For: Trowbridge JCC ACF ATC	
Approved by: Ian Bradley	
Interface with Emergency Services	
Date reviewed: 25/02/2025	
Risk	The first responder has a duty to minimise the risk to the surrounding area upon arrival. If the gas incident is within an enclosed area, isolating the system is the correct course of action. However, in a open, well-ventilated area, isolating the system may not be necessary, and could cause secondary hazards
Caused By	Poor communication
	Lack of understanding
Hazards Resulting from Risk	Risk of causing a supply emergency
	Causing the need to purge systems
	Long downtime of gas network
Current Preventative Methods	Use of the Gas Safety Management Plan
	Monitored and maintained
Further Required Preventative Methods	Providing training to the Emergency Services, so that they will be able to better tackle gas incidents – not carried out or managed
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

Site Reviewed Model Risk Assessment - 15	
<div> <div>For: Trowbridge JCC ACF ATC</div> <div>Approved by: Ian Bradley</div> </div>	
<div> <div>Natural Disasters, civil disturbances, other unforeseeable events</div> <div>Date reviewed: 25/02/2025</div> </div>	
Risk	The risk of unforeseeable events causing gas related incidents cannot be planned for. However, it is possible to minimise the impact of the resulting hazards
Caused By	Explosions Ground tremors Gas pipe sabotage
Hazards Resulting from Risk	Damage to pipelines caused by uncontrolled escaping gas Risk of causing a supply emergency Damage to persons & property Risk of Explosions & Fire Pollution of environment Purging maybe required after corrective action
Current Preventative Methods	High security levels Immediately contact RFCA emergency gas contact number 0800 317 960 in the event of a gas escape or damaged pipe Contact site Gas Responsible Person or Gas safety Manager Refer to the Gas Safety Management Plan Part A and B
Further Required Preventative Methods	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.

ANNEX D

ANNEX D - ADDITIONAL SITE-SPECIFIC RISK ASSESSMENT TEMPLATE

Please copy and add further sheets as required

Additional Site-specific Risk Assessment 16	
For:	Approved by:
	Date reviewed:
Risk	
Caused By	
Hazards Resulting from Risk	
Current Preventative Methods	
Further Required Preventative Methods	
Audits	In the event of an incident, near miss or any other hazardous occurrence this RA must be reviewed and updated as appropriate.