

Copyright © Trimble 2018, FastTest Plus v2018.0.0, IJ Cannings & Son Ltd

I. Supply Characteristics and Earthing Arrangements				Nature of Supply Parameters		Supply protective device	
Earthing Arrangements	Number and Type of Live Conductors						
TN-S	N/A	a.c.	☒	d.c.	N/A	Nominal Voltage $U^{(1)}$	400 V
TN-C-S	☒	1-Phase (2 wire)	N/A	1-Phase (3 wire)	N/A	Nominal Voltage $U_0^{(1)}$	230 V
TN-C	N/A	2-Phase (3 wire)	N/A	3 Wire	N/A	Nominal frequency $f^{(1)}$	50 Hz
TT	N/A	3-Phase (3 wire)	N/A	3-Phase (4 wire)	☒	Prospective fault current $I_{pf}^{(2)}$	6.80 kA
IT	N/A	Other	N/A			External loop impedance $Z_e^{(2)}$	0.07 Ω
Confirmation of supply polarity				☒		Number of supplies	1
				(Note: (1) by enquiry, (2) by enquiry or by measurement)		BS(EN) 1361 Fuse HBC Type 2 Nominal current rating 100 A Short circuit capacity 33 kA	

J. Particulars of Installation Referred to in the Report			
Means of earthing		Details of installation Earth Electrode (where applicable)	
Distributor's facility	☒	Type (e.g. rod(s), tape etc.)	N/A
Installation earth electrode	N/A	Resistance to Earth	N/A Ω
		Location	N/A
		Method of measurement	N/A

Main Protective Conductors				Tick boxes and enter details as applicable	
Earthing Conductor	Material	Copper	csa	16	mm ²
				Continuity Verified	☒
				Connection Verified	☒
Main protective bonding conductors	Material	Copper	csa	10	mm ²
				Continuity Verified	☒
				Connection Verified	☒
Bonding of Incoming Service				Maximum Demand (Load)	
Water installation pipes	☒	Gas installation pipes	N/A	Structural Steel	N/A
Oil installation pipes	N/A	Lightning protection	N/A		
Please State				80 Amps	
Other incoming service(s)				Protective measure(s) against electric shock	
N/A				ADS	

Main Switch / Switch-Fuse / Circuit-Breaker / RCD					
Location	Main cutout box front of building			Current rating	80 A
Type BS(EN)	88	No of poles	3	Fuse/Device rating or setting	80 A
Supply Conductors material	Copper	Supply Conductors csa	25	Voltage rating	400 V
				if RCD main switch	
				Rated residual operation current, $I_{\Delta n}$	N/A mA
				Rated time delay	N/A ms
				RCD Operating time at, $I_{\Delta n}$	N/A ms

K. Observations		
Referring to the attached schedule(s) of Inspection and Test Results, and subject to the limitations specified at the Extent and Limitations of the Inspection and testing section.		
No remedial action is required. ☒ The following observations are made ☒		
Item No	Observations	Code
1	Cct 5L3- 30ma RCD/RCBO failed to operate under fault conditions.	C2
2	1x DB front cover single blank faulty.	C2
3	Hand dryer in disabled WC not working.	C3
One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.		
C1 - Danger present. Risk of injury. Immediate remedial action required	0	
C2 - Potentially dangerous - urgent remedial action required	2	
C3 - Improvement recommended	1	
F1 - Further investigation required without delay	0	

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

Note: this form is suitable for many types of smaller installations, not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome		Comments	
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)													
1.1	Service cable										✓		No	
1.2	Service head										✓		No	
1.3	Earthing arrangement										✓		No	
1.4	Meter tails										✓		No	
1.5	Metering equipment										✓		No	
1.6	Isolator (where present)										✓		No	
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)										N/A		No	
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)													
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)										✓		No	
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)										N/A		No	
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)										✓		No	
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)										✓		No	
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)										✓		No	
3.6	Confirmation of main protective bonding conductor sizes (544.1)										✓		No	
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)										✓		No	
3.8	Accessibility and condition of other protective bonding connections (543.3.1; 543.3.2)										✓		No	
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)													
4.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)										✓		No	
4.2	Security of fixing (134.1.1)										✓		No	
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)										✓		No	
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)										✓		No	
4.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)										✓		No	
4.6	Presence of main linked switch (as required by 462.1.201)										✓		No	
4.7	Operation of main switch (functional check) (643.10)										✓		No	
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (643.10)										✓		No	
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)										✓		No	
4.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)										✓		No	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit/distribution board (514.14)										✓		No	
4.12	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)										N/A		No	
4.13	Presence of other required labelling (please specify) (Section 514)										✓		No	
4.14	Compatibility of protective devices, bases and other components; correct type and rating (No signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)										✓		No	
4.15	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.3)										✓		No	
4.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)										✓		No	
4.17	Protection against electromagnetic effects where cables enter consumer unit/distribution board/enclosures (521.5.1)										✓		No	
4.18	RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.5.2; 531.2)										✓		No	
4.19	RCD(s) provided for additional protection/requirements - includes RCBOs (411.3.3; 415.1)										✓		No	
4.20	Confirmation of indication that SPD is functional (651.4)										N/A		No	
4.21	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)										✓		No	
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)										N/A		No	
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)										N/A		No	
5.0	FINAL CIRCUITS													
5.1	Identification of conductors (514.3.1)										✓		No	
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)										✓		No	
5.3	Condition of insulation of live parts (416.1)										✓		No	

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome			Comments
5.0	FINAL CIRCUITS (Continued)													
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)										✓			No
5.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)										✓			No
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)										✓			No
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)										✓			No
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)										✓			No
5.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)										✓			No
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)										✓			No
5.10	Concealed cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)										✓			No
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6.204)										✓			No
5.12	Provision of additional requirements for protection by RCD not exceeding 30 mA:													
5.12.1	For all socket-outlets of rating 32 A or less, unless an exception is permitted (411.3.3)										✓			No
5.12.2	For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)										✓			No
5.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)										✓			No
5.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)										✓			No
5.12.5	Final circuits supplying luminaires within domestic (household) premises (411.3.4)										N/A			No
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)										✓			No
5.14	Band II cables segregated/separated from Band I cables (528.1)										✓			No
5.15	Cables segregated/separated from communications cabling (528.2)										✓			No
5.16	Cables segregated/separated from non-electrical services (528.3)										✓			No
5.17	Termination of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)													
5.17.1	Connections soundly made and under no undue strain (526.6)										✓			No
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)										✓			No
5.17.3	Connections of live conductors adequately enclosed (526.5)										✓			No
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)										✓			No
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2(v))										✓			No
5.19	Suitability of accessories for external influences (512.2)										✓			No
5.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)										✓			No
5.21	Single-pole switching or protective devices in line conductors only (132.14.1;530.3.3)										✓			No
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER													
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)										N/A			No
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)										N/A			No
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)										N/A			No
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)										N/A			No
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3 m from zone 1 (701.512.3)										N/A			No
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)										N/A			No
6.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)										N/A			No
6.8	Suitability of current-using equipment for particular position within the location (701.55)										N/A			No
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS													
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied.)									Number of locations	0			No

Inspected By

Name: Jamie Paulton

Date: 21/09/2020

Signature:



TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION	
Location of Distribution Board	Main cutout box (square D)	Supply to distribution board is from: N/A	Associated RCD (if any) BS(EN) N/A RCD No of Poles N/A RCD Rating N/A mA
Distribution board designation	SwF DB 1	No of phases N/A Nominal Voltage N/A V Overcurrent protective device for the distribution circuit Type BS(EN) N/A Rating N/A A	

[illegible]

A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

Board Tests

TO BE COMPLETED IN EVERY CASE

☒

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED
DIRECTLY TO THE ORIGIN OF THE INSTALLATION

N/A

 Ω

Ip

N/A

kA

Clearing times of associated RCD (if any) At $I_{\Delta n}$

N/A

ms

TEST INSTRUMENTS (SERIAL NUMBERS) USED
--

225710

RCD

225710

225710

N/A

225710

N/A

Details of circuits and/or equipment vulnerable to damage when testing

Circuit Tests

[illegible]

Tested By _____

I. B. Lutz

Approved Electrician

Jamie Paulton

21/09/2020

Board Details															
TO BE COMPLETED IN EVERY CASE					ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION										
Location of Distribution Board	Main entrance corridor by door. (Control gear direct/Lewden)				Supply to distribution board is from:	SubMains(SwF DB 1 , 1/TP)			Associated RCD (if any)						
Distribution board designation	DB 1				No of phases	3		Nominal Voltage	400		V		BS(EN)	N/A	
					Overcurrent protective device for the distribution circuit								RCD No of Poles	N/A	
					Type BS(EN)	88-2 Fuse HRC		Rating	80		A		RCD Rating	N/A mA	
Circuit Details															
Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times (s)	Overcurrent protective device					RCD	Maximum permitted Zs (Ω)	
					Live mm ²	cpc mm ²		BS(EN)	AFDD	Type	Rating (A)	Short circuit capacity (kA)			Operating current (Δn)
1/L1	Heaters 1st floor A&B classrooms	A	B	2	2.5	1.5	0.4	61009 RCD/RCBO		B	20	6	30	1667	
1/L2	Heaters 1st floor Corridor and office 2	A	B	2	2.5	1.5	0.4	61009 RCD/RCBO		B	20	6	30	1667	
1/L3	Heaters 1st floor Wcs	A	B	2	1.5	1	0.4	61009 RCD/RCBO		B	10	6	30	1667	
2/L1	Water heater female WC	A	B	1	2.5	1.5	0.4	61009 RCD/RCBO		B	16	6	30	1667	
2/L2	Water heater male WC	A	B	1	2.5	1.5	0.4	61009 RCD/RCBO		B	16	6	30	1667	
2/L3	Water heater servery	A	B	1	2.5	1.5	0.4	61009 RCD/RCBO		B	16	6	30	1667	
3/L1	Hand dryers 1st floor WCs	A	B	2	2.5	1.5	0.4	61009 RCD/RCBO		B	20	6	30	1667	
3/L2	Hand dryer disabled WC	A	B	2	2.5	1.5	0.4	61009 RCD/RCBO		B	10	6	30	1667	
3/L3	Heaters parade room	A	B	2	2.5	1.5	0.4	61009 RCD/RCBO		B	20	6	30	1667	
4/L1	Heaters corridor	A	B	2	2.5	1.5	0.4	61009 RCD/RCBO		B	16	6	30	1667	
4/L2	Lift supply	A	B	1	2.5	1.5	0.4	61009 RCD/RCBO		B	16	6	30	1667	
4/L3	Fire alarm	O	B	1	2.5	1.5	0.4	60898 MCB		B	16	10	N/A	2.18	
5/L1	Door closer PSU	A	B	1	1.5	1	0.4	61009 RCD/RCBO		B	16	6	30	1667	
5/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-	
5/L3	Sockets 1st floor radio room & class 2	A	B	6	2.5	1.5	0.4	61009 RCD/RCBO		B	20	6	30	1667	
6/L1	Sockets 1st floor A&B, corridor	A	B	6	2.5	1.5	0.4	61009 RCD/RCBO		B	20	6	30	1667	
6/L2	Sockets servery & corridor	A	B	3	2.5	1.5	0.4	61009 RCD/RCBO		B	20	6	30	1667	
6/L3	Sockets parade & office	A	B	8	2.5	1.5	0.4	61009 RCD/RCBO		B	20	6	30	1667	
7/L1	Lights 1st floor	A	B	9	1.5	1	0.4	61009 RCD/RCBO		B	6	6	30	1667	
7/L2	Lights ground floor	A	B	17	1.5	1	0.4	61009 RCD/RCBO		B	6	6	30	1667	
7/L3	Disabled alarm	A	B	1	1.5	1	0.4	61009 RCD/RCBO		B	6	6	30	1667	
8/L1	Heating control	A	B	1	1.5	1	0.4	61009 RCD/RCBO		B	6	6	30	1667	
8/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-	
8/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-	
Wiring Code															
A	B	C	D	E	F	G	H	O							
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other							

Board Tests																
TO BE COMPLETED IN EVERY CASE											TEST INSTRUMENTS (SERIAL NUMBERS) USED					
Correct supply polarity confirmed ☒					Phase sequence confirmed (where appropriate) ☒											
Supplementary Conductors ☒																
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION											Earth fault loop impedance 225710 RCD 225710					
Zs 0.07 Ω Ip 6.80 kA											Insulation resistance 225710 Multi-function N/A					
Operating times of associated RCD (if any) At I Δ n N/A ms											Continuity 225710 Other N/A					
Details of circuits and/or equipment vulnerable to damage when testing																
None																
Circuit Tests																
Circuit number and phase	Circuit Impedances Ω					Insulation resistance					Polarity (✓)	Maximum measured earth fault loop impedance Ω	RCD		AFDD Test button operation	Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Test Voltage	Live/Live MΩ	Live/Neutral MΩ	Live/Earth MΩ	Earth/Neutral MΩ			Operating time at I Δ n (ms)	Test button operation		
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂)	(R ₂)											
1/L1	N/A	N/A	N/A	0.63	N/A	500	N/A	200	200	200	✓	0.70	18	✓		NO
1/L2	N/A	N/A	N/A	0.69	N/A	500	N/A	200	200	200	✓	0.76	18	✓		NO
1/L3	N/A	N/A	N/A	0.60	N/A	500	N/A	200	200	200	✓	0.67	19	✓		NO
2/L1	N/A	N/A	N/A	0.53	N/A	500	N/A	200	200	200	✓	0.60	18	✓		NO
2/L2	N/A	N/A	N/A	0.75	N/A	500	N/A	200	200	200	✓	0.82	22	✓		NO
2/L3	N/A	N/A	N/A	0.32	N/A	500	N/A	200	200	200	✓	0.39	24	✓		NO
3/L1	N/A	N/A	N/A	0.73	N/A	500	N/A	200	200	200	✓	0.80	18	✓		NO
3/L2	N/A	N/A	N/A	0.58	N/A	500	N/A	200	200	200	✓	0.65	18	✓		NO
3/L3	N/A	N/A	N/A	0.52	N/A	500	N/A	200	200	200	✓	0.59	22	✓		NO
4/L1	N/A	N/A	N/A	0.15	N/A	500	N/A	200	200	200	✓	0.22	18	✓		NO
4/L2	N/A	N/A	N/A	0.58	N/A	500	N/A	200	200	200	✓	0.65	19	✓		NO
4/L3	N/A	N/A	N/A	0.12	N/A	500	N/A	200	200	200	✓	0.19	N/A	N/A		NO
5/L1	N/A	N/A	N/A	0.55	N/A	500	N/A	200	200	200	✓	0.62	18	✓		NO
5/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/L3	N/A	N/A	N/A	0.63	N/A	500	N/A	200	200	200	✓	0.72	Fail	✗		NO
6/L1	N/A	N/A	N/A	0.81	N/A	500	N/A	200	200	200	✓	0.88	28	✓		NO
6/L2	N/A	N/A	N/A	1.03	N/A	500	N/A	200	200	200	✓	1.10	28	✓		NO
6/L3	N/A	N/A	N/A	0.83	N/A	500	N/A	200	200	200	✓	0.90	18	✓		NO
7/L1	N/A	N/A	N/A	1.87	N/A	500	N/A	Lim	200	200	✓	1.94	18	✓		NO
7/L2	N/A	N/A	N/A	0.94	N/A	500	N/A	Lim	200	200	✓	1.01	19	✓		NO
7/L3	N/A	N/A	N/A	0.55	N/A	500	N/A	200	200	200	✓	0.62	18	✓		NO
8/L1	N/A	N/A	N/A	0.12	N/A	500	N/A	200	200	200	✓	0.19	18	✓		NO
8/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Tested By																
Signature							Position		Approved Electrician							
Name		Jamie Paulton					Date of testing		21/09/2020							

CONDITION REPORT GUIDANCE FOR RECIPIENTS (to be appended to the Report)

This Report is an important and valuable document which should be retained for future reference.

1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. The person ordering the Report should have received the 'original' Report and the inspector should have retained a duplicate.
3. The 'original' Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested six-monthly. **For safety reasons it is important that this instruction is followed.**
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ('Danger present'), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ('Potentially dangerous'), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit/distribution board.