ELECTRICAL INSTALLATION CONDITION REPORT



	4.1. 01							
A. Details	of the Client/Person Ord	ering the	Report	B. R	eason for Produ	ucing this Repo	rt	
Client:	Wessex RFCA			Pu	rpose of this report:			
Address:	Mount House			5	Yearly periodic	electrical test and	inspec	tion report for
	Mount Street			ir	nsurance purpose	es.		
	Taunton							
	Somerset			L				
	TA1 3QE				te(s) on which Inspect d testing was carried or		0	
0.0.4.1					a testing mas same a			
C. Details	of the Installation which	is the Sub	oject of this Report			Domestic	Comme	rcial Industrial
Installation:	Wooton Under Edge Cad	ets			escription of remises:	N/A	N/A	N/A
Occupier:	Wessex RFCA			0	ther:			
Address:	School Road				Cadet Training F	acility		
, tau. 555.	Wotton-Under-Edge			E	stimated age of wiring	system:		25 yrs
	Gloucestershire				vidence of alterations		If yes	25 yis
	Cioacoctororino	G	L12 7JL		r additions:	✓	estimate	d Age 5 yrs
Record of	✓ Records held By:	Wessex	PECA			Date of prev	vious	Not Known
Installation ava		Wessex	REGA			inspection:		40t Itilowii
D. Extent a	and Limitations Inspectio	n and Tes	sting					
	trical Installation covered by this re			Agreed	limitations including t	he reasons (See regul	ation 653	.2)
Full period	dic electrical test and inspe	ction report	t in accordance	R1+	R2 tests are calc	ulated.		
See Add	litional Page							
				Callı	um Harrison			
			Agreed with name	June	am riamoon			
	mitations including the reasons (Se	e page No	N/A)					
None								
TI	16 6 16 2 11 0 11 0 1					W D07074 0040 (IET	W D	
to July 2018	n and testing detailed in this report	and accompa	nying schedules have bee	n carrie	ed out in accordance w	ith BS/6/1:2018 (IET	Wiring R	egulations) as amended
It should be no	oted that cables concealed within to							
other electrica	d unless specifically agreed betwe al equipment.	en the client a	and inspector prior to the ir	ispectio	on. An inspection shou	id be made within an a	accessible	e root space nousing
E. Summa	ry of the Condition of the	Installati	On General conditi	on of th	e installations (In term	s of electrical safety)		
The instal	lation is in need of moderni	sation in o	rder for it to comply v	with cı	ırrent wiring regu	lations Particular	attenti	on should be
	litional Page		radi for it to comply t		anoni wiing roga	idiono. i ditiodidi	attoriti	on one and be
			*An unacticfactory acc		nt indicator that dange	araus (anda C1) and/a	- natantia	lly domestic (and
Overall asses	ssment of the installation Uns	atisfactory	C2) conditions have b			erous (code C1) and/o	r potentia	lly dangerous (code
F. Recomr	mendations							
	erall assessment of the suitability o					ORY, I recommend	that any	observations classified as
	nt' (code C1) or 'Potentially danger vithout delay is recommended for o							
	assified as 'Improvement recomme	ended' (code (C3) should be given due co	nsidera	ation.			sted by 06/11/2025
	,	•	edial action being taken					
G. Declara			for the inspection and test kercised reasonable skill a					
	information in this repor	t, including the	e observations and attache ted extent and limitations	ed sche	dules, provides an acc			
T1: T:41 -	IJ Cannings& Son Ltd,	Scoulit tile sta	ned extern and infinations	iii seciid	of this report.			
Trading Title and address	Stratford house,				NICE	IC Enrolment Number	9140	
	Waterbridge Court,							
	Exeter, Devon, EX2 8EX				Bra	nch No. (If Applicable	N/A	
Inspected and	d tested by:							
Name Cal	lum Harrison	Position	Qualifying Supervis	sor	Signature	Alin	Date	06/11/2020
Report autho	rised for issue by:		, , ,			U		
Name Cal	lum Harrison	Position	Qualifying Supervis	sor	Signature	gli	Date	06/11/2020
L Cobodu	lo(c) The effects to be 1.1.) are rest. Co			lid anhered to	etteche il to it		
H. Schedu			his document and this rep			attached to it.		
N/A	Schedule(s) of inspection a	nd N/A	Schedule(s)	of test re	esults are attached			

I. Supply	Chara	acteristics	and E	arthing /	Arrangen	nents										
Earthing Arrangeme	ng				Live Conduc			Nature of S	Supply	y Param	eters		Supply	protective d	levice	
	N/A	a.c.	✓			d.c.	N/A	Nominal	U ⁽¹⁾	400	V	BS(EN)				
		1-Phase		1-Phase		2		Voltage Nominal	U ₀ ⁽¹⁾	230	V	1361 F	use HE	3C		
TN-C-S	Y	(2 wire)	N/A	(3 wire)	N/A	2 Wire	N/A	Voltage			V					
TN-C	N/A	2-Phase	N/A			3	N/A	Nominal frequency	f ⁽¹⁾	50	Hz	Туре				
		(3 wire)	ايظا			Wire	الظا	Prospective fault current	lpf ⁽²⁾	2.16	kA	2				
TT I	N/A	3-Phase (3 wire)	N/A	3-Phase (4 wire)	✓	Other	N/A	External loop impedance	n m	0.11	Ω	Nominal current ra		100	A	
IT I	N/A	Other N/A						Number of		1		Short circ	J			
		Confirmation	n of supply	y polarity		✓		supplies (Note: (1) by e		_	enquiry or	capacity		33	kA	
L Particu	ulars (of Installati	ion Re	ferred to	o in the R	eport		by measureme	ent)							
	s of eart		ОП-1-10	GII GG	/ III die			f installation Ea	arth El	ectrode	(where a	pplicable)				
Distributor's		√		e.g. rod(s),	N/A		Otta	Locat		N/A	` .	/piicux,				
facility Installation			tape etc	Í				LUCA	lion	-	•					
earth electro	ode N	N/A	Resistar Earth	nce to	N/A			Ω								
									nod of sureme	ent N/A	4					
Main Pro	tective	e Conduct	tors	Tick I	boxes and en	nter deta	ils as ap	plicable								
Earthing		Material		pper		csa	16	mm ²	Cr	ontinuity	Verified	—		Connection V	/erified	—
Conductor				ppc.		00				mu	VOIL			Comics	Gina	Ÿ
Main protection bonding conc		Material	Cor	pper		csa	10	mm ²	Co	ontinuity	/ Verified	✓		Connection V	'erified	✓
Bonding of			t-llation	St	-tural		·-htning			Maxir	mum Dem	and (Load))			
	pipes	✓ Gas ins	stallation pipes	N/A Sti	Steel N/		_ightning rotection			100		Amps				
Oil installa pi	ation Noipes	N/A			Plea	ase State	Э					sure(s) aga	ainst elect	ric shock		
				incoming service(s)	N/A N/A	4				ADS	3					
Main Swit	tch / S	Switch-Fus	se / Cir	cuit-Bre	aker / R0	CD										
Location	Ма	ains Position	n Office	;					Curre		100	А	Rated	if RCD main		
									rating	ıg e/Device	100		opera	tion current,	N/A	mA
										g or sett	100	A	I∆n Rated	time delay	N/A	ms
Type BS(EN	1) 609	947-2 MCC	В		No	lo of pole	s 2		Volta rating	•	230	V	RCD	Operating	N/A	me
Supply Conductors	Со	pper			Supply Conducto	ors 25		mm ²					time a		N/A	ms
material					csa											
K. Observ	vation	S														
Referring to t	the attac	hed schedule	(s) of Insp	pection and	Test Results	s, and su	ubject to t	the limitations sp	pecified	d at the l	Extent and	I Limitation	s of the Ir	nspection and	I testing	section.
No remedial	action is	required.	N/A	The follo	owing observa	ations ar	e made	✓								
Item No							Obs	servations							Co	de
1	DB1	, circuit 1, 2	2no swit	tched fus	sed spurs	contro!	lling hig	gh level halo	ogen h	neaters	s near si	ide Hall,	require	replacing,	, C	;2
		ty switch, ur														
2								WCs. Heate						-	С	2
				•				exposed part							-	
								D protection.	Also	the sw	/itched t	used spi	ur in the	• Men's	-	
One of the fo		servations					,	vations made ab	hove to	indicate	to the pe	rson(s) res	nonsible f	for the installa	ation the	
	_	or remedial act		Ilas boon a	illocated to c.	aun o			JOVE 1.	Illuioaco	to the pe.	3011(3) 135 _F	ponsible .	Of the motal	Ilion are	
C1 - Danger	r present	nt. Risk of injury	y. Immedia	ate remedia	al action requ	uired	0									
C2 - Potentia	ally dang	igerous - urgen	nt remedia	al action rec	beriup		2									
C3 - Improve	ement re	ecommended					7									
1				delay			0									

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition Unacceptable State C1 Improvement recommended C3 Investigation FI Not verified	N/V Limitation LIM Not applicable	e N/A			
Item No	Description	Outcome				
1.0	External condition of intake equipment (visual inspection only)					
1.1	Service cable	✓	No			
1.2	Service head	✓	No			
1.3	Earthing arrangement	√	No			
1.4	Meter tails	✓	No			
1.5	Metering equipment	✓	No			
1.6	Isolator (where present)	✓	No			
2.0	Presence of adequate arrangements for other sources					
2.1	Presence of alternative/additional supply warning notices at the origin of the installation	N/A	No			
3.0	Earthing and bonding arrangements					
3.1	Presence and condition of distributor's earthing arrangement	✓	No			
3.2	Presence and condition of earth electrode connection, where appropriate	N/A	No			
3.3	Confirmation of earthing conductor size	✓	No			
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	No			
3.5	Confirmation of main protective bonding conductor sizes	✓	No			
3.6	Condition and accessibility of main protective bonding conductor connections	✓	No			
3.7	Condition and accessibility of other protective bonding connections	✓	No			
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	No			
4.0	Consumer unit(s)/ Distribution board(s)					
4.1	Adequacy of working space/accessibility to consumer unit/ distribution board	✓	No			
4.2	Security of fixing	✓	No			
4.3	Condition of enclosure(s) in terms of IP rating	✓	No			
4.4	Condition of enclosure(s) in terms of fire rating	✓	No			
4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	No			
4.6	Presence of linked main switch	✓	No			
4.7	Operation of main switch(es) (functional check)	✓	No			
4.8	Operation of main switch (functional), main switch capable of being secured in the OFF position	✓	No			
4.9	Manual operation of circuit breakers and RCDs to prove disconnection (functional check)	✓	No			
4.10	Correct identification of circuits and protective devices	✓	No			
4.11	Presence of required charts and labels:					
4.11.1	Provision of diagram, chart, table or equivalent forms of information	✓	No			
4117	Warning notice of durable material indicating there are live parts which are not capable of being isolated by a single device	✓	No			
4.11.3	Periodic inspection notice positioned at or near the origin of the installation	✓	No			
4.11.4	Presence of RCD six-monthly test notice at or near consumer unit/distribution board	✓	No			
4.11.5	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit/distribution board	✓	No			
4.11.6	Presence of other required labelling provided	✓	No			
4.12	Compatibility of protective device(s), base(s) and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	No			
4.13	Single-pole switching or protective devices in the line conductors only	✓	No			
4.14	Protection against mechanical damage where cables enter consumer unit/ distribution board	✓	No			
4.15	Protection against electromagnetic effects where cables enter metallic consumer unit enclosure	✓	No			
4.16	RCDs provided for fault protection - includes RCBOs	✓	No			
4.17	RCDs provided for additional protection includes RCBOs	✓	No			
4.18	Confirmation of indication that SPD is functional	N/A	No			
4.19	Operation/adequacy of AFDD(s) where present	N/A	No			
4.20	Confirmation that conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure	✓	No			
4.21	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	No			
4.22	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	No			

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition Unacceptable condition State C1 Improvement State Further FI Not verified	N/V	Limitation	LIM	Not applicable	N/A		
Item No	Description		Outo	ome		Comments		
5.0	Distribution/final circuits							
5.1	Identification of conductors		,	/		No		
5.2	Cables correctly supported throughout		✓					
5.3	Condition of insulation of live parts		,	/		No		
5.4	Non-sheathed live conductors protected by enclosure in conduit, ducting or trunking (including confirmation the integrity of conduit and trunking systems)	of	,		No			
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation		•	/		No		
5.6	Protective devices, type and rated current are suitable for fault protection		١	/		No		
5.7	Presence and adequacy of circuit protective conductors		١	/		No		
5.8	Co-ordination between conductors and overload protection devices		١	/		No		
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences		١	/		No		
5.10	Cables adequately protected against mechanical damage and abrasion		,	/		No		
5.11	Provision of additional protection by 30 mA RCD for*:							
5.11.1	- all socket-outlets with a rated current not exceeding 32 A	$\overline{}$,	/		No		
5.11.2	- mobile equipment not exceeding a rating of 32 A for use outdoors		N.	/A		No		
5.11.3	- cables concealed in walls/partitions at a depth of less than 50 mm		C3 (see s	ectio	n K)	No		
5.11.4	- cables concealed in walls/partitions containing metal parts regardless of depth			/		No		
5.11.5	- all AC final circuits supplying luminaires within domestic household premises		N.	/Δ		No		
0	*Note: Older installations designed prior to BS 7671:2018 may not have been provided with RCDs fo	r additio				110		
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects					No		
5.13	Band II cables segregated/separated from Band I cables		N.	No				
5.14	Cables segregated/separated from communications cabling		1	No				
5.15	Cables segregated/separated from non-electrical services				No			
5.16	Termination of cables at enclosures:					NO		
5.16.1	Connections soundly made and under no undue strain	I				No		
5.16.2	No basic insulation of a conductor visible outside enclosure			,		No		
5.16.3					No			
	Connection of live conductors adequately enclosed				No			
5.16.4	Adequately connected at point of entry to enclosure	_						
5.17	Condition of accessories including socket-outlets, switches and joint boxes is satisfactory				No			
5.18	Suitability of accessories for external influences		•		No			
5.19	Adequacy of working space/accessibility to equipment				No			
5.20	Single-pole switching or protective devices in line conductors only					No		
6.0	Isolation and switching							
	In general:							
6.1.1	Presence and condition of appropriate devices					No		
6.1.2	Correct operation verified					No		
6.2	For isolation and switching for mechanical maintenance only:							
6.2.1	Capable of being secured in the OFF position where appropriate					No		
6.2.2	Acceptable location (local/remote)		<u>'</u>			No		
6.2.3	Clearly identified by position and/or durable marking(s)		١			No		
6.3	For isolation only:							
6.3.1	Warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device		•			No		
7.0	Current-using equipment (permanently connected)							
7.1	Condition of equipment in terms of IP rating					No		
7.2	Equipment does not constitute a fire hazard		•	/		No		
7.3	Enclosure not damaged/deteriorated so as to impair safety		•		No			
7.4	Suitability for the environment and external influences		•			No		
7.5	Security of fixing					No		
	Cable entry holes in ceiling above luminaires sized or sealed so as to restrict the spread of fire	1	,	/		No		
7.6	List number and location of luminaires inspected in section 9					1		

EC337601 - Master

Note: this form is suitable for many types of smaller installations not exclusively domestic.

	Acceptable condition		Limitation	LIM Not applicable	N/A		
tem No	Description		Outco	me	Comment		
7.7	Recessed luminaires (downlighters):						
7.7.1	Correct type of lamps fitted		N/A	4	No		
7.7.2	Installed to minimise build-up of heat		N/A				
7.7.3	No signs of overheating to surrounding building fabric		N/A	4	No		
7.7.4	No signs of overheating to conductors/terminations		N/A	4	No		
8.0	Location(s) containing a bath or shower						
8.1	Additional protection by RCD not exceeding 30mA for:						
8.1.1	- low voltage circuits serving the location		N/A	4	No		
8.1.2	- low voltage circuits passing through Zone 1 and Zone 2 not serving the location		N/A	4	No		
8.2	Where used as a protective measure, requirements for SELV or PELV are met		N/A	4	No		
8.3	Shaver sockets comply with BS EN 61558-2-5 (formerly BS 3535)		N/A	4	No		
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2018		N/A	A	No		
8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from Zone 1		N/A		No		
8.6	Suitability of equipment for external influences for installed location in terms of IP rating		N/A		No		
8.7	Suitability of equipment for installation in a particular zone		N/A	4	No		
9.0	Other special installations or locations						
nspect	ted By						
nspect	ted By Name: Callum Harrison Date:	06/11/2	2020				

Boai	rd Deta	ils																
٦	ГО ВЕ СО	MPLETE	ED IN EVERY CASE		ONLY 1	O BE CC)MPLETE	D IF TH	E DISTR	IBUTION BOARD OF THE INSTALL		NECTED	DIRECT	LY TO T	HE ORIG	SIN		
	tion of bution		Position Office tree Starbreaker .oad)		Supply t distributi board is No of ph	on from:	N/A N/A		Nomina	l Voltage N/A	BS(EN)	N/A	CD (if an	y)			
Distri	bution	DB 1			Overcur	ent prote	ctive devi	ice for the	e distribu	Poles	RCD No of Poles N/A							
board designation					Type BS(EN) N/A Rating N/A A							Rating N/A mA						
Circ	uit Deta	ils																
nber se				ing	ethod	ervec		cuit	ted ion		Overcurrent p device				RCD	S (Ω)		
Circuit number and phase		Circuit designation		Circuit designation		Type of wiring	Reference method	No of points served	Live mm ²	cpc mm ²	Max permitted disconnection times (s)	BS(EN)	AFDD	Туре	Rating (A)	Short circuit capacity (kA)	Operating current (∆n)	Maximum permitted Zs (Ω)
1/L3	Halogen He	eaters Cer	ntre	А	В	4	6	2.5	0.4	60898 MCB		С	32	10	N/A	0.68		
2/L3	Halogen He	eaters Nea	ar & Office Panel Heate	- A	В	3	4	1.5	0.4	60898 MCB		С	16	10	N/A	1.37		
3/L3	Halogen He	eaters Far	•	Α	В	2	4	1.5	0.4	60898 MCB		С	20	10	N/A	1.09		
4/L3	Wcs, Dowr	nflow Heat	ers & Element Heaters	А	В	4	4	1.5	0.4	60898 MCB		В	16	10	N/A	2.73		
5/L3	Timer/Cont	tactor Hea	ting	А	В	1	1.5	1	0.4	60898 MCB		В	6	10	N/A	7.28		
6/L3	L3 Lighting Near Hall, Office, Store & External				В	7	1	1	0.4	60898 MCB		В	6	10	N/A	7.28		
7/L3	Lighting Fa	r Hall WC	s & Servery	А	В	9	1	1	0.4	60898 MCB		В	6	10	N/A	7.28		
8/L3	Sockets Ne	ear		А	В	3	2.5	1.5	0.4	60898 MCB		В	20	10	30	2.19		
9/L3	Sockets Fa	ır & Ext Liç	ght	А	В	3	2.5	1.5	0.4	60898 MCB		В	20	10	30	2.19		
10/L3	Socket & V	Vater Heat	ter Kitchen	A	В	2	2.5	1.5	0.4	60898 MCB		В	20	10	30	2.19		
11/L3	Water Hea	ter & Hand	d Dryer Mens WC	A	В	2	2.5	1.5	0.4	60898 MCB		В	20	10	30	2.19		
12/L3	Water Hea	ter & Hand	d Dryer Ladies WC	A	В	2	2.5	1.5	0.4	60898 MCB		В	20	10	30	2.19		
					+													
					+	+												
					-													
					+													
					+-	1	-											
\ 0.4:																		
VVirir	ng Code															,		
	<i></i>	4	В	С		D		E		F	G		Н		0			
	PVC cables PVC PVC in in in cables metallic non-n		PVC cab in non-met condu	Ccables PVC cables PVC cable in in in metallic metallic non-metal		allic	PVC/SWA XLPE/SWA cables cables		Mineral insulated cables		Other							

EC337601 - Master

Board 1	Tests															
		TO BE CO	OMPLETED) IN EVERY	CASE				TES	ET INSTRI	MENT	S (SERIAL N	LIMBERS	LISED		
Correct s	supply pola	arity confirmed	d 🗸	Phase se	equence co	nfirmed	√			31 INSTITU	JIVILIN I	O (OLIVIAL IV	OIVIDLING) USLD		
Su	pplementa	ary Conductors	s 🗸	(where a	ppropriate)		Ť	Earth fau		5701		RCD	2257	701		
ONLY TO		MPLETED IF T					ECTED	impedan Insulation	ce 22	5701		Multi-	N/A			
Zs N/								resistano	e			function	511			
		associated R			/A m	ns		Continuit	y 225	5701		Other	N/A			
		ıits and/or				o dama	ge									
N/A																
Circuit 7	Tests	O.										1				
		Circ	uit Impedar Ω	ices			Insul	ation resis	tance			Mandana	RC	D	ton	l le
Circuit number and		g final circuits easure end to		All cire (At least colu to be con	st one ımn	Test	Live/	Live/	Live/	Earth/	Polarity (v)	Maximum measured earth fault loop	Operating time at I∆ n (ms)	Test button operation	AFDD Test button operation	Remarks see continuation sheet
phase	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R _{1 + R₂)}	(R ₂)	Voltage	Live MΩ	Neutral MΩ	Earth MΩ	Neutral MΩ	۵	impedance Ω	perat : I∆ n	Test	AFDE	see
1/L3	N/A	N/A	N/A	0.11	N/A	500	N/A	200	200	200	1	0.22	N/A	N/A		NO
2/L3	N/A	N/A	N/A	0.23	N/A	500	N/A	200	200	200	·	0.34	N/A	N/A		NO
3/L3	N/A	N/A	N/A	0.29	N/A	500	N/A	200	200	200	v	0.40	N/A	N/A		NO
4/L3	N/A	N/A	N/A	0.35	N/A	500	N/A	200	200	200	✓	0.46	N/A	N/A		NO
5/L3	N/A	N/A	N/A	0.10	N/A	500	N/A	200	200	200	1	0.21	N/A	N/A		NO
6/L3	N/A	N/A	N/A	0.69	N/A	500	N/A	200	200	200	1	0.80	N/A	N/A		NO
7/L3	N/A	N/A	N/A	0.57	N/A	500	N/A	200	200	200	1	0.68	N/A	N/A		NO
8/L3	N/A	N/A	N/A	0.30	N/A	500	N/A	200	200	200	1	0.41	52	1		NO
9/L3	N/A	N/A	N/A	0.39	N/A	500	N/A	200	200	200	1	0.50	52	1		NO
10/L3	N/A	N/A	N/A	0.28	N/A	500	N/A	200	200	200	1	0.39	52	1		NO
11/L3	N/A	N/A	N/A	0.59	N/A	500	N/A	200	200	200	1	0.70	52	1		NO
12/L3	N/A	N/A	N/A	0.52	N/A	500	N/A	200	200	200	✓	0.63	52	✓		NO
Tested	Ву															
Signa	iture			glii-				Position		Qualifyi	ng Su	pervisor				
Name	;	Callur	m Harriso	n				Date of testing		06/11/2	020					

Extent of Electrical Installation covered by this report, Continued. from page 1
with IEE regulations, BS7671,
est and inspect, guidance note 3.
General condition of the installations (In terms of electrical safety), Continued. from page 1
given to the Dimplex Coldwatcher heaters which have been installed low level in the WCs, no RCD
protection and in very close proximity to the urinals.

Observations Continued from Page 2

Item No	Description	Code
	WC is faulty and requires replacing.	
3	DB1, circuit 6, no 30mA RCD protection for cables buried in walls.	C3
4	DB1, circuits 6&7, 8no T8 type fluorescent fittings are showing signs of deterioration, recommend LED type	C3
	battens are installed in place.	
5	DB1, circuit 8, no discrimination between 30mA RCDs, office socket outlet it RCD type as well as the final circuit	C3
	being 30mA RCD protected. Recommend replacing the socket for a standard twin socket outlet.	
6	No surge arrestor for the installation.	C3
7	5.0 Distribution/final circuits 5.11.3 - cables concealed in walls/partitions at a depth of less than 50 mm	C3
8	DB1, circuits 1-7 have no 30mA RCD protection.	C3
9	Distribution Board 1 (Crabtree Starbreaker Split Load type) is at capacity.	C3
I		

Code Key

- C1 Danger present. Risk of injury. Immediate remedial action required
- C2 Potentially dangerous urgent remedial action required
- C3 Improvement recommended
- FI Further investigation required without delay

CONDITION REPORT GUIDANCE FOR RECIPIENTS

(to be appended to the Report)

This Report is an important and valuable document which should be retained for future reference.

- 1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
- The person ordering the Report should have received the 'original' Report and the inspector should have retained a duplicate.
- 3. The 'original' Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
- Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested six-monthly. For safety reasons it is important that this instruction is followed.
- 5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
- 6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
- 7. For items classified in Section K as C1 ('Danger present'), the safety of those using the installation is at risk, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
- 8. For items classified in Section K as C2 ('Potentially dangerous'), the safety of those using the installation may be at risk and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
- 9. Where it has been stated in Section K that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
- 10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit/ distribution board.