

# ELECTRICAL INSTALLATION CONDITION REPORT

EC647505 - Master



<b>A. Details of the Client/Person Ordering the Report</b>		<b>B. Reason for Producing this Report</b>	
Client:	Wessex RFCA	Purpose of this report: 5 Yearly periodic electrical test and inspection report for an installation for insurance purposes.	
Address:	Wessex RFCA Mount Street Taunton Somerset TA1 3QE	Date(s) on which Inspection: and testing was carried out 13/09/2017	
<b>C. Details of the Installation which is the Subject of this Report</b>			
Installation:	Wyvern Barracks Building 6	Description of premises:	Domestic N/A Commercial N/A Industrial N/A
Occupier:	Wyvern Barracks Building 6 (Guards Room)	Other:	Guards room
Address:	6th Battalion the Rifles HQ Barrack Road Exeter Devon EX2 6AE	Estimated age of wiring system:	15 yrs
Record of Installation available:	<input checked="" type="checkbox"/>	Evidence of alterations or additions:	<input checked="" type="checkbox"/> If yes estimated Age 5 yrs
Records held By:	I J Cannings	Date of previous inspection:	27/06/2012
<b>D. Extent and Limitations Inspection and Testing</b>			
Extent of Electrical Installation covered by this report: The complete installation in accordance to IEE wiring --See Additional Page--		Agreed limitations including the reasons (See regulation 634.2) R1 + R2 tests are calculated.	
Operational Limitations including the reasons (See page No N/A )		Agreed with name Andy Palmer	
None			
This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS7671:2008 (IET Wiring Regulations) as amended to July 2015 It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.			
<b>E. Summary of the Condition of the Installation</b>		General condition of the installations (In terms of electrical safety)	
The general condition of the electrical installation is okay, however there are some improvements recommended to bring installation --See Additional Page--			
Overall assessment of the installation	Satisfactory	*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.	
<b>F. Recommendations</b>			
Where the overall assessment of the suitability of the installation for continued use above is stated as SATISFACTORY, I recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (code FI). Observation classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken I recommend that the installation is further inspected and tested by 13/09/2022			
<b>G. Declaration</b>			
I, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by My signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.			
Trading Title and address	I J Cannings & Son Ltd, Stratford House, Waterbridge Court, Exeter, Devon, EX2 8EX	NICEIC Enrolment Number	9140
		Branch No. (If Applicable)	0
<b>Inspected and tested by:</b>			
Name	Lewis Conabeer	Position	Approved Electrician
Signature		Date	13/09/2017
<b>Report authorised for issue by:</b>			
Name	David Tucker	Position	Contracts Manager
Signature		Date	13/09/2017
<b>H. Schedule(s)</b> The attached schedule(s) are part of this document and this report is valid only when they are attached to it.			
2	Schedule(s) of inspection and	2	Schedule(s) of test results are attached

## I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements	Number and Type of Live Conductors				Nature of Supply Parameters		Supply protective device	
TN-S <input type="text" value="N/A"/>	a.c. <input checked="" type="checkbox"/>		d.c. <input type="text" value="N/A"/>		Nominal Voltage $U^{(1)}$ <input type="text" value="N/A"/> V	BS(EN) 60947-2 MCCB		
TN-C-S <input checked="" type="checkbox"/>	1-Phase (2 wire) <input type="text" value="N/A"/>	1-Phase (3 wire) <input checked="" type="checkbox"/>	2 Wire <input type="text" value="N/A"/>		Nominal Voltage $U_0^{(1)}$ <input type="text" value="230"/> V			
TN-C <input type="text" value="N/A"/>	2-Phase (3 wire) <input type="text" value="N/A"/>		3 Wire <input type="text" value="N/A"/>		Nominal frequency $f^{(1)}$ <input type="text" value="50"/> Hz	Type <input type="text" value="N/A"/>		
TT <input type="text" value="N/A"/>	3-Phase (3 wire) <input type="text" value="N/A"/>	3-Phase (4 wire) <input type="text" value="N/A"/>	Other <input type="text" value="N/A"/>		Prospective fault current $I_{pf}^{(2)}$ <input type="text" value="2.65"/> kA	Nominal current rating <input type="text" value="100"/> A		
IT <input type="text" value="N/A"/>	Other <input type="text" value="N/A"/>				External loop impedance $Z_e^{(2)}$ <input type="text" value="0.17"/> $\Omega$	Short circuit capacity <input type="text" value="80"/> kA		
Confirmation of supply polarity <input checked="" type="checkbox"/>				(Note: (1) by enquiry, (2) by enquiry or by measurement)				

## J. Particulars of Installation Referred to in the Report

Means of earthing	Details of installation Earth Electrode (where applicable)	
Distributor's facility <input checked="" type="checkbox"/>	Type (e.g. rod(s), tape etc.) <input type="text" value="N/A"/>	Location <input type="text" value="N/A"/>
Installation earth electrode <input type="text" value="N/A"/>	Resistance to Earth <input type="text" value="N/A"/> $\Omega$	Method of measurement <input type="text" value="N/A"/>

## Main Protective Conductors

Tick boxes and enter details as applicable

Earthing Conductor	Material <input type="text" value="Copper"/>	csa <input type="text" value="25"/> mm <sup>2</sup>	Connection and Continuity Verified <input checked="" type="checkbox"/>
Main protective bonding conductors	Material <input type="text" value="Copper"/>	csa <input type="text" value="10"/> mm <sup>2</sup>	Connection and Continuity Verified <input checked="" type="checkbox"/>
<b>Bonding of Incoming Service</b> Water installation pipes <input checked="" type="checkbox"/> Gas installation pipes <input checked="" type="checkbox"/> Structural Steel <input type="text" value="N/A"/> Lightning protection <input type="text" value="N/A"/> Oil installation pipes <input type="text" value="N/A"/> Please State Other incoming service(s) <input type="text" value="N/A"/> <input type="text" value="N/A"/>			Maximum Demand (Load) <input type="text" value="100"/> Amps Protective measure(s) against electric shock <input type="text" value="ADS"/>

## Main Switch / Switch-Fuse / Circuit-Breaker / RCD

Location <input type="text" value="Guard Room"/>	Current rating <input type="text" value="100"/> A	<b>if RCD main switch</b> Rated residual operation current, $I_{\Delta n}$ <input type="text" value="N/A"/> mA Rated time delay <input type="text" value="N/A"/> ms RCD Operating time at, $I_{\Delta n}$ <input type="text" value="N/A"/> ms
Type BS(EN) <input type="text" value="60947-3"/> No of poles <input type="text" value="2"/>	Fuse/Device rating or setting <input type="text" value="100"/> A	
Supply Conductors material <input type="text" value="Copper"/> Supply Conductors csa <input type="text" value="25"/> mm <sup>2</sup>	Voltage rating <input type="text" value="230"/> V	

## K. Observations

Referring to the attached schedule(s) of Inspection and Test Results, and subject to the limitations specified at the Extent and Limitations of the Inspection and testing section.

No remedial action is required.  The following observations are made ☒

Item No	Observations	Code
1	DB needs up grading, cables in walls no RCD Protection. Recommend DB is replaced	C3
2	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.19 RCD(s) provided for additional protection - includes RCBOs (411.3.3; 415.1)	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1 - Danger present. Risk of injury. Immediate remedial action required	<input type="text" value="0"/>
C2 - Potentially dangerous - urgent remedial action required	<input type="text" value="0"/>
C3 - Improvement recommended	<input type="text" value="2"/>
FI - Further investigation required without delay	<input type="text" value="0"/>

# CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

EC647505 - Master

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome		Comments	
<b>1.0</b>	<b>DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT</b>													
1.1	Condition of service cable										✓		No	
1.2	Condition of Service head										✓		No	
1.3	Condition of distributor's earthing arrangement										✓		No	
1.4	Condition of meter tails - Distributor/Consumer										✓		No	
1.5	Condition of metering equipment										✓		No	
1.6	Condition of Isolator (where present)										✓		No	
<b>2.0</b>	<b>PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES</b>										N/A		No	
<b>3.0</b>	<b>EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)</b>													
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)										✓		No	
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)										N/A		No	
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)										✓		No	
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)										✓		No	
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)										✓		No	
3.6	Confirmation of main protective bonding conductor sizes (544.1)										✓		No	
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)										✓		No	
3.8	Accessibility and condition of other protective bonding connections (543.3.2)										✓		No	
<b>4.0</b>	<b>CONSUMER UNIT (S) / DISTRIBUTION BOARD(S)</b>													
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)										✓		No	
4.2	Security of fixing (134.1.1)										✓		No	
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)										✓		No	
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)										✓		No	
4.5	Enclosure not damaged/deteriorated so as to impair safety (Regulation 621.2 (iii))										✓		No	
4.6	Presence of linked main switch (as required by 537.1.4)										N/A		No	
4.7	Operation of main switch (functional check) (612.13.2)										✓		No	
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13.2)										✓		No	
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)										✓		No	
4.10	Presence of RCD quarterly test notice at or near consumer unit / distribution board (514.12.2)										✓		No	
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514.14)										✓		No	
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)										N/A		No	
4.13	Presence of other required labelling (please specify)(Section 514)										N/A		No	
4.14	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)(421.1.3)										✓		No	
4.15	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.2)										✓		No	
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.11)										✓		No	
4.17	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1) )										✓		No	
4.18	RCD(s) provided for fault protection – includes RCBOs(411.4.9; 411.5.2; 531.2)										✓		No	
4.19	RCD(s) provided for additional protection - includes RCBOs (411.3.3; 415.1)										C3 (see section K)		No	
4.20	Confirmation of indication that SPD is functional (534.2.8)										✓		No	
4.21	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure (526.1)										✓		No	
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)										N/A		No	
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)										N/A		No	
<b>5.0</b>	<b>FINAL CIRCUITS</b>													
5.1	Identification of conductors (514.3.1)										✓		No	
5.2	Cables correctly supported throughout their run (522.8.5)										✓		No	
5.3	Condition of insulation of live parts (416.1)										✓		No	

# CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED

EC647505 - Master

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome			Comments
5.0	FINAL CIRCUITS (Continued)													
5.4.0	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)										✓			No
5.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)										✓			No
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)										✓			No
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)										✓			No
5.7	Adequacy of protective devices; type and rated current for fault protection (411.3)										✓			No
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)										✓			No
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)										✓			No
5.10	Concealed cables installed in prescribed zones (see section D. Extent and limitations) (522.6.202)										✓			No
5.11	Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6.204)										✓			No
5.12.0	Provision of additional protection by RCD not exceeding 30mA													
5.12.1	For all socket-outlets of rating 20 A or less, unless an exception is permitted (411.3.3)										✓			No
5.12.2	For supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)										✓			No
5.12.3	For cables concealed in walls at a depth of less than 50mm (522.6.202; 522.6.203)										✓			No
5.12.4	For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)										✓			No
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)										✓			No
5.14	Band II Cables segregated / separated from Band I cables (528.1)										✓			No
5.15	Cables segregated / separated from communications cabling (528.2)										✓			No
5.16	Cables segregated / separated from non-electrical services (528.3)										✓			No
5.17.0	Termination of cables at enclosures – indicate extent of sampling in Section D of the report (Section 526)													
5.17.1	Connections soundly made and under no undue strain (526.6)										✓			No
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)										✓			No
5.17.3	Connections of live conductors adequately enclosed (526.5)										✓			No
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc...) (522.8.5)										✓			No
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))										✓			No
5.19	Suitability of accessories for external influences (512.2)										✓			No
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)										✓			No
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.2)										✓			No
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER													
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30mA (701.411.3.3)										N/A			No
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)										N/A			No
6.3	Shaver sockets comply with BS EN 61558-2-5 formally BS 3535 (701.512.3)										N/A			No
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671: 2008 (701.415.2)										N/A			No
6.5	Low Voltage (e.g.230 volts) socket outlets at least 3m from Zone 1 (701.512.3)										N/A			No
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)										N/A			No
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)										N/A			No
6.8	Suitability of current-using equipment for particular position within the location (701.55)										N/A			No
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS													
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied).									Number of locations	0			No

## Inspected By

Name: Lewis Conabeer

Date: 13/09/2017

Signature:



Board Details		
TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
Location of Distribution Board	Building 7 Mains Intake Room	Supply to distribution board is from N/A
Distribution board designation	DB A	No of phases N/A      Nominal Voltage N/A V
		Overcurrent protective device for the distribution circuit
		Type BS(EN) N/A      Rating N/A A
		Associated RCD (if any)
		BS(EN) N/A
		RCD No of Poles N/A
		RCD Rating N/A mA

Circuit Details													
Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times	Overcurrent protective device				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>		BS(EN)	Type No	Rating A	Short circuit capacity kA	Op. current I <sub>Δn</sub>	Max permitted Z <sub>s</sub> Ω
1/TP	Circuit Not Tested												
2/TP	Circuit Not Tested												
3/TP	Circuit Not Tested												
4/TP	Circuit Not Tested												
5/L1	Sub Mains(DB 1)	F	D	1	25	25	5	60947-2 MCCB		100	30	N/A	LIM
5/L2	Circuit Not Tested												
5/L3	Circuit Not Tested												
6/TP	Circuit Not Tested												
7/TP	Circuit Not Tested												
8/TP	Circuit Not Tested												
9/TP	Circuit Not Tested												
10/TP	Circuit Not Tested												
11/TP	Circuit Not Tested												
12/TP	Circuit Not Tested												
13/TP	Circuit Not Tested												
14/TP	Circuit Not Tested												
15/TP	Circuit Not Tested												
16/TP	Circuit Not Tested												

Wiring Code								
A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

## Board Tests

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

## TEST INSTRUMENTS (SERIAL NUMBERS) USED

Zs   $\Omega$  Operating times of associated RCD (if any) At  $I \Delta n$   ms

Ipf  kA At  $5I \Delta n$   ms

Correct supply polarity confirmed ☒ Phase sequence confirmed (where appropriate) ☒

Earth fault loop impedance  RCD

Insulation resistance  Other

Continuity  Other

## Details of circuits and/or equipment vulnerable to damage

N/A

## Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance				p o l a r i t y	Maximum measured earth fault loop impedance Ω	RCD operating times			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral			At I Δ n ms	At 5I Δ n ms	Test button operation	
	r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	(R <sub>2</sub> )										
1/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/L1	N/A	N/A	N/A	0.05	N/A	N/A	200	200	200	✓	0.22	N/A	N/A	N/A	NO
5/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
14/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
15/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

## Tested By

Signature



Position

Approved Electrician

Name

Lewis Conabeer

Date of testing

13/09/2017

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION	
Location of Distribution Board	Guards Room	Supply to distribution board is from	SubMains(DB A, 5/L1)
Distribution board designation	DB 1	No of phases	1
		Nominal Voltage	230 V
		Overcurrent protective device for the distribution circuit	
		Type BS(EN)	60947-2 MCCB
		Rating	100 A
		Associated RCD (if any)	
		BS(EN)	61008 RCD
		RCD No of Poles	2
		RCD Rating	30 mA

Circuit Details

Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times	Overcurrent protective device				RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>		BS(EN)	Type No	Rating A	Short circuit capacity kA	Op. current I <sub>Δn</sub>	Max permitted Zs Ω
1/L1	Lighting	A	B	8	1	1	0.4	60898 MCB	B	6	10	N/A	7.28
2/L1	Smoke Detectors	A	B	4	1	1	0.4	60898 MCB	B	6	10	N/A	7.28
3/L1	Bomb Alert	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.73
4/L1	Armoury Alarm	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.73
5/L1	Barriers	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.73
6/L1	Barriers	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.73
7/L1	Surge Arrestor	A	B	1	10	6	0.4	60898 MCB	C	63	10	N/A	0.35
8/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
9/L1	RCD Module (Split Board)	-	-	-	-	-	-	-	-	-	-	-	-
10/L1	Outside Lights	A	B	2	1	1	0.4	60898 MCB	B	6	10	30	7.28
11/L1	Outside Lights Near	A	B	3	1	1	0.4	60898 MCB	B	6	10	30	7.28
12/L1	Far Lamp Post	A	B	2	2.5	1.5	0.4	60898 MCB	B	6	10	30	7.28
13/L1	Ring Main Dado	A	B	4	2.5	1.5	0.4	60898 MCB	B	32	10	30	1.37
14/L1	IT Hub	A	B	1	2.5	1.5	0.4	60898 MCB	B	16	10	30	2.73
15/L1	Ring Main	A	B	6	2.5	1.5	0.4	60898 MCB	B	32	10	30	1.37
16/L1	Ring Main Kitchen	A	B	8	2.5	1.5	0.4	60898 MCB	B	32	10	30	1.37
17/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code

A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

# Board Tests

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION						TEST INSTRUMENTS (SERIAL NUMBERS) USED					
Zs	0.22	Ω	Operating times of associated RCD (if any)	At I Δ <sub>n</sub>	N/A	ms	Earth fault loop impedance	225742	RCD	225742	
Ipf	1.12	kA		At 5I Δ <sub>n</sub>	N/A	ms	Insulation resistance	225742	Other	N/A	
Correct supply polarity confirmed	✓		Phase sequence confirmed (where appropriate)		✓		Continuity	225742	Other	N/A	

# Details of circuits and/or equipment vulnerable to damage

Bomb Alert, Armoury alarm, electronic ballast, neon indicators, RCDs.

# Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance				p o l a r i t y	Maximum measured earth fault loop impedance Ω	RCD operating times			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral			At I Δ <sub>n</sub>	At 5I Δ <sub>n</sub>	Test button operation	
	r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	(R <sub>2</sub> )										
1/L1	N/A	N/A	N/A	1.01	N/A	N/A	200	200	200	✓	1.23	N/A	N/A	N/A	NO
2/L1	N/A	N/A	N/A	0.29	N/A	N/A	200	200	200	✓	0.51	N/A	N/A	N/A	NO
3/L1	N/A	N/A	N/A	0.14	N/A	N/A	200	200	200	✓	0.36	N/A	N/A	N/A	NO
4/L1	N/A	N/A	N/A	0.16	N/A	N/A	200	200	200	✓	0.38	N/A	N/A	N/A	NO
5/L1	N/A	N/A	N/A	0.03	N/A	N/A	200	200	200	✓	0.25	N/A	N/A	N/A	NO
6/L1	N/A	N/A	N/A	0.06	N/A	N/A	200	200	200	✓	0.28	N/A	N/A	N/A	NO
7/L1	N/A	N/A	N/A	0.04	N/A	N/A	200	200	200	✓	0.26	N/A	N/A	N/A	NO
8/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10/L1	N/A	N/A	N/A	0.18	N/A	N/A	200	200	200	✓	0.40	40	18	✓	NO
11/L1	N/A	N/A	N/A	0.25	N/A	N/A	200	200	200	✓	0.47	40	18	✓	NO
12/L1	N/A	N/A	N/A	0.48	N/A	N/A	200	200	200	✓	0.70	40	18	✓	NO
13/L1	0.27	0.26	0.39	0.16	N/A	N/A	200	200	200	✓	0.38	40	18	✓	NO
14/L1	N/A	N/A	N/A	0.14	N/A	N/A	200	200	200	✓	0.36	40	18	✓	NO
15/L1	0.19	0.19	0.29	0.33	N/A	N/A	200	200	200	✓	0.55	40	18	✓	NO
16/L1	0.33	0.31	0.45	0.37	N/A	N/A	200	200	200	✓	0.59	40	18	✓	NO
17/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

# Tested By

Signature		Position	Approved Electrician
Name	Lewis Conabeer	Date of testing	13/09/2017



Extent of Electrical Installation covered by this report, Continued. from page 1

regulations BS7671, guidance note 3.

General condition of the installations (In terms of electrical safety), Continued. from page 1

up to current regulations and standards.

## CONDITION REPORT GUIDANCE NOTES FOR RECIPIENTS

**This report is an important and valuable document which should be retained for future reference.**

1. The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.
3. The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates residual current devices (RCD) there should be a notice at or near the device stating that it should be tested quarterly. **For safety reasons it is important that this instruction is followed.**
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ("Potentially Dangerous"), the safety of those using the installation may be at risk and it is recommended that a competent person undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation (code F1) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit / distribution board.