ELECTRICAL INSTALLATION CONDITION REPORT



A. Details	of the Clie	nt/Person Orde	ring the	Report	B. Reason for Producing this Report									
Client:	Wessex R	(FCA			Purpose of this report:									
Address:	Mount Hou Mount Stre Taunton Devon TA1 3QE				Date(s) on which Inspection: 29/10/2019									
					and testing was carried out									
C. Details			the Sub	ject of this Report		-in-tion of	Commer	ercial Industrial						
Installation:	Bridgewat	ter Cadet hut				scription of mises:	N	Ά	✓ N/A					
Occupier:	Wessex				Othe									
Address:	Friarn aver				N/A Estimated age of wiring system: 20 vrs									
	Bridgewate Somerset	} Γ			Evid	dence of alter	ations	_	If yes	20 yrs				
			TA	A6 3RF	or a	idditions:	N/		estimate	d Age N/A yrs				
Record of Installation ava	n/A	Records held By:	N/A					Date of prev inspection:	ious	lot Known				
D. Extent a	and Limitat	tions Inspection	and Tes	sting										
		n covered by this repo			Agreed lin	mitations inclu	uding the reaso	ns (See regula	ation 653.	2)				
fixed wirin	g only				In acco	ordance w	ith guidance	e note 3 an	d BS76	71				
					WOCCY	,								
Operational Li	mitations inclus	ding the reasons (See	page No	Agreed with name	wessx	•								
None	mations metab	ling the reasons (See	page No T)										
to July 2018 It should be no	oted that cablesed unless specif	s concealed within tru	nking and co	onying schedules have been onduits, under floors, in roand inspector prior to the in	oof spaces,	, and generall	ly within the fat	oric of the build	ding or un	derground, have NOT				
		ondition of the	Installati	On General condit	tion of the i	installations (I	In terms of elec	ctrical safety)						
		working order												
	ssment of the ir		factory	*An unsatisfactory as C2) conditions have b			dangerous (co	ode C1) and/or	r potential	lly dangerous (code				
F. Recomm			''talleti	for the state of t	· -tated	CATION	ACTORY I	mond	1 t - m	"l-ocified on				
'Danger prese Investigation w	nt' (code C1) or vithout delay is	r 'Potentially dangerou recommended for obs provement recommen	us' (code C2 servations id ded' (code C	on for continued use abov 2) are acted upon as a mat dentified as 'further investi C3) should be given due contential action being taken	tter of urge igation requ consideration	ency. <i>uired' (code F</i> on.	·I).		·	00/40/0004				
G. Declara	whice infor	ch are described abov rmation in this report,	e, having ex including the	for the inspection and test kercised reasonable skill a e observations and attach atted extent and limitations	and care wheel	hen carrying olles, provides	out the inspect an accurate as	ion and testing	g, hereby	declare that the				
Trading Title and address	_	s & Son Ltd., ouse Water Bridge Co	urt,				NICEIC Enroll	t Ni-mbor	0140					
and address	Mat ford Par Exeter,	rk Road,					NICEIC Enrol		9140					
	Devon, EX2	: 8EX					Branch No.	(If Applicable)	n/a					
Inspected and	-					г				00/40/0040				
	rtyn Thorpe rised for issue		Position	Approved Electricia	an s	Signature	O.		Date	29/10/2019				
	llum Harriso		Position	Approved Electricia	an s	Signature	gli	-	Date	29/10/2019				
H. Schedu	le(s) The	attached schedule(s)	are part of t	his document and this rep	ort is valid	l only when th	nev are attache	d to it.						
1		ule(s) of inspection and				ults are attach								

L Supply Ch	aracteristics	and Earthing	Arrangen	ents							
Earthing	Ni	umber and Type of				Nature of	Supply	Parameters		Supply protective de	evice
Arrangements	•			Т	NI/A	Nominal	(1)	400 V	BS(EN)	OWER J	,,,,,
TN-S N/A		✓		d.c.	N/A	Voltage	(4)			Fuse HBC	
TN-C-S ✓	1-Phase (2 wire)	N/A 1-Phase (3 wire)	N/A	2 Wire	N/A	Nominal Voltage		230 V			
TN-C N/A	2-Phase (3 wire)	N/A		3 Wire	N/A	Nominal frequency Prospective	f (1)		Type 1		
TT N/A	3-Phase (3 wire)	N/A 3-Phase (4 wire)	✓	Other	N/A	fault current External loop impedance		1.066 kA 0.21 Ω	Nominal current ra	100	A
IT N/A	Other N/A					Number of supplies		1	Short circ	cuit	kA
	Confirmation	n of supply polarity		~				(2) by enquiry	or	10.0	M
J. Particular	rs of Installat	tion Referred to	o in the R	eport							
Means of	earthing			D	etails of	f installation Ea	arth Ele	ctrode (where	applicable)		
Distributor's facility	✓	Type (e.g. rod(s), tape etc.)	N/A			Locat	tion	N/A			
Installation	N/A	Resistance to	N/A			Ω					
earth electrode		Earth				Metho	od of				
							suremen	nt N/A			
	tive Conduct	tors	boxes and en	iter detai	ils as apr						
Earthing Conductor	Material	Copper		csa	25	mm ²	Cor	ntinuity Verified	1 🗸	Connection Ve	erified 🗸
Main protective bonding conductor	ors Material	Copper		csa	16	mm ²	Cor	entinuity Verified	i 🗸	Connection Ve	erified 🗸
Bonding of Inco								Maximum De	mand (Load)		
Water installation pipes	IV/A	stallation pipes N/A St	tructural Steel N/		_ightning rotection			100	Amps		
Oil installation pipes	N/A			ase State						ainst electric shock	
. مانم		Other incoming service(s)	N/A N/A					ADS			
Main Switch	/ Switch-Fus	se / Circuit-Bre	eaker / R0	CD							
	office		GH6.	7-			Curre		00 A	if RCD main	
	•						rating	,		operation current,	mA mA
								/Device 10 or setting	00 A	I∆n Rated time delay	N/A ms
Type BS(EN)	61008 RCD		No	o of pole	s 2		Voltag		80 v	rated time delay	
Supply	Copper		Supply	ors 16		mm ²	rating			RCD Operating time at, I∆n	14 ms
Conductors material			Conducto csa	rs		Піп					
K. Observati	ions										
Referring to the a	attached schedule	(s) of Inspection and	Test Results	s, and su	ubject to	the limitations s	pecified	at the Extent a	nd Limitation	ns of the Inspection and	testing section.
No remedial action	_		owing observa		-	N/A					
Item No						ervations					Code
No						517445					
53 50				5.45		- 15-26	- 101	- 0, -		2 1 4-11-2	
	ving codes, as app cy for remedial act		allocated to ea	ach of the	ē observ	rations made an	ove to II	ndicate to the p	erson(s) resp	ponsible for the installat	tion the
C1 - Danger prese	ent. Risk of injury. Ir	mmediate remedial ac	tion required		0						
C2 - Potentially da	angerous - urgent r	remedial action requir	red		0						
C3 - Improvemen	it recommended				0						
		vithout delay			0						

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

Note: this form is suitable for many types of smaller installations, not exclusively domestic.

Outcomes	Acceptable Unacceptable State C1 Improvement State Further condition or C2 recommended C3 investigation FI verified	N/V Limitation LIM Not applicate	le N/A
Item No	Description	Outcome	Comments
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)		
1.1	Service cable	✓	No
1.2	Service head	✓	No
1.3	Earthing arrangement	✓	No
1.4	Meter tails	✓	No
1.5	Metering equipment	✓	No
1.6	Isolator (where present)	✓	No
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)	✓	No
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)		
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	✓	No
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)	N/A	No
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)	✓	No
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)	√	No
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)	✓	No
3.6	Confirmation of main protective bonding conductor sizes (544.1)	✓	No
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)	✓	No
3.8	Accessibility and condition of other protective bonding connections (543.3.1;543.3.2)	✓	No
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)		
4.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)	✓	No
4.2	Security of fixing (134.1.1)	✓	No
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)	✓	No
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)	✓	No
4.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)	✓	No
4.6	Presence of main linked switch (as required by 462.1.201)	✓	No
4.7	Operation of main switch (functional check) (643.10)	✓	No
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (643.10)	✓	No
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓	No
4.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)	√	No
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit/distribution board (514.14)	✓	No
4.12	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)	✓	No
4.13	Presence of other required labelling (please specify) (Section 514)	✓	No
4.14	Compatibility of protective devices, bases and other components; correct type and rating (No signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)	✓	No
4.15	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.3)	✓	No
4.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)	✓	No
4.17	Protection against electromagnetic effects where cables enter consumer unit/distribution board/enclosures (521.5.1)	✓	No
4.18	RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.5.2; 531.2)	✓	No
4.19	RCD(s) provided for additional protection/requirements - includes RCBOs (411.3.3;415.1)	✓	No
4.20	Confirmation of indication that SPD is functional (651.4)	✓	No
4.21	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓	No
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	✓	No
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	✓	No
5.0	FINAL CIRCUITS		
5.1	Identification of conductors (514.3.1)	✓	No
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓	No
5.3	Condition of insulation of live parts (416.1)	✓	No

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No				ı			Outco		Comments					
5.0	FINAL CIRCU	JITS (Co	ontinued)											
5.4	Non-sheathed	d cables	protected by end		✓		No							
5.4.1	To include the	e integrity	y of conduit and		✓		No							
5.5	Adequacy of (523)	cables fo	or current-carryin	g capacity v	with regard for th	e type a	nd nature of inst	tallation (S	Section		✓	/		No
5.6	,	between	conductors and	overload p	rotective devices	(433.1;	533.2.1)				✓	/		No
5.7	Adequacy of	protective	e devices: type a	and rated cu	irrent for fault pro	tection	(411.3)				✓	/		No
5.8	Presence and	d adequa	cy of circuit prot	ective cond	uctors (411.3.1;	Section	543)				✓	/		No
5.9	Wiring system	n(s) appr	opriate for the ty	pe and nati	ure of the installa	tion and	external influen	ices (Sect	ion 522)		✓	/		No
5.10	Concealed ca	ables inst	talled in prescrib	ed zones (s	ee Section D. Ex	tent and	l limitations) (52	2.6.202)			✓	/		No
5.11			der floors, above t and limitations)		in walls/partitions	s, adequ	ately protected	against da	mage		✓	/		No
5.12	Provision of a	dditional	I requirements for	r protection	by RCD not exc	eeding :	30 mA:							
5.12.1	For all socket	outlets o	of rating 32 A or	less, unless	an exception is	permitte	ed (411.3.3)				✓	/		No
5.12.2	For the supply	y of mob	ile equipment no	t exceeding	32 A rating for ι	ise outd	oors (411.3.3)				✓		No	
5.12.3	For cables co	ncealed	in walls at a dep	th of less th	nan 50 mm (522.0	5.202; 5	22.6.203)				✓		No	
5.12.4	For cables co	ncealed	in walls/partition	s containin	g metal parts reg	ardless	of depth (522.6.	203)			✓		No	
5.12.5	Final circuits	supplying	g luminaires with	in domestic	(household) pre	mises (4	111.3.4)				✓	/		No
5.13	Provision of fi	ire barrie	rs, sealing arran	gements ar	nd protection aga	inst the	mal effects (Sec	ction 527)			✓		No	
5.14	Band II cables	s segreg	ated/separated f	rom Band I	cables (528.1)						✓		No	
5.15	Cables segre	gated/se	parated from co	mmunicatio	ns cabling (528.2	2)					✓		No	
5.16	Cables segre	gated/se	parated from no	n-electrical	services (528.3)						✓		No	
5.17	Termination of	of cables	at enclosures - i	ndicate exte	ent of sampling in	n Sectio	n D of the report	(Section	526)					
5.17.1	Connections	soundly r	made and under	no undue s	strain (526.6)						✓	/		No
5.17.2	No basic insu	lation of	a conductor visi	ble outside	enclosure (526.8)					✓		No	
5.17.3	Connections	of live co	nductors adequa	ately enclos	ed (526.5)						✓			No
5.17.4	Adequately co	onnected	d at point of entry	to enclosu	re (glands, bush	es etc.)	(522.8.5)				✓			No
5.18	Condition of a	accessori	ies including soc	ket-outlets,	switches and joi	nt boxes	s (651.2(v))				✓			No
5.19	Suitability of a	accessor	ies for external i	nfluences (512.2)						✓			No
5.20	Adequacy of	working	space/accessibil	ity to equipr	ment (132.12; 51	3.1)					✓			No
5.21	Single-pole sv	witching	or protective dev	vices in line	conductors only	(132.14	.1;530.3.3)				✓			No
6.0	LOCATION(S	S) CONT.	AINING A BATH	OR SHOW	VER									
6.1	Additional pro	tection for	or all low voltage	(LV) circui	ts by RCD not ex	ceeding	30 mA (701.41	1.3.3)			✓			No
6.2	Where used a	as a prote	ective measure,	requiremen	ts for SELV or P	ELV me	t (701.414.4.5)				N/	A		No
6.3	Shaver socke	ets compl	ly with BS EN 61	558-2-5 for	merly BS 3535 (701.512	.3)				✓		No	
6.4	Presence of s	suppleme	entary bonding c	onductors,	unless not require	ed by B	5 7671:2018 (70	1.415.2)			✓			No
6.5	Low voltage (e.g. 230	volt) socket-outl	ets sited at	least 3 m from zo	one 1 (7	01.512.3)				✓			No
6.6	Suitability of e	equipmer	nt for external inf	luences for	installed location	n in term	s of IP rating (70	01.512.2)			✓			No
6.7	Suitability of a	accessor	ies and controlg	ear etc. for	a particular zone	(701.51	2.3)				✓		No	
6.8	Suitability of o	current-u	sing equipment	for particula	r position within	the loca	tion (701.55)				✓			No
7.0	OTHER PAR	T 7 SPE	CIAL INSTALLA	ATIONS OR	LOCATIONS									
7.1	List all other s inspections a		nstallations or loc	ations pres	ent, if any. (Reco	ord sepa	rately the results	s of partic		mber of cations		0		No

Inspected By		
Name:	Martyn Thorpe	Date: 29/10/2019
Signature:	O.	

Boar	d Detai	ls																
Т	O BE COM	MPLETE	D IN EVERY CASE		ONLY	то ве сс)MPLETE	:D IF TH	E DISTR	IBUTION BOARD			IECTED	DIRECTI	_Y TO T	HE ORIG	SIN	
		Office			Supply t	to							Assc	ciated R0	D (if an	v)		
Locati	oution	Unice			distribut board is	tion	N/A				-1	BS(EN) N/A						
Board	I				No of ph		N/A		Nomina	Voltage N/A	V	RCD No of						
Dietrik	Distribution DR 1				Overcurrent protective device for the distribution circuit									N/A				
board		DB 1			Type BS(EN) N/A Rating N/A A								ating	N/A		n	nΑ	
desigi					71.	,	177			3 14//1				14// \				
	uit Deta	ils									Over	current pr	otective			RCD 6		
Circuit number and phase				Type of wiring	Reference method	No of points served		cuit tors csa	Max permitted disconnection times (s)			device	!		+ ?		Maximum permitted Zs (᠒)	
ircuit numb and phase		Circuit o	designation	of w	Jce r	oints	00.11440	10.0 000	perm perm perm perm			4500	-	€	ircui y (kA	ating ∶(∆n	mum itted	
Circu				Type	efere	o of p	Live mm ²	cpc mm ²	Max disco	BS(EN)		AFDD	Type	Rating (A)	Short circuit capacity (kA)	Operating current (∆n)	Maxii perm	
1/L3	SPARE			_	<u> </u>	<u>Z</u>	-	-	-	_		-		_	လ အ	ੂ ਤ	-	
	Skts			A	В	4	2.5	1.5	0.4	60898 MCB	3		В	32	10	30	1667	
3/L3	fan heater o	office		A	В	1	2.5	1.5	0.4	60898 MCB	3		В	20	10	30	1667	
4/L3	fan heater r	ange		A	В	1	2.5	1.5	0.4	60898 MCB	3		В	20	10	30	1667	
5/L3	heater			А	В	1	2.5	1.5	0.4	60898 MCB	3		В	20	10	30	1667	
6/L3	3 fan			А	В	2	2.5	1.5	0.4	60898 MCB		В	10	10	30	1667		
7/L3	Z/L3 Lts office			А	В	9	1.5	1	0.4	60898 MCB		В	10	10	30	1667		
8/L3	8/L3 Lts range			А	В	8	1.5	1	0.4	60898 MCB	3		В	10	10	30	1667	
9/L3	3 Unknown			F	С	1	6	6	0.4	60898 MCB			С	32	10	30	1667	
	Bollards			F	С	3	2.5	1.5	0.4	60898 MCB			С	16	10	30	1667	
	SPARE			-	-	-	-	-	-	-		-	-	-	-	-	-	
12/L3	SPARE			-	-	-	-	-	-	-		-	-	-	-	-	-	
							1											
				+-		_												
				+	+	-												
				+														
				+		-												
				+	+													
				+														
Wirir	ng Code	9																
	A	١	В	С		D		Е		F		G		Н		0		
	PVC cables PVC cables PVC in metallic nor		PVC cab in non-met condu	cables PVC cables in in metallic results		PVC cablin non-meta trunkin	bles PVC/SWA tallic cables				Mineral insulated cables		0	Other				

EC2423 - Master

Board 7	Гests															
		TO BE CO	OMPLETED	IN EVERY	CASE				Т	EST INSTRU	JMENT	S (SERIAL N	UMBERS) USED		
Correct s	supply pola	arity confirmed	d 🗸		equence co		√					- (,		
Su	pplementa	ary Conductor	rs 🗸	(where a	ppropriate)			Earth fau	22	25710		RCD	225	710		
ONLY TO		MPLETED IF TECTLY TO T					ECTED		Insulation resistance 225710 Multi-function N/A							
Zs N/	A c	2 lpf N/	A kA					Continuit		25710		Other				
Operating times of associated RCD (if any) At 1Δ n N/A ms									y Z	237 10		Other	IN/A			
Details	of circu	iits and/or	equipm	ent vuln	erable t	o dama										
none Circuit Tests																
Circuit	Tests	0.														
		Circ	uit Impedar Ω				Insul	ation resist	ance			Maximum	RC	D	tton	ion
Circuit number and		g final circuits easure end to		All cir (At leas	st one ımn	Test	Test Live/	Live/	Live/		Polarity (v)	measured earth fault loop	Operating time at l∆ n (ms)	Test button operation	AFDD Test button operation	Remarks see continuation sheet
phase	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	to be con (R ₁ + R ₂₎	(R ₂)	Voltage	Live MΩ	Neutral MΩ	Earth MΩ	Neutral MΩ	P	impedance Ω	Operat at I∆ n	Test	AFDC	see (
1/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2/L3	0.17	0.17	0.29	0.23	N/A	500	N/A	200	200	200	√	0.44	42	1		NO
3/L3	N/A	N/A	N/A	0.25	N/A	500	N/A	200	200	200	√	0.46	42	1		NO
4/L3	N/A	N/A	N/A	0.45	N/A	500	N/A	200	200	200	√	0.66	42	1		NO
5/L3	N/A	N/A	N/A	0.18	N/A	500	N/A	200	200	200	√	0.39	42	1		NO
6/L3	N/A	N/A	N/A	0.28	N/A	500	N/A	200	200	200	✓	0.49	42	1		NO
7/L3	N/A	N/A	N/A	0.26	N/A	500	N/A	200	200	200	✓	0.47	42	1		NO
8/L3	N/A	N/A	N/A	0.16	N/A	500	N/A	200	200	200	√	0.37	42	1		NO
9/L3	N/A	N/A	N/A	0	N/A	500	N/A	200	200	200	✓	lim	42	✓		NO
10/L3	N/A	N/A	N/A	1.78	N/A	500	N/A	200	200	200	✓	1.99	42	✓		NO
11/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12/L3	-	-	-	-	-	-	-	-	-	-	1	-	1	-	1	-
Tested	Ву															
Signa	iture			a				Position		Approve	ed Ele	ctrician				
Name Martyn Thorpe								Date of testing 29/10/2019								

CONDITION REPORT GUIDANCE FOR RECIPIENTS (to be appended to the Report)

This Report is an important and valuable document which should be retained for future reference.

- 1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
- The person ordering the Report should have received the 'original' Report and the inspector should have retained a duplicate.
- 3. The 'original' Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
- Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested six-monthly. For safety reasons it is important that this instruction is followed.
- 5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
- 6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
- 7. For items classified in Section K as C1 ('Danger present'), the safety of those using the installation is at risk, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
- 8. For items classified in Section K as C2 ('Potentially dangerous'), the safety of those using the installation may be at risk and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
- 9. Where it has been stated in Section K that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
- 10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit/ distribution board.