

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

FT/EIC 3486000001701



Client Details

Client	WESSEX RFCA	Installation	OKEHAMPTON PLATOON
Address	MOUNT HOUSE MOUNT STREET TAUNTON SOMERSET	Address	MILITARY SIDINGS TORS ROAD OKEHAMPTON DEVON
Postcode	TA1 3QU	Postcode	EX20 1EF

Details of the Installation

Description of premises Domestic ☐ Commercial ☒ Industrial ☐ Date of original installation ?

Installation is New ☐ Addition ☐ Alteration ☒ Records Available Yes ☐ No ☒ RCD Risk assessment attached ☐

Description of the installation
COMPLETION OF ALL C2 & C3 DEVIATION WORK PREVIOUSLY NOTED ON EICR AND DETAILED WITHIN WRITTEN REPORT.

Extent of the installation covered by this certificate
ONLY AFFCETED RESULTS REQUIRED BY COMPLETION OF ALL C2 & C3 DEVIATION WORK PREVIOUSLY NOTED ON EICR AND DETAILED WITHIN WRITTEN REPORT HAVE BEEN CHANGED WITHIN THIS CERTIFICATE. ALL OTHER TEST RESULTS INCLUDED ARE TAKEN FROM WHEN EICR WAS CARRIED OUT.
CURRENT EICR NO: 3486000001245 ISSUED 10-11-21

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which i have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022 except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	Technical Electrical Engineering Ltd t/a Mr Electric	Position	Technician
Inspector Name	Leo Kessell	Date	10/11/2022
Address	Wheal Kitty Studios Wheal Kitty St Agnes TR5 0RD	Scheme No.	019875
		Branch No.	
		Signature	

Reviewed By	Steve Creese	Reviewed By	
Reviewed By Date	15/11/2022	Signature	

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 4 years

ELECTRICAL INSTALLATION CERTIFICATE

[BS 7671: 2018+A2:2022 as amended]

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

FT/EIC 3486000001701



Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S ☐ TN-C-S ☒ TT ☐ Other ☐ If Other please specify N/A

Number & Type of live conductors AC ☒ DC ☐ No. of phases 3 No. of wires 4

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ 400/230 v Nominal frequency, f⁽¹⁾ 50 Hz Confirmation of polarity ☒

Prospective fault current, I_{pf} ⁽²⁾ 2.7 kA External loop impedance, Z_e ⁽²⁾ 0.14 Ω

Supply Protective Device BS (EN) 1361 Fuse HBC 1 Type 1 Rated Current 100 A

No. of Additional Supplies 0

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc)
Location Electrode resistance to earth Ω **Means of Earthing**
Distributors facility ☒ Installation Earth Electrode ☐
Maximum Demand (load) 50 Amps ☒ KVA ☐

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	16 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Ω <input type="text"/>
Protective Bonding Conductor	Copper	10 mm ²	Continuity Verified <input checked="" type="checkbox"/>	LIM Ω <input type="text"/>

Main Supply Conductor	Material	csa	(connection / continuity) (✓) or Value	(✓) or Value
	Copper	25 mm ²	Water installation <input checked="" type="checkbox"/>	Ω <input type="text"/>
Main Switch Location	ELECTRICAL CUPBOARD		To structural steel <input checked="" type="checkbox"/>	Ω <input type="text"/>
			Gas installation pipes <input type="text"/>	Ω <input type="text"/>
			Oil installation pipes <input type="text"/>	Ω <input type="text"/>
			Other <input type="text"/>	Ω <input type="text"/>

Fuse/device rating or setting 100 A Voltage rating 230 V BS(EN) 60947-3 No. of Poles 2 Current Rating 100 A
If RCD main switch: Rated residual operating current I Δn N/A mA Rated time delay N/A ms Measured operating trip time N/A ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

EXISTING INSTALLATION COVERED UNDER EICR 3486000001245 CARRIED OUT ON THE 10-11-21. [ONLY AMENDED RESULTS HAVE BEEN CHANGED ON THIS CERTIFICATE]

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory			Indicates the inspection is not applicable to a particular item		
		<input checked="" type="checkbox"/>			<input type="checkbox"/>
1.0	Condition of consumer;s intake equipment (visual inspection only)	<input checked="" type="checkbox"/>	8.0	Circuits (Distribution and Final)	<input checked="" type="checkbox"/>
2.0	Parallel or switched alternative sources of supply	<input type="checkbox"/>	9.0	Isolation and switching	<input checked="" type="checkbox"/>
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	<input checked="" type="checkbox"/>	10.0	Current-using equipment (permanently connected)	<input checked="" type="checkbox"/>
4.0	Basic Protection	<input checked="" type="checkbox"/>	11.0	Identification and notices	<input checked="" type="checkbox"/>
5.0	Protective measure other than ADS	<input type="checkbox"/>	12.0	Location(s) containing a bath or shower	<input checked="" type="checkbox"/>
6.0	Additional protection	<input checked="" type="checkbox"/>	13.0	Other special installations or locations	<input type="checkbox"/>
7.0	Distribution equipment	<input checked="" type="checkbox"/>	14.0	Prosumer's low voltage electrical installation(s)	<input type="checkbox"/>

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) 0 schedules of circuit details and test results are attached

Inspector's Name: Leo Kessell

Signature

Date: 10/11/2022

for Industrial/Commercial Premises

FT/EIC 3486000001701



Client Name	WESSEX RFCA	Installation Address	OKEHAMPTON PLATOON, MILITARY SIDINGS, TORS ROAD, OKEHAMPTON, DEVON
Client Address	MOUNT HOUSE, MOUNT STREET TAUNTON, SOMERSET	Postcode	EX20 1EF
Client Postcode	TA1 3QU		

Distribution board details - Complete in every case SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location ELECTRICAL CUPBOARD Designation DB 1 No. of ways 12	Complete only if the distribution board is not connected directly to the origin of the installation Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text"/> No. of phases 1 <input type="text"/> BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> A Nominal voltage NA <input type="text"/> V RCD BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> IDn mA
--	---

[illegible]

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

for Industrial/Commercial Premises

FT/EIC 3486000001701



Client Name	WESSEX RFCA		Installation Address	OKEHAMPTON PLATOON, MILITARY SIDINGS, TORS ROAD, OKEHAMPTON, DEVON	
Client Address	MOUNT HOUSE, MOUNT STREET TAUNTON, SOMERSET		Client Postcode	TA1 3QU	
			Installation Postcode	EX20 1EF	
Distribution board details - Complete in every case			Complete only if the distribution board is not connected directly to the origin of the installation		
Location	ELECTRICAL CUPBOARD		Associated RCD (if any):	BS (EN)	N/A
Designation	DB 1		Z _{db}	0.31	Ω Operating at IΔn N/A ms
No. of ways	12	<input checked="" type="checkbox"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed			
No. of phases	1	SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	I _{pf}	1.5	kA No. of poles N/A Time delay (if applicable) N/A

[illegible]

ANY ELECTRONIC DEVICES.

Date(s) dead testing To

Date(s) live testing To

Loop impedance	009986101940215	Insulation resistance	009986101940215	Continuity	009986101940215	RCD	009986101940215	E/Electrode	
----------------	-----------------	-----------------------	-----------------	------------	-----------------	-----	-----------------	-------------	--

Tested by: Name (capital letters) LEO KESSELL

Signature

Position	Technician	Date	10/11/2022
----------	------------	------	------------

for Industrial/Commercial Premises

FT/EIC 3486000001701



Client Name	WESSEX RFCA	Installation Address	OKEHAMPTON PLATOON, MILITARY SIDINGS, TORS ROAD, OKEHAMPTON, DEVON
Client Address	MOUNT HOUSE, MOUNT STREET TAUNTON, SOMERSET	Postcode	EX20 1EF
Client Postcode	TA1 3QU		

Distribution board details - Complete in every case SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input type="checkbox"/> Location ELECTRICAL CUPBOARD Designation DB 2 No. of ways 4	Complete only if the distribution board is not connected directly to the origin of the installation Overcurrent protective device Supply to distribution board is from <input type="text"/> for the distribution circuit: No. of phases 1 <input type="text"/> BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> A Nominal voltage NA <input type="text"/> V RCD BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> IΔn mA
--	--

[illegible]

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results.

for Industrial/Commercial Premises


FT/EIC 3486000001701



Mr.  Electric™

Client Name	WESSEX RFCA		Installation Address	OKEHAMPTON PLATOON, MILITARY SIDINGS, TORS ROAD, OKEHAMPTON, DEVON	
Client Address	MOUNT HOUSE, MOUNT STREET TAUNTON, SOMERSET	Client Postcode	TA1 3QU		Installation Postcode
			EX20 1EF		
Distribution board details - Complete in every case			Complete only if the distribution board is not connected directly to the origin of the installation		
Location	ELECTRICAL CUPBOARD		Associated RCD (if any):	BS (EN)	N/A
Designation	DB 2		Z _{db}	0.31	Ω Operating at IΔn N/A ms
No. of ways	4	<input checked="" type="checkbox"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed			
No. of phases	1	SPD: <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable	I _{pf}	1.5	kA No. of poles N/A Time delay (if applicable) N/A

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	10/11/2022	To	10/11/2022
ANY ELECTRONIC DEVICES.		Date(s) live testing	10/11/2022	To	10/11/2022
Test instrument serial number(s)					
Loop impedance	009986101940215	Insulation resistance	009986101940215	Continuity	009986101940215
		RCD	009986101940215	E/Electrode	
Tested by: Name (capital letters)		Signature			
LEO KESSELL					
Position	Technician	Date	10/11/2022		

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations
BS 7671: 2018 (IET Wiring Regulations 18th Edition)

FT/EIC 3486000001701



Generic Continuation

Remarks:

DB 2 Remarks:
4/L3 - STREET LIGHTS: READINGS TAKEN AT FUSED ISOLATOR LOCATED AT THE BOTTOM OF THE LIGHTNG POLE.