



**Defence
Infrastructure
Organisation**

**Gas Safety Management Plan
(Section A)**

Honiton JCC ACF ATC

05/04/2025

**Produced to meet the requirements of the Gas Safety
(Installation and Use) Regulations 1998**

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE

Establishment: Honiton JCC ACF ATC

ESTABLISHMENT KEY PERSONALITIES (GAS) CONTACTS

Role	Name	Tel No.	Email
Head of Establishment	Brig (Retd) Neville Holmes	01823 217930 07850 655017	wx-ce@rfca.mod.uk
Establishment's SHEF	Lee S Davis	01392 307006 07850 833956	wx-dev-cqm@rfca.org.uk
Establishments 4C's Coordinator	Andrew Pritchard	07388 949747	wx-dev-acoy@rfca.org.uk
Senior DIO Estate Representative or Equivalent	Mark Cubitt	07955 280440	wx-est-hd@rfca.mod.uk
Site DIO Estate Representative or Equivalent	Kelvin Walker	07508 130359	wx-est-mgr2@rfca.mod.uk
MMO Site Manager or equivalent	Andrew Pritchard	07388 949747	wx-dev-acoy@rfca.org.uk
Gas Safety Manager (GSM)	Justin Westcott	07793222820	Justin.Westcott@vivodefence.com
Gas Responsible Person (GRP)	Riona Moroney	07854053184	Riona.moroney@vivodefence.com

The Content of this Gas Safety Management Plan (GSMP) have been Approved by the Gas Safety Manager:

Signature: *JP Westcott*

Date: 05/04/2025

Authorisation for Implementation

The content and format of this GSMP has been agreed and authorised for implementation by Defence Infrastructure Organisation Technical Services Principal Gas Engineer (DIO TS PGE) and a unique reference number has been generated to support this.

Approved – J Obbard PGE – 25 January 2024

The Content of this GSMP have been agreed by the Senior DIO Estate Representative or Equivalent and future works following the findings will be supported:

Signature:

M Cubitt

Date: 24/04/2025

The content of this GSMP have been agreed by the Head of Establishment and future works following the findings will be supported

Signature:

N Holmes

Date: 24/04/2025

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE

Establishment: Honiton JCC ACF ATC

REVIEWS AND AMMENDMENTS

GSMPs are 'living documents' that should be subject to continual review and updating as required. Although the level of attention required will vary considerably depending on the size and complexity of each site, GSMPs should be reviewed at least once per quarter by the GRP, unless otherwise agreed by the PGE. Although it is likely that changes are not required at each review, the date of review and any changes made should be indicated on the tables below. The review of the GSMP will include a site visit to ensure that the site and the content of the GSMP remain valid. The reviews and amendments made will be deleted during the DIO TS three yearly review when the GSMP is re-authorised by the PGE.

Date	Page No.	Amendment
21/06/2022	All	Initial Development
11/10/2022	N/A	No Amendments Required
16/02/2023	N/A	No Amendments Required
28/04/2023	N/A	No Amendments Required
18/07/2023	ii & 1	Updated HoE Details
31/10/2023	N/A	No Amendments Required
02/01/2024	N/A	No Amendments Required
30/04/2024	ii & 1	Updated HoE Details
31/07/2024	N/A	No Amendments Required
18/10/2024	ii, 2	Updated HoEstates
18/10/2024		GSM re-authorisation (previously authorised 02/01/2024)
19/02/2025	ii	Update GSM & GRP Contact details
19/02/2025	All	Update literature to reflect Vivo as MMO.

Date	Reviewed by	Authorised by	Comments
11/10/2022	M Fenwick	M Fenwick	Quarterly Review
16/01/2023	M Fenwick	M Fenwick	Quarterly Review
28/02/2023	M Fenwick	N King	Initial Review
28/04/2023	M Fenwick	M Fenwick	Quarterly Review
18/07/2023	M Fenwick	M Fenwick	Quarterly Review
31/10/2023	M Fenwick	M Fenwick	Quarterly Review
02/01/2024	M Fenwick	N King	Annual Review
30/04/2024	M Fenwick	M Fenwick	Quarterly Review
31/07/2024	M Fenwick	M Fenwick	Quarterly Review
18/10/2024	M Fenwick	M Fenwick	Quarterly Review
18/10/2024	Neville King	Neville King	GSM re-authorisation
24/01/2025	M Fenwick	M Fenwick	DNV De-Mobilisation Review/Handover
19/02/2025	R Moroney	R Moroney	Quarterly Review
05/04/2025	Justin Westcott	Justin Westcott	Initial review/Approval

FORWARD

MOD, as a gas conveyor within Great Britain, has submitted an Exemplar Gas Safety Case (MOD GSC) to demonstrate compliance with the Gas Safety (Management) Regulations 1996 (GS(M)R). Maintenance Management Organisations (MMO's) are engaged who have the overall contractual responsibility to operate and maintain the gas network assets under their Contract, including the management of the safe flow of gas within the system and the provision of an emergency service. The MOD delegate specific duties to the MMO but accountability for gas safety on each site rests with the Head of Establishment.

Whilst gas downstream of the Emergency Control Valve (ECV) fall outside of the scope of (GS(M)R) similar criteria as those referred to above must be accommodated within an appropriate management system. The specific criteria required to adequately manage gas infrastructure downstream of the ECV are described in the Gas Safety (Installation and Use) Regulations 1998 (GS(IU)R).

The MOD GSC considers all parts of the MOD estates gas supply system that forms part of the gas supply network. This includes all parts of the MOD gas network from the Bulk Primary Meter Installation to the individual gas appliances and the safe release of the products of combustion. The MOD GSC considers primarily those matters that relate to the management of the safe flow of gas within the system and the provision of an emergency service for all aspects of the gas system.

Following initial approval of the Gas Safety Management Plans (GSMPs) by the DIO Principal Gas Engineer (PGE), the Gas Safety Manager (GSM) is required to reapprove this GSMP annually. GSMPs must be submitted to DIO PGE every three years for authorisation.

GSMP Section A document contains site specific details of the establishments utilisation infrastructure to assist with measures to ensure compliance with the GS(IU)R for installation pipework and associated components.

GSMP Section B documents contain site specific details and arrangements as a direct annex to the MOD GSC in line with the Gas Safety (Management) Regulations 1996 (GS(M)R).

GSMP Section C document contains site specific details and requirements of the establishment's LPG networks.

Although the legal status of this document applies in the UK only, the MOD apply the same requirements to the management of gas on its overseas estate, in accordance with the currently published Secretary of State's Health and Safety policy statement.

Contents

ESTABLISHMENT KEY PERSONALITIES (GAS) CONTACTS	II
REVIEWS AND AMMENDMENTS	III
FORWARD.....	IV
1 THE DUTY HOLDER AND ESTABLISHMENT LEVEL KEY PERSONALITIES.....	1
1.1. GAS SAFETY CASE DUTY HOLDER.....	1
1.2. DIO TECHNICAL SERVICES PRINCIPAL GAS ENGINEER (PGE).	1
1.3. ESTABLISHMENT PERSONALITIES.....	1
1.4. MAINTENANCE MANAGEMENT ORGANISATION (MMO).....	2
1.5. ADDITIONAL GAS CONTACTS.	2
2 SITE SPECIFIC DETAILS.....	3
2.1 SITE OVERVIEW.	3
2.2 NATURAL GAS.....	3
2.3 LPG GAS.	3
2.4 EXTERNAL INSTALLATION PIPEWORK.	4
2.5 DETAILS OF BUILDINGS SERVED.....	4
2.6 ADDITIONAL DETAILS OF BUILDINGS BEING SERVED.....	4
3 METER DETAILS	5
3.1 PRIMARY METER DETAILS.....	5
3.2 UTILISATION METER DETAILS. (METERS SUPPLIED DIRECTLY FROM THE MOD GAS NETWORK)	5
4 DIAGRAMS AND DRAWINGS.....	6
4.1 LINE DIAGRAMS FOR BUILDING(S) INTERNAL GAS INSTALLATION PIPEWORK.	6
4.2 ADDITIONAL DRAWINGS.	6
5 GAS INCIDENTS.....	7
5.1 SITE REPORTING PROCEDURES FOR DEALING WITH GAS INCIDENTS.....	7
6 GAS EQUIPMENT	8
6.1 EQUIPMENT LIST.....	8
6.2 ADDITIONAL EQUIPMENT INFORMATION.....	8
7 ANNEXES	9

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE

Establishment: Honiton JCC ACF ATC

1 THE DUTY HOLDER AND ESTABLISHMENT LEVEL KEY PERSONALITIES

1.1. Gas Safety Case Duty Holder.

The duty holder for the MOD Gas Safety Case is the Permanent Under Secretary for Defence (PUS). However, day to day responsibility for the preparation and maintenance of the document is delegated to the DIO TS Head of Engineering and Construction, who also has the responsibility for managing the system in accordance with the Safety Case. PUS delegates maintenance responsibility to the Top-Level Budget Holders (TLB's), to manage safety of the gas network. The TLB's utilise MOD Contracts i.e. MMOs who have responsibility for maintaining the gas network on behalf of the MOD.

Name:	Permanent Under Secretary
Address:	Main Building Horse Guards Parade Whitehall London SW1A 2HB

1.2. DIO Technical Services Principal Gas Engineer (PGE).

The PGE assumes the role of Senior Authorising Authority which is a term used within the MOD to recognise the authority of the person responsible for overseeing the appointment of, and auditing Authorising Engineers (AEs). For Gas the AEs are replaced by Gas Safety Managers (GSMs).

Name:	Jeremy Obbard
Address:	DIO HQ Whittington Barracks Lichfield WS14 9TJ
☎:	07748 903260
✉:	Jeremy.obbard100@mod.gov.uk

1.3. Establishment Personalities.

Name of Establishment:	Honiton JCC ACF ATC	
Establishment Address:	Honiton JCC ACF ATC 1 King Street Honiton Devon EX14 1AB	
Head of Establishment (HoE) (This is the most senior MOD person identified, by the chain of command, as responsible for the establishment. The HoE holds accountability for ensuring site compliance with the requirements of GSMR and the MOD GSC, including this GSMP.)	Name:	Neville Holmes MBE
	Position:	Chief Executive
	Organisation:	Wessex Reserve Forces' and Cadets' Association
	Address:	Mount House Mount Street Taunton Somerset TA1 3QE
	☎:	01823 217930 or 07850 655017
	✉:	wx-ce@rfca.mod.uk
Senior DIO representative or equivalent (This may be the SEFM, but will vary depending on the contract this establishment falls under)	Name:	Mark Cubitt
	Position:	Head of Estates
	Organisation:	Wessex Reserve Forces' & Cadets' Association
	Address:	Mount House Mount Street Taunton Somerset TA1 3QE
	☎:	07955 280440
	✉:	wx-est-hd@rfca.mod.uk

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE

Establishment: Honiton JCC ACF ATC

1.4. Maintenance Management Organisation (MMO).		
The MMO for this establishment is: VIVO		
Gas Emergency Helpdesk (Typically, MMO Helpdesk) (24 Hours) Note: Please do not contact the general public National Gas Emergency Service for suspected gas escapes on RFCA infrastructure.	Organisation: ☎:	VIVO Helpdesk Helpdesk 25 Goodlass Road Hunts Cross Liverpool L24 9HJ 0800 030 9320
Gas Safety Manager (GSM)	Name: Organisation: Address: ☎: ✉:	Justin Westcott VIVO Defence Services Building 003 CTCRM Lympstone NR Exmouth Devon EX8 5AR 07793 222820 Justin.Westcott@vivodefence.com
Gas Responsible Person (GRP)	Name: Organisation: Address: ☎: ✉:	Riona Moroney VIVO Defence Services Building 003 CTCRM Lympstone NR Exmouth Devon EX8 5AR 07845053184 Riona.Moroney@vivodefence.com
1.5. Additional Gas Contacts.		
Gas Supplier	Organisation: Address: ☎: ✉:	Total Energies Gas & Power 55-57 High Street Redhill Surrey RH1 1RX 01737 275 746 gp.redhill.ccs@totalenergies.com
LPG Supplier	Organisation: Address:	Not Applicable, no bulk LPG on site.
Meter Asset Manager (MAM)	Organisation: Address: ☎: ✉:	Energy Assets Ltd 6 Almondvale Business Park Almondvale Way Livingston EH54 6GA 0800 001 4310 box.ngm.meteringdataenquiries@nationalgrid.com
National Gas Emergency Centre (24 Hours)	Organisation: ☎:	National Gas Emergency Service 0800 111 999

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE

Establishment: Honiton JCC ACF ATC

2 SITE SPECIFIC DETAILS

2.1 Site Overview.

A brief description of the establishment and its current use. This should include how many separate sites are present and the number of buildings being supplied by gas.

Honiton JCC ACF ATC is a single site establishment with 1 building on site and this building is supplied with gas direct from the EGDN network and has a single stream MAM owned and operated gas meter and regulator.

The Joint Cadet Centre is occupied by the Devon ACF Honiton Detachment and 1064 (Honiton) Squadron of the ATC.

The main building is used for office space, drill hall and Classrooms.

The site is generally unmanned day to day but can have around 30 people on site for parades.

2.2 Natural Gas.

A brief description of the natural gas installations, including how many MOD networks are present, the number of buildings each MOD network supplies and how many buildings are supplied direct from the EGDN. This should also include any demarcations in place between stakeholders and responsibilities.

The gas supply to Honiton JCC ACF ATC is fed direct from the Low Pressure (LP) EGDN network on to site and there is a 25mm PE riser entering the external meter box which runs through the EGDN ECV to feed the single stream MAM owned and operated meter and regulator which supplies the installation pipework at 21.4 mbar. (LP)

This is single supply meter 01.

The gas meter is located in a floor standing GRP meter box at the West End of the building.

Single Supply Meter 001 – Elster BK-G4M,
S/N – G4 K0007440 11 01
6m3/hr
MPRN – 9137885709

The gas pipe exits the meter box in 22mm copper for a short distance and enters the building at low level directly into the plant room. The external installation pipework is less than 0.5 metres in length.

There is an AECV on entry to the plant room and 4 metres of 22mm copper to feed the single site boiler. This is a domestic sized combi boiler in a commercial building. (38 KW)

There is only copper pipework on this installation.

2.3 LPG Gas.

A brief description of the LPG installations, including how many compounds are at the establishment, condition and make up of each compound, the number and size (kg) of vessels in each compound, the number of LPG MOD networks, the number of buildings supplied from the LPG MOD networks, how many buildings are supplied direct and not from an LPG MOD network. Details of the LPG pipework after the first stage regulator up to the building(s).

Note: The demarcation agreement between the LPG supplier and the MOD has been agreed and the MOD take responsibility from the outlet of the first stage regulator. The LPG supplier is responsible for the vessel, vessel associated components (excluding any earth bonding) pipework up to and including the first stage regulator.

No LPG on this establishment

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE

Establishment: Honiton JCC ACF ATC

2.4 External Installation Pipework.

A brief description of the external installation pipework (above or below ground) on each building. This is from the ECV to where it enters the building(s), the material, diameter, lengths, supports, conditions etc.

There is a small section of 22mm copper external installation pipework, less than 0.5 metres in length. This exits the meter box at low level and enters the building directly into the plant room.

2.5 Details of buildings served.

A list of the buildings being supplied by gas via an MOD network, LPG compound or directly from the EGDN and the usage of the gas (catering, hot water, heating, fire training, etc) at the building.

Ser	Building Number	Building description	Supplied by	Gas usage
1	Main Building	Office space, Classrooms, Drill hall	EGDN Network	Heating, Hot water.

2.6 Additional details of buildings being served.

Any additional detail about a building that may be required or useful in an emergency or requires more details than captured above.

NOTE: This section is to be used to capture the Service Family Accommodation (SFA) properties where it is not practical to fit above.

N/A

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE

Establishment: Honiton JCC ACF ATC

3 METER DETAILS

3.1 Primary Meter Details.

The following table describes the basic arrangement of the primary meter installation(s). (These are the responsibility of the MAM)

NOTE: More detail on the primary meters that supply MOD networks can be seen in the GSMP part B.

Number of primary meter installations:		1 (EGDN Single Supply)							
Meter Name / ID	MPRN	Supplying (MOD network ID or Bldg number)	location	Incoming pressure tier – HP, IP, MP, LP	Outlet pipeline				Max Flow (M ³ hr)
					P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	
Single Supply Primary Fiscal Meter 01	9137885709	Main Building	West End of Building – Floor Mounted Meter Box	LP	LP	21.4	Copper	22	6

3.2 Utilisation Meter Details. (meters supplied directly from the MOD gas network)

The following table describes the basic arrangement of the utilisation meter installation(s). (These are the responsibility of the MOD)

Number of utilisation meter installations:		N/A – No MoD Network on Site								
Meter Name / ID	Being supplied from (MOD network ID)	Inlet pipeline				Outlet pipework				Max Flow (M ³ hr)
		P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE


Establishment: Honiton JCC ACF ATC

4 DIAGRAMS AND DRAWINGS

4.1 Line diagrams for building(s) internal gas installation pipework.

This section is to contain line diagrams for building internal installation pipework and associated components. This diagram should be fixed to the building at a practical and accessible location as well as within any associated document centres. It may be embedded as a PDF to this document for online use.

NOTE: Drawings are only required for commercial installations or for installation in commercial settings (non-domestic use). This may mean more installations than listed in IGEM/UP/2 Edition 3 (4.2.14), depending on the installations intended use.

Drawing Number	Building	Comments
WX44-A-A3	Main Building	Not to Scale Gas Installation Line Drawing.
		 WX44-A-A3.pdf

4.2 Additional drawings.

This section is to contain any additional drawings that may be required or may be of benefit to this GSMP or emergency procedures.

Drawing Number	Building	Comments

5 GAS INCIDENTS

5.1 Site reporting procedures for dealing with gas incidents.

This section is to contain the establishment's site-specific procedure for dealing with reports of gas incidents with regards the external installation pipework, internal installation pipework and equipment. Details of all individuals with responsibilities under this procedure should be included.

Procedure for an incident involving the gas installations on site:

- Call VIVO Helpdesk line on 0800 030 9320, open 24 hours per day.
- VIVO helpdesk will contact 0800 111 999
- The EGDN shall attend and make safe a gas incident.
- Vivo Gas Responsible Person shall be informed immediately by the site personnel.

Unique Document Reference:

Establishment: Honiton JCC ACF ATC

WX44-A-20240125

Issued by DIO TS PGE

6 GAS EQUIPMENT**6.1 Equipment List.**

This section is to include details of all the gas equipment being used at the establishment.

Building number	Equipment location	Equipment type (make, model)	Serial Number	Appliance kW rating	Flue classification	Comments
Main Building	Plant Room	Worcester Greenstar 38Cdi Classic Boiler	3730-520-001637-773100252	38	Room Sealed	

6.2 Additional equipment information.

This section is to contain any additional equipment information that may be required or may be of benefit to this GSMP or emergency procedures.

Not Applicable

Unique Document Reference:
WX44-A-20240125
Issued by DIO TS PGE

Establishment: Honiton JCC ACF ATC

7 ANNEXES

Gas Line Drawing

