



# Defence Infrastructure Organisation

## **Gas Safety Management Plan (Section A)**

**Bath ARC RMR AFCO ACF ATC**

**18/03/2025**

**Produced to meet the requirements of the Gas Safety  
(Installation and Use) Regulations 1998**

Unique Document Reference:

Establishment: Bath ARC RMR AFCA ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

**ESTABLISHMENT KEY PERSONALITIES (GAS) CONTACTS**

Role	Name	Tel No.	Email
Head of Establishment	Lt. Col. Lee Crompton	07846 820884	<a href="mailto:Lee.crompton575@mod.gov.uk">Lee.crompton575@mod.gov.uk</a>
Establishment's SHEF	Capt J Ledgister	01225 492302	<a href="mailto:john.ledgister803@mod.gov.uk">john.ledgister803@mod.gov.uk</a>
Establishments 4C's Coordinator	Mark Lynn (Caretaker)	01225 492302 Ext 6	<a href="mailto:mark.lynn553@mod.gov.uk">mark.lynn553@mod.gov.uk</a>
Senior DIO Estate Representative or Equivalent	Mark Cubitt	07955 280440	<a href="mailto:wx-est-hd@rfca.mod.uk">wx-est-hd@rfca.mod.uk</a>
Site DIO Estate Representative or Equivalent	Rory Simpson (Estates Manager)	01823 217941 07957 436139	<a href="mailto:wx-est-mgr2@rfca.mod.uk">wx-est-mgr2@rfca.mod.uk</a>
MMO Site Manager or equivalent	Paul Wakeford	07356 101565	<a href="mailto:paul.wakeford@vivodefence.com">paul.wakeford@vivodefence.com</a>
Gas Safety Manager (GSM)	Justin Westcott	07793 222820	<a href="mailto:justin.westcott@vivodefence.com">justin.westcott@vivodefence.com</a>
Gas Responsible Person (GRP)	Ian Bradley	07793 222771	<a href="mailto:ian.bradley1@vivodefence.com">ian.bradley1@vivodefence.com</a>

The Content of this Gas Safety Management Plan (GSMP) have been Approved by the Gas Safety Manager:

Signature: *JP Westcott*

Date: 18/03/2025

**Authorisation for Implementation**

The content and format of this GSMP has been agreed and authorised for implementation by Defence Infrastructure Organisation Technical Services Principal Gas Engineer (DIO TS PGE) and a unique reference number has been generated to support this.

Approved – J Obbard PGE – 15 January 2024

The Content of this GSMP have been agreed by the Senior DIO Estate Representative or Equivalent and future works following the findings will be supported:

Signature:

*M Cubitt*

Date: 23/04/2025

The content of this GSMP have been agreed by the Head of Establishment and future works following the findings will be supported

Signature: ... *L Crompton*

...Date.....23 Apr 25

Issued by DIO TS PGE

GSMPs are 'living documents' that should be subject to continual review and updating as required. Although the level of attention required will vary considerably depending on the size and complexity of each site, GSMPs should be reviewed at least once per quarter by the GRP, unless otherwise agreed by the PGE. Although it is likely that changes are not required at each review, the date of review and any changes made should be indicated on the tables below. The review of the GSMP will include a site visit to ensure that the site and the content of the GSMP remain valid. The reviews and amendments made will be deleted during the DIO TS three yearly review when the GSMP is re-authorised by the PGE.

[illegible]

Unique Document Reference:

Establishment: Bath ARC RMR AFCO ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

Date	Reviewed by	Authorised by	Comments
30/11/2022	D. Cooper	Neville King	Initial development
25/02/2023	D. Cooper		Q1 review
25/05/2023	D. Cooper		Q2 review
25/08/2023	D. Cooper		Q3 review
24/11/2023	D. Cooper		Annual review
23/02/2024	D. Cooper		Q1 review
10/05/2024	D. Cooper		Q2 review
27/09/2024	D. Cooper		Q3 review
17/10/2024	Neville King	Neville King	GSM re-authorisation
11/12/2024	D. Cooper		DNV demobilisation review (site visit)
17/02/2025	Ian Bradley	J Westcott	Initial Review
18/03/2025	J Westcott	J Westcott	Initial review/approval

WX02-A-20240115

Issued by DIO TS PGE

---

**FORWARD**

MOD, as a gas conveyor within Great Britain, has submitted an Exemplar Gas Safety Case (MOD GSC) to demonstrate compliance with the Gas Safety (Management) Regulations 1996 (GS(M)R). Maintenance Management Organisations (MMO's) are engaged who have the overall contractual responsibility to operate and maintain the gas network assets under their Contract, including the management of the safe flow of gas within the system and the provision of an emergency service. The MOD delegate specific duties to the MMO but accountability for gas safety on each site rests with the Head of Establishment.

Whilst gas downstream of the Emergency Control Valve (ECV) fall outside of the scope of (GS(M)R) similar criteria as those referred to above must be accommodated within an appropriate management system. The specific criteria required to adequately manage gas infrastructure downstream of the ECV are described in the Gas Safety (Installation and Use) Regulations 1998 (GS(IU)R).

The MOD GSC considers all parts of the MOD estates gas supply system that forms part of the gas supply network. This includes all parts of the MOD gas network from the Bulk Primary Meter Installation to the individual gas appliances and the safe release of the products of combustion. The MOD GSC considers primarily those matters that relate to the management of the safe flow of gas within the system and the provision of an emergency service for all aspects of the gas system.

Following initial approval of the Gas Safety Management Plans (GSMPs) by the DIO Principal Gas Engineer (PGE), the Gas Safety Manager (GSM) is required to reapprove this GSMP annually. GSMPs must be submitted to DIO PGE every three years for authorisation.

GSMP Section A document contains site specific details of the establishments utilisation infrastructure to assist with measures to ensure compliance with the GS(IU)R for installation pipework and associated components.

GSMP Section B documents contain site specific details and arrangements as a direct annex to the MOD GSC in line with the Gas Safety (Management) Regulations 1996 (GS(M)R).

GSMP Section C document contains site specific details and requirements of the establishment's LPG networks.

Although the legal status of this document applies in the UK only, the MOD apply the same requirements to the management of gas on its overseas estate, in accordance with the currently published Secretary of State's Health and Safety policy statement.

WX02-A-20240115

Issued by DIO TS PGE

## Contents

<b>ESTABLISHMENT KEY PERSONALITIES (GAS) CONTACTS .....</b>	<b>II</b>
<b>REVIEWS AND AMMENDMENTS .....</b>	<b>III</b>
<b>FORWARD.....</b>	<b>V</b>
<b>1 THE DUTY HOLDER AND ESTABLISHMENT LEVEL KEY PERSONALITIES.....</b>	<b>1</b>
1.1. GAS SAFETY CASE DUTY HOLDER.....	1
1.2. DIO TECHNICAL SERVICES PRINCIPAL GAS ENGINEER (PGE).....	1
1.3. ESTABLISHMENT PERSONALITIES.....	1
1.4. MAINTENANCE MANAGEMENT ORGANISATION (MMO).....	2
1.5. ADDITIONAL GAS CONTACTS.....	2
<b>2 SITE SPECIFIC DETAILS.....</b>	<b>4</b>
2.1 SITE OVERVIEW.....	4
2.2 NATURAL GAS.....	4
2.3 LPG GAS.....	5
2.4 EXTERNAL INSTALLATION PIPEWORK.....	5
2.5 DETAILS OF BUILDINGS SERVED.....	6
2.6 ADDITIONAL DETAILS OF BUILDINGS BEING SERVED.....	6
<b>3 METER DETAILS .....</b>	<b>7</b>
3.1 PRIMARY METER DETAILS.....	7
3.2 UTILISATION METER DETAILS (METERS SUPPLIED DIRECTLY FROM THE MOD GAS NETWORK).....	7
<b>4 DIAGRAMS AND DRAWINGS.....</b>	<b>8</b>
4.1 LINE DIAGRAMS FOR BUILDING(S) INTERNAL GAS INSTALLATION PIPEWORK.....	8
4.2 ADDITIONAL DRAWINGS.....	8
<b>5 GAS INCIDENTS.....</b>	<b>9</b>
5.1 SITE REPORTING PROCEDURES FOR DEALING WITH GAS INCIDENTS.....	9
<b>6 GAS EQUIPMENT .....</b>	<b>10</b>
6.1 EQUIPMENT LIST.....	10
6.2 ADDITIONAL EQUIPMENT INFORMATION.....	11
<b>7 ANNEXES .....</b>	<b>12</b>

Unique Document Reference:

Establishment: Bath ARC RMR AFCO ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

## 1 THE DUTY HOLDER AND ESTABLISHMENT LEVEL KEY PERSONALITIES

### 1.1. Gas Safety Case Duty Holder.

The duty holder for the MOD Gas Safety Case is the Permanent Under Secretary for Defence (PUS). However, day to day responsibility for the preparation and maintenance of the document is delegated to the DIO TS Head of Engineering and Construction, who also has the responsibility for managing the system in accordance with the Safety Case. PUS delegates maintenance responsibility to the Top-Level Budget Holders (TLB's), to manage safety of the gas network. The TLB's utilise MOD Contracts i.e. MMOs who have responsibility for maintaining the gas network on behalf of the MOD.

Name:	Permanent Under Secretary
Address:	Main Building Horse Guards Parade Whitehall London SW1A 2HB

### 1.2. DIO Technical Services Principal Gas Engineer (PGE).

The PGE assumes the role of Senior Authorising Authority which is a term used within the MOD to recognise the authority of the person responsible for overseeing the appointment of, and auditing Authorising Engineers (AEs). For Gas the AEs are replaced by Gas Safety Managers (GSMs).

Name:	Jeremy Obbard
Address:	DIO HQ Whittington Barracks Lichfield WS14 9TJ
☎:	07748 903260
✉:	Jeremy.obbard100@mod.gov.uk

### 1.3. Establishment Personalities.

Name of Establishment:	Bath ARC RMR AFCO ACF ATC	
Establishment Address:	Upper Bristol Road, Bath, BA1 3AE.	
Head of Establishment (HoE)  (This is the most senior MOD person identified, by the chain of command, as responsible for the establishment. The HoE holds accountability for ensuring site compliance with the requirements of GSMR and the MOD GSC, including this GSMP.)	Name: Position: Organisation: Address:  ☎: ✉:	Lt Col Lee Crompton Head of Establishment MoD, British Army 93 Signal Squadron Regimental Headquarters Horfield Army Reserve Centre Dorian Road Bristol BS7 0XL 07846 820884 <a href="mailto:Lee.crompton575@mod.gov.uk">Lee.crompton575@mod.gov.uk</a>

Unique Document Reference:

Establishment: Bath ARC RMR AFCA ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

Senior DIO representative or equivalent  (This may be the SEFM, but will vary depending on the contract this establishment falls under)	Name: Mark Cubitt Position: Head of Estates Organisation: Wessex Reserve Forces' and Cadets' Association Address: Mount House Mount Street Taunton Somerset TA1 3QE 07955 280440 ☎: <a href="mailto:wx-est-hd@rfca.mod.uk">wx-est-hd@rfca.mod.uk</a>
---	---

**1.4. Maintenance Management Organisation (MMO).**

The MMO for this establishment is:		VIVO
Gas Emergency Helpdesk (24 Hours)	Organisation: VIVO Helpdesk 25 Goodlass Road Hunts Cross Liverpool L24 9HJ ☎: 0800 030 9320 ✉: <a href="mailto:helpdesk@vivodefence.com">helpdesk@vivodefence.com</a>	
Gas Safety Manager (GSM)	Name: Justin Westcott Organisation: VIVO Address: Building 002, CTCRM Lympstone Nr Exmouth Devon, EX8 5AR ☎: 07793 222820 ✉: <a href="mailto:justin.westcott@vivodefence.com">justin.westcott@vivodefence.com</a>	
Gas Responsible Person (GRP)	Name: Ian Bradley Organisation: VIVO Address: Trenchard Lines, Upavon, Pewsey, Wiltshire. SN9 6BE ☎: 07793 222771 ✉: <a href="mailto:ian.bradley1@vivodefence.com">ian.bradley1@vivodefence.com</a>	

**1.5. Additional Gas Contacts.**

External Gas Distribution Network (EGDN)	Organisation: Wales & West Utilities Ltd Address: Wales & West House Spooners Close Celtic Springs Coedkernew Newport, NP10 8FZ ☎: 0800 912 2999 ✉: <a href="mailto:Steve.harding@wwutilities.co.uk">Steve.harding@wwutilities.co.uk</a>
--	---










Unique Document Reference:

Establishment: Bath ARC RMR AFCO ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

Gas Supplier	Organisation: Address:   :  :	TotalEnergies Gas & Power 55-57 High Street, Redhill, Surrey, RH1 1RX. 01737 275 746 <a href="mailto:gp.redhill.ccs@totalenergies.com">gp.redhill.ccs@totalenergies.com</a>
LPG Supplier	Organisation: Address:   :  :	Not applicable - no bulk LPG on site.
Meter Asset Manager (MAM)	Organisation: Address:   :  :	Energy Assets Ltd 6 Almondvale Business Park, Almondvale Way, Livingston EH54 6GA 01506 405 405 <a href="mailto:info@energyassetsnetworks.co.uk">info@energyassetsnetworks.co.uk</a>
National Gas Emergency Centre (24 Hours)	 :	0800 111 999

WX02-A-20240115

Issued by DIO TS PGE

## 2 SITE SPECIFIC DETAILS

### 2.1 Site Overview.

A brief description of the establishment and its current use. This should include how many separate sites are present and the number of buildings being supplied by gas.

Bath ARC has two buildings on site, plus a Caretaker's flat within the main building which are supplied with gas from the low-pressure EGDN. There are individual EGDN supplies on this site for two gas meters.

Building (1) is used for Office Space, Kitchen, Drill Hall a plantroom and Caretaker's flat.

Building (2) is used as a workshop/garage.

During the working week there is up to 70 members of staff on site.

The Army Cadets attend on Mondays from 19:00 until 21:00 hrs for parade.

### 2.2 Natural Gas.

A brief description of the natural gas installations, including how many MOD networks are present, the number of buildings each MOD network supplies and how many buildings are supplied direct from the EGDN. This should also include any demarcations in place between stakeholders and responsibilities.

The gas supplied to Bath ARC is fed from an EGDN single feed low pressure network which supplies three primary meters (one disconnected) all of which are in a plant room on the western side of the building.

Main Building BFPM

Feeds the main building and workshop from the MoD Low pressure installation. The gas is used for catering, heating and hot water.

**Primary Meter 1:** BK-G40 (65m<sup>3</sup>/hr)

**Location:** Meter Room

**Serial No:** M065 K11550 14 D6

**MPRN:** 3479902

**Pressure Tier:** LP

The MoD is responsible from the meter outlet valve of the meter (demarcation point) up to and including the appliances in the main building and workshop.

**Plant Room** - From the meter 3" steel enters the plant room that has an AECV and drop valve at low level before rising to high level. At high level the pipework reduces to 2" steel to feed two 150kw boilers and at another tee from the 3" installation pipework it reduces to 1 1/4" steel to supply a 58.3 kw gas water heater.

**Kitchen** - From the meter a 1 1/4" steel installation pipe travels within the building to the kitchen AECV and then reduces to 28mm copper at a solenoid valve before continuing in copper to supply a 47kw range, 30kw Bullseye range and 22kw fryer. The fryer disconnected by supply chain contractor (Boden) on 30/9/2024.

Unique Document Reference:

Establishment: Bath ARC RMR AFCO ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

**Workshop** - From the BFPM a 1¼" steel installation pipe from high level exits the building travels along a boundary wall before dropping to low level to enter the workshop.

On entering the workshop there is a 1¼" AECV and purge valve. After the AECV the installation pipework rises to high level to feed a 54kw air heater.

#### **Caretaker's Meter**

The meter for the caretaker's flat is fed from an EGDN low pressure network (21mb) from the meter outlet a 28mm copper pipe travels within the main building to the caretakers flat, before transitioning to 22mm copper under the 30kw boiler.

**Primary Meter 2:** BK-G4 (6m3/hr)

**Location:** Meter Room

**Serial No:** G4 K0124792 01 01

**MPRN:** 4224401603

**Pressure Tier:** LP

The MoD is responsible from the meter outlet valve of both meters (demarcation point) up to and including the appliances in the two buildings.

**Meter 3 does not have a gas supply connected with the ECV being capped.**

The meter is fed from an EGDN low pressure network (21mb)

Model: E6S – Serial number SOO31262 98 11 - MPRN: TBC

This meter previously fed Harding House, which is now outside of the wire and not used by the MoD and is now known as Sterling House. The meter has been disconnected at its inlet and is not required.

### **2.3 LPG Gas.**

A brief description of the LPG installations, including how many compounds are at the establishment, condition and make up of each compound, the number and size (kg) of vessels in each compound, the number of LPG MOD networks, the number of buildings supplied from the LPG MOD networks, how many buildings are supplied direct and not from an LPG MOD network. Details of the LPG pipework after the first stage regulator up to the building(s).

*Note: The demarcation agreement between the LPG supplier and the MOD has been agreed and the MOD take responsibility from the outlet of the first stage regulator. The LPG supplier is responsible for the vessel, vessel associated components (excluding any earth bonding) pipework up to and including the first stage regulator.*

No LPG installation on this site.

### **2.4 External Installation Pipework.**

A brief description of the external installation pipework (above or below ground) on each building. This is from the ECV to where it enters the building(s), the material, diameter, lengths, supports, conditions etc.

Unique Document Reference:

Establishment: Bath ARC RMR AFCO ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

1½" Steel pipe exits the plantroom and travels for 33m externally at high level to feed a heater in the workshop. The pipe is correctly supported is in good condition but has insufficient gas indicator tape on it.

### 2.5 Details of buildings served.

A list of the buildings being supplied by gas via an MOD network, LPG compound or directly from the EGDN and the usage of the gas (catering, hot water, heating, fire training, etc) at the building.

Ser	Building Number	Building description	Supplied by	Gas usage
1	Main building	Offices, kitchen and workshop	EGDN	Heating, hot water and catering.
2	Caretaker's flat	Accommodation	EGDN	Heating and hot water.
3	3	Offices	EGDN	Disconnected and Capped at ECV
4				
5				

### 2.6 Additional details of buildings being served.

Any additional detail about a building that may be required or useful in an emergency or requires more details than captured above.

*NOTE: This section is to be used to capture the Service Family Accommodation (SFA) properties where it is not practical to fit above.*

N/A.

Unique Document Reference:

Establishment: Bath ARC RMR AFCC ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

### 3 METER DETAILS

#### 3.1 Primary Meter Details.

The following table describes the basic arrangement of the primary meter installation(s). (These are the responsibility of the MAM)

*NOTE: More detail on the primary meters that supply MoD networks can be seen in the GSMP part B.*

<b>Number of primary meter installations:</b>			2						
Meter Name / ID	MPRN	Supplying (MOD network ID or Building number)	location	Incoming pressure tier – HP, IP, MP, LP	Outlet pipeline				Max Flow (M <sup>3</sup> hr)
					P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	
M065 K11550 14 D6	3479902	Main building	Boiler room	LP	LP	NOM	Steel	80	65
G4 KO1247792 01 01	4224401603	Caretaker's flat	Boiler room	LP	LP	NOM	Copper	22	6
E6 S0031262 98 11	TBC	3	Boiler room	LP	LP	NOM	Copper	22	6

#### 3.2 Utilisation Meter Details (meters supplied directly from the MoD gas network).

The following table describes the basic arrangement of the utilisation meter installation(s). (These are the responsibility of the MOD)

<b>Number of utilisation meter installations:</b>			N/A							
Meter Name / ID	Being supplied from (MOD network ID)	Inlet pipeline				Outlet pipework				Max Flow (M <sup>3</sup> hr)
		P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	P tier – HP, IP, MP, LP	Pressure (mbar)	Material	Diameter (mm)	

Unique Document Reference:

Establishment: Bath ARC RMR AFCO ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

## 4 DIAGRAMS AND DRAWINGS

### 4.1 Line diagrams for building(s) internal gas installation pipework.

This section is to contain line diagrams for building internal installation pipework and associated components. This diagram should be fixed to the building at a practical and accessible location as well as within any associated document centres. It may be embedded as a PDF to this document for online use.

*NOTE: Drawings are only required for commercial installations or for installation in commercial settings (non-domestic use). This may mean more installations than listed in IGEN/UP/2 Edition 3 (4.2.14), depending on the installations intended use.*

Drawing Number	Building	Comments
SW-BATH RFCA-GAS-SCH-001	Main building, workshop and caretaker's flat.	

### 4.2 Additional drawings.

This section is to contain any additional drawings that may be required or may be of benefit to this GSMP or emergency procedures.

Drawing Number	Building	Comments

WX02-A-20240115

Issued by DIO TS PGE

## 5 GAS INCIDENTS

### 5.1 Site reporting procedures for dealing with gas incidents.

This section is to contain the establishment's site-specific procedure for dealing with reports of gas incidents with regards the external installation pipework, internal installation pipework and equipment. Details of all individuals with responsibilities under this procedure should be included.

#### Procedure for an incident involving the External Installation Pipework on site:

- Call VIVO Helpdesk Team on **0800 030 0930** open 24 hours per day.
- Helpdesk will in turn will call National Grid **0800 111 999** to attend and make safe a gas incident.
- VIVO Helpdesk Team will send a text message to alert the Responsible Person Gas who should attend/discuss the incident with the Site Team/POC.
- Once the 1<sup>st</sup> Responders have attended and made safe, the Site Team should contact the VIVO Helpdesk and raise a job to repair the reported leak and get the gas reinstated.
- Out of hours is as above.

#### Procedure for an incident involving the Internal Installation Pipework on site:

- Call VIVO Helpdesk Team on **0800 030 9320** open 24 hours per day.
- Helpdesk will in turn will call National Grid **0800 111 999** to attend and make safe a gas incident.
- VIVO Helpdesk Team will send a text message to alert the Responsible Person Gas who should attend/discuss the incident with the Site Team/POC.
- Once the 1<sup>st</sup> Responders have attended and made safe, the Site Team should contact the VIVO Helpdesk and raise a job to repair the reported leak and get the gas reinstated.
- Out of hours is as above.

#### Procedure for Equipment Faults:

- Call VIVO Helpdesk Team on **0800 030 9320** open 24 hours per day.
- VIVO Helpdesk Team will raise a job for a contractor to attend, repair and reinstate the equipment.
- Out of hours is as above.

Unique Document Reference: Establishment: Bath ARC RMR AFCC ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

## 6 GAS EQUIPMENT

### 6.1 Equipment List.

This section is to include details of all the gas equipment being used at the establishment.

Building number	Equipment location	Equipment type (make, model)	Serial Number	Appliance kW rating	Flue classification	Comments
Main building	Plantroom	Ideal Evomax 2 boiler (1)	22082000000239	150	Open Fan flued	New 2021
Main building	Plantroom	Ideal Evomax boiler (2)	22082000000240	150	Open Fan flued	New 2021
Main building	Plantroom	Andrews Ecoflo water heater	AD53302452	58.3	Fan flued	New Oct 2024. Installed by MFM. Commissioning paperwork requested 3/1/25.
Main Building	Kitchen	Blue Seal 6 burner range cooker	N/A	47	Flueless	No record available. Data badge not readable.
Main Building	Kitchen	Blue Seal 6 bullseye range cooker	N/A	30	Flueless	No record available. Data badge not accessible.
Main Building	Kitchen	Zanussi fryer	N/A	22	Flueless	No record available. Data badge not accessible. Turned off 30/9/24 by supply chain contractor (Boden)
Workshop	Garage area	Reznor air heater	N/A	54	Open flue	No record available. Appliance at high level, data badge not accessible.
Caretaker's flat	Spare room	Ideal Independent 30 combi	21543500002343	30	Fan flued	



Unique Document Reference: Establishment: Bath ARC RMR AFCO ACF ATC

WX02-A-20240115

Issued by DIO TS PGE

**6.2 Additional equipment information.**

This section is to contain any additional equipment information that may be required or may be of benefit to this GSMP or emergency procedures.

Kitchen Canopy Gas Interlock is installed in main building kitchen, with SSOV, and emergency stop valve adjacent to kitchen door.

WX02-A-20240115  
Issued by DIO TS PGE

7 ANNEXES

